

Mississippi Power and Light Company
ATTN: Mr. J. B. Richard
Senior Vice President, Nuclear
P. O. Box 1640
Jackson, MS 39205

Gentlemen:

SUBJECT: REPORT NOS. 50-416/84-01 and 50-417/84-02

Thank you for your response of March 28, 1984, to our Notice of Violation issued on February 29, 1984, concerning activities conducted at your Grand Gulf facility.

In review of your Emergency Plan Procedure 10-S-01-05, "General Emergency," we find that you failed to incorporate an initial protective action recommendation of sheltering upon declaration of a General Emergency. This must be added to the Procedure in order for it to meet current regulations. Therefore, correction of Emergency Plan Procedure 10-S-01-05 is necessary. A supplemental response on this matter is requested within 20 days of receipt of this letter.

We appreciate your cooperation in this matter.

Sincerely,

R. C. Lewis, Director
Division of Reactor Projects

cc:
J. E. Cross, Plant Manager
Ralph T. Lodly, Manager of
Quality
Middle South, Services, Inc.

bcc:
NRC Resident Inspector
Document Control Desk
State of Mississippi

RII <i>RM</i>	RII <i>WC</i>	RII <i>DC</i>	RII <i>kc</i>	RII <i>CJ</i>	RII <i>DV</i>	RII <i>JS</i>	RII <i>RL</i>
RMarston	WCline	DCollins	kCarroll	CJulian	DVerrelli	JStohr	RLewis
5/2/84	5/2/84	5/2/84	5/2/84	5/2/84	5/2/84	5/2/84	5/3/84