

ENCLOSURE 1

NOTICE OF VIOLATION

Mississippi Power & Light
Grand Gulf 1 and 2

Docket Nos. 50-416 and 417
License Nos. NPF-13 & CPPR-119

The following violation was identified during an inspection conducted on January 16-17, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50.54(q) requires that nuclear power reactor licensees follow and maintain in effect emergency plans which meet the requirements of Appendix E to 10 CFR Part 50 and the planning standards of 50.47(b). Section (b) (10) of 10 CFR 50.47 requires that the licensee's emergency plans shall include information to demonstrate that a range of protective actions have been developed for the plume exposure pathway EPZ for emergency workers and the public, and that guidelines for the choice of protective actions during an emergency, consistent with Federal guidance, are developed and in place.

The Federal Guidance on the protective actions to be recommended to offsite officials for general emergencies is addressed in Appendix 1 of NUREG 0654/FEMA-REP-1, Rev. 1, entitled "Criteria for Preparation and Evaluation of Radiological Emergency Preparedness in support of Nuclear Power Plants." This guidance is clarified by IE Information Notice No. 83-28: "Criteria for Protective Action Recommendations for General Emergencies."

Contrary to the above, the licensee has failed to incorporate the above guidance in the Implementing Procedures in that there is no mechanism or requirement for determining directly from containment and core status what offsite protective action recommendations will be made.

This is a Severity Level IV Violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

8407060062 840619
PDR ADOCK 05000416
Q PDR

Mississippi Power and Light Company 2
Notice of Violation

Docket Nos. 50-416 and 50-417
License Nos. NPF-13 & CPPR-119

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: FEB 29 1984