

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

June 27, 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1&2
Information for Containment Systems
Branch (CSB) Regarding SER Confirmatory
Issue No. 20 (Procedures for Hydrogen
Recombiner Operation)

Reference: Procedure No. S58.1.B, Revision 1:
Start-Up of a Containment Hydrogen
Recombiner from the Standby Condition
or Following a Trip

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:


We are pleased to offer the following information in order to close out SER confirmatory issue #20.

Section 7.2 of the reference procedure provides the following precaution to ensure that initiation of a hydrogen recombiner will not create a steam bypass path that could cause the containment design pressure to be exceeded:

"Following an accident, do not place the hydrogen recombiners in service until the reactor has been depressurized."

Should any additional information be required, please do not hesitate to contact us.

Sincerely,



JHA/gra/06188408

cc: See Attached Service List

8407060173 840627
PDR ADOCK 05000352
PDR

Boo!
1/0

cc: Judge Lawrence Brenner
Judge Richard F. Cole
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency
Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing
Appeal Board
Atomic Safety & Licensing
Board Panel
Docket & Service Section
Martha W. Bush, Esq.
Mr. James Wiggins
Mr. Timothy R. S. Campbell
Ms. Phyllis Zitzer
Judge Peter A. Morris