



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

March 14, 1984

U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Attention: Mr. Thomas T. Martin, Director  
Division of Engineering and Technical Programs

Gentlemen:

RESPONSE TO INSPECTION TEAM FINDINGS  
NRC COMBINED INSPECTION 50-272/84-05 and 50-311/84-05  
SALEM GENERATING STATION, UNITS NO. 1 AND 2  
DOCKET NOS. 50-272 AND 50-311

Our letter dated February 10, 1984, provided Public Service Electric & Gas (PSE&G) Company's response to two concerns identified during the subject inspection. In response to one concern related to the use of double U-bolts as pipe support anchors, we committed to conducting a test program to verify our U-bolt analytical model. Attached is Specification No. ND-SA-84-01 which represents the program procedure. We are currently proceeding with securing a vendor laboratory to implement the test programs; thus, a prompt review and comments would be greatly appreciated.

Sincerely,

E. A. Liden  
Manager - Nuclear  
Licensing and Regulation

TP:mg

Attachment

8407060312 840615  
PDR ADCK 05000272  
G PDR

The Energy People

C: Mr. James Linville  
Senior Resident Inspector

Mr. Donald C. Fischer  
NRC Project Manager