

yellow

JUN 18 1984

Tennessee Valley Authority
ATTN: Mr. H. G. Parris
Manager of Power and Engineering
500A Chestnut Street Tower II
Chattanooga, TN 37401

Gentlemen:

SUBJECT: REPORT NOS. 50-438/84-03 AND 50-439/84-03

Thank you for your response of March 30, 1984, to our Notice of Violation issued on February 29, 1984, concerning activities conducted at your Bellefonte facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions for examples (1) and (4) of the violation during future inspections.

After careful review of the basis for your denial of examples (2), (3) and (5) we have determined that additional inspection will be required to determine the validity of your arguments. Therefore, we have designated this to be an unresolved item Nos. 50-438, 439/84-03-02, "Concrete Expansion Anchor Bolt Installation Requirements and Pipe Gap Tolerance for Hanger OKC-MPHG-1378-R2," pending further NRC inspection.

We appreciate your cooperation in this matter.

Sincerely,

RL

Richard C. Lewis, Director
Division of Reactor Projects

- cc: E. Condon, Bellefonte Nuclear Plant Engineering Coordinator
- A. M. Qualls, Plant Manager
- J. W. Anderson, Manager
Office of Quality Assurance
- H. N. Culver, Chief, Nuclear Safety Staff
- W. R. Brown, Jr., Bellefonte Nuclear Plant Project Manager
- D. L. Williams, Jr., Supervisor
Licensing Section
- K. D. Mali, Project Engineer
- L. S. Cox, Construction Project Manager

8407060318 840618
PDR ADOCK 05000438
PDR

bcc: NRC Resident Inspector
Document Control Desk
State of Tennessee

See prior conc.

11

RII	RII	RII	RII	RII	RII
WLi:dr 6/ /84	JBlake 6/ /84	AHerdt 6/ /84	JOlshinski 6/ /84	DVerrelli 6/ /84	RLewis 6/ /84

1501

Tennessee Valley Authority
ATTN: Mr. H. G. Parris
Manager of Power and Engineering
500A Chestnut Street Tower II
Chattanooga, TN 37401

Gentlemen:

SUBJECT: REPORT NOS. 50-438/84-03 AND 50-439/84-03

Thank you for your response of March 30, 1984, to our Notice of Violation issued on February 29, 1984, concerning activities conducted at your Bellefonte facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions for examples (1) and (4) of the violation during future inspections.

After careful review of the basis for your denial of examples (2), (3) and (5) we have determined that additional inspection will be required to determine the validity of your arguments, therefore we have designated this to be an unresolved item Nos. 50-438, 439/84-03-02, "Concrete Expansion Anchor Bolt Installation Requirements and Pipe Gap Tolerance for Hanger OKC-MPHG-1378-R2," pending further NRC inspection.

We appreciate your cooperation in this matter.

Sincerely,

RS

Richard C. Lewis, Director
Division of Reactor Projects

cc: J. A. Coffey, Director of Nuclear Power
A. M. Qualls, Plant Superintendent
L. S. Cox, Project Manager
W. R. Brown, Jr., OEDC Project Manager
J. W. Anderson, Manager
Office of Quality Assurance
H. N. Culver, Chief, Nuclear Safety
Review Staff
D. L. Williams, Jr., Supervisor
Licensing Section
M. K. D. Mali, Project Engineer

bcc: NRC Resident Inspector
Document Control Desk
State of Tennessee

RII
W Liu
W Liu:dr
6/12/84

RII
BC for
JBlake
6/12/84

RII
A Herdt
A Herdt
6/12/84

RII
S Jolshinski
Jolshinski
6/15/84

PCY
W E D Peterson
6/18/84
RII
D Verrelli
D Verrelli
6/18/84

RII
R C Lewis
R C Lewis
6/18/84