

BOSTON EDISON COMPANY
300 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

WILLIAM D. HARRINGTON
SENIOR VICE PRESIDENT
NUCLEAR

June 28, 1984
BECO. 84-095

Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing
Office of Nuclear Regulatory Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

License No. DPR-35
Docket No. 50-293

Dear Sir:

On May 2, 1984, a telephone conference took place regarding the Pilgrim Nuclear Power Station Inservice Inspection Program. Participants at this meeting were P. Leech from the NRC; G. Freund and R. Yorg from EG&G; and F. Famulari, T. Ferris, and M. Williams from Boston Edison Company. Eleven items were discussed, in which resolution was reached on NRC Items 1, 2, and 3. This letter provides information for resolution of the remaining items (4-11).

Item 4

NRC Request

Your letter to NRC (answer to NRC Question #2, BECo , #82-296, dated 11/15/84) mentioned that none of the welds in the recirculation pump casing were pressure-retaining. Please provide cross-section drawings of your pumps that show the casing welds.

BECO. Response

The requested reactor recirculation pump cross-section drawings are provided as Attachments 1 and 2 to this letter.

Item 5

NRC Request

Concerning relief request PRR-3, your answers to NRC Question #1 submitted in BECo letter 82-296, stated that some Class 1 valves had been disassembled for maintenance. What were the results of the visual examinations of their internal surfaces? If they have been previously furnished to the NRC, please document by reference.

8407090249 840628
PDR ADOCK 05000293
Q PDR

A047
11

BECo. Response

The requested information has been submitted to the NRC in the following Inservice Inspection Final Reports:

1. 1977 Inservice Inspection of Pilgrim Nuclear Power Station, Unit 1-Volume 1.
2. 1980 Inservice Inspection of Pilgrim Nuclear Power Station, Unit 1-Volume 1.
3. 1981 Inservice Inspection of Pilgrim Nuclear Power Station, Unit 1-Volume 3.

Item 6

NRC Request

Please identify any class 1 valves (and their categories) that have been disassembled since November 1982. What were the results of the visual examinations on their internal surfaces? If they have been previously furnished to the NRC, please document by reference.

BECo. Response

No Class I valves have been disassembled from November 1982 through December 10, 1983. Pilgrim Nuclear Power Station commenced the current refueling outage on December 10, 1983. The valves, listed in Attachment 3, are or will be disassembled and a VT-3 visual examination of the internal surfaces will be performed during this outage. The results of the examination will be transmitted as part of the 1984 Inservice Inspection Final Report.

Item 7

NRC Request

Please provide a drawing or sketch of your reactor vessel that shows the locations of the longitudinal and circumferential shell welds. The drawing should indicate which welds are in the beltline (core) region. Also give the percentage of each beltline weld that is accessible, whether internally or externally, to either volumetric or remote visual (VT-1) examination (PRR-4).

BECo Response

A reactor vessel layout drawing delineating the beltline region welds and the portions accessible for ultrasonic examination from the vessel exterior is provided as Attachment 4 to this letter. As shown, ten percent of each longitudinal weld and five percent of each circumferential weld are accessible for examination. Due to the BWR vessel interior configuration, the beltline region welds are not accessible for ultrasonic examination from the vessel interior.

Also, it should be noted that the reactor vessel interior is in the as-welded cladded condition. Thus, a remote visual (VT-1) examination to determine the condition of the underlying beltline region is not a meaningful examination.

Item 8

NRC Request

Item B1.21 and B1.22 of Category B-A (PRR-5) require that the accessible portions up to 100% of one head weld in each direction be examined. It appears that your program meets code requirements for examining head welds. Please state why you believe that relief is needed.

BECO. Response

The reactor vessel bottom head meridional welds are accessible for ultrasonic examination. However, the configuration of the reactor vessel bottom head and vessel support skirt limits the examination of the outer circumferential weld to a one side only examination. See Attachments 5 and 6 for drawings depicting the accessible welds and the restrictions. Approximately sixty percent of the length of the reactor vessel bottom head welds is accessible for examination. Revised Relief Request No. PRR-5 is submitted as Attachment 7.

Item 9

NRC Request

The containment atmospheric control system (PRR-7) would seem to be exempt from code NDE by IWC-1220(b). Please state why you believe that relief is needed.

BECO. Response

IWC-1220 (b) states the following components are exempt from the inservice examination requirements of IWC-2500:

"(b) Components of systems or portions of systems, other than Residual Heat Removal Systems and Emergency Core Cooling Systems, that are not required to operate above a pressure of 275 psig (19.00 KPa) or above a temperature of 200°F (93°C)."

The containment atmospheric control system, CACS, at PNPS normally operates at a pressure of 1 psig and a temperature of 50°F. However, the CACS maximum operating pressure and temperature is 56 psig and 281°F, respectively.

IWC-1220(b) does not specifically state that the exemption applies to systems that normally do not operate above the specified values. Therefore, since the maximum operating temperature of 281°F exceeds the 200°F temperature required for exemption by IWC-1220(b), Relief Request No. PRR-7 was submitted.

Item 10NRC Request

Of the code-allowed exemptions listed on pages 4-2 and 4-3 of your program, only one, EX-5, excludes ECCS and RHR systems. Please confirm that none of the other listed exemptions includes ECCS and RHR systems.

BECo. Response

Code-allowed exemptions, EX-3, EX-5 and EX-10, do not apply to the ECC and RHR systems at PNPS. The remaining listed exemptions do apply to the ECC and RHR systems.

Item 11NRC Request

Concerning your Inservice Inspection Checklist for the 1983/1984 refueling outage (Enclosure A to BECo letter 83-290, dated 12/1/83), the nozzle-to-vessel weld item (23.90) contains a remark that there is limited access. If the code examination requirements cannot be met on any nozzles, a relief request should be submitted that identifies the nozzles and degree of accessibility. Certain other items in the table (such as those in Category B-A and B-J) should be attributed to existing relief requests.

BECo Response

The code examination requirements cannot be met on the twenty-one nozzles located within the biological shield due to the reactor vessel insulation/biological shield configuration. Relief Request PRR-9 has been prepared and is submitted as Attachment 8 to this letter.




If after reviewing this information you have any further questions, please contact us.

Very truly yours,

WJ Hanington

Attachments



RECIRC PUMP SUSPENSION LUGS
 920 D 797
 FCF 730E 822 (PLGRM)




DISTRIBUTION

COMP	DATE	BY	REVISION
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

RECHTEL CORP.
 NEW HAVEN, CT





TRUSS
 100000
 100000



Also Available On Aperture Card

- (1) CONTROLLED BLEED OFF (2) VAL LEAKAGE DRAIN
- (3) PRESSURE COMP ODS (4) TRANSDUCERS (5) (6) (7) TRANSDUCERS (8) (9) (10) TRANSDUCERS
- (11) TRANSDUCERS (12) TRANSDUCERS (13) TRANSDUCERS (14) TRANSDUCERS (15) TRANSDUCERS
- (16) TRANSDUCERS (17) TRANSDUCERS (18) TRANSDUCERS (19) TRANSDUCERS (20) TRANSDUCERS

Attachment 1



NOTES:

- 1. THIS IS A TRANSFER LOAD FROM LEFT TO RIGHT AND NOT A TENSION LOAD
- 2. PUMP ROTOR ASSEMBLY TO BE PURCHASED AND INSTALLED BY OWNER AND NOT BY MANUFACTURER
- 3. PUMP ROTOR ASSEMBLY TO BE DELIVERED TO SITE. DRAWING TO BE USED FOR SITE CONSTRUCTION ONLY


APR 13 1968

8407090249-01
 M-IE-12-1

REVISIONS

NO.	DATE	DESCRIPTION
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		

920 D 797
 FCF 730E 822 (PLGRM)



RECEIVED
APR - 9 1970
JOB 60
PLM:JLN:MAA

Also Available On
Aperture Card

SCANNING CLEARANCE IN INCHES ON DIAMETER	
A	100 - 104
B	200 - 204
C	0.18 - 0.18
D	0.15 - 0.15
E	0.10 - 0.10

REACT. RECIRED. PUMP

VERTICAL RECIRCULATING PUMP
BYRON JACKSON DIV
BORG-WARNER CORP
1 IF-5602

APERTURE CARD

PILGRIM STATION
GENERAL ELECTRIC CO.
APR - 20 1970
VPE # 1775-18-1
EP # 202-1

EP # 202-1
G.E. ORDER # 202-18075

8407080249-02

CERTIFIED
by VENDOR
APPROVED
By _____
Date _____
FOR
ASBOK (SAS) 10-10-10
SEE THE CERTIFICATE
FOR APPROVED SECTION

CERTIFIED

By _____
Date _____
Byron Jackson Pumps, Inc.
A Division of Borg-Warner Corp.

VPE 1775-18-1
MIE


Attachment 2

Attachment 3



VALVES SCHEDULES FOR DISASSEMBLY DURING RFO #6
AS OF MAY 18, 1984



<u>GROUP</u>	<u>SYSTEM</u>	<u>VALVE NO.</u>
1	HPCI	2301-4
3	Main Steam	203-1A
		203-1B
		203-1C
		203-1D
		203-2A
		203-2B
		203-2C
		203-2D
9	RHR	1001-29A
		1001-29B
		1001-50
13	Feedwater	6-58A
		6-58B
		6-62A
		6-62-B
19	Main Steam	203-3A
		203-3B
		203-3C
		203-3D
20	Main Steam	203-4A
		203-4B
		203-4C
		203-4D

E-232-336



WE CAN ONLY PERFORM A ONE SIDED EXAM DUE TO THE VESSEL SKIRT

-  Inaccessible Welds
-  Accessible Welds



SECTION A-A
SCALE 1/2\"/>

1. CHECK ALL DIMENSIONS
2. REVIEW ALL DIMENSIONS
3. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
4. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
5. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
6. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
7. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
8. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
9. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION
10. CHECK FOR ANY DIMENSIONS MADE FOR FABRICATION




FIGURE 4.2-4
 REACTOR VESSEL-SKIRT INSULATION
 PILGRIM NUCLEAR POWER STATION
 FINAL SAFETY ANALYSIS REPORT

RELIEF REQUEST NO PRR-5 Rev. 1

I. IDENTIFICATION OF COMPONENTS AND IMPRACTICAL CODE REQUIREMENTS.

The reactor pressure vessel bottom head contains seventeen circumferential and meridional welds.

Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter 1980 Addenda requires a volumetric examination of 100 percent of the length of one meridional head weld and one circumferential head weld each inspection interval (Code Category B-A).

Relief is requested from the above mentioned Code requirements on the basis of inaccessibility.

II. BASIS FOR RELIEF

As discussed in Relief Request PRR-4, accessibility for examination of these welds was not considered in the plant design. The configuration of the vessel support skirt attachment weld and the reactor vessel skirt insulation limits the examination of the outer circumferential weld to a one side only examination.

III. ALTERNATE PROVISIONS

Boston Edison will perform a volumetric examination of the reactor vessel outer circumferential weld from one side only.

Attachment 8

RELIEF REQUEST NO. PRR-9

I. IDENTIFICATION OF COMPONENTS AND IMPRACTICAL CODE REQUIREMENTS

The reactor vessel is designed with 21 nozzle-to-vessel welds located within the biological shield weld.

The ASME Boiler & Pressure Vessel Code, Section XI "Rules for Inservice Inspection of Nuclear Power Plant Components", 1980 Edition, Winter 1980 Addenda, Table IWB-2500-1, Category B-D, Item Number B3.90 requires that a volumetric examination of each nozzle-to-vessel weld be conducted. These examinations are required to be completed each inspection interval.

II. BASIS FOR RELIEF

Relief is requested from the above mentioned code requirements on the basis that 100% accessibility is not permitted due to the reactor vessel insulation/biological shield configuration. Accessibility for the examination of all nozzle-to-vessel welds was not provided for in the original plant design which occurred prior to the issuance of Section XI requirements.

III. ALTERNATE PROVISIONS

The reactor nozzle-to-vessel welds will be volumetrically examined to the extent practicable.