

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)
of)
PUBLIC SERVICE COMPANY OF COLORADO) Docket No. 50-267


Application for Amendment to
Appendix A of Facility Operating License
License No. DPR-34

OF THE
PUBLIC SERVICE COMPANY OF COLORADO
FOR THE
FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to Appendix A of
Facility Operating License, License No. DPR-34,
is submitted for NRC review and approval.

Respectfully submitted,
PUBLIC SERVICE COMPANY OF COLORADO

By O. R. Lee, Vice President



KELLY, STANSFIELD & O'DONNELL
Bryant O'Donnell
Robert E. Thompson
Public Service Company Building
Denver, Colorado 80202

Attorneys for Applicant

ATTACHMENT 1

SUMMARY OF PROPOSED CHANGES

SUMMARY OF PROPOSED CHANGES

<u>Section</u>	<u>Description Of Change</u>
LCO 4.4.1	<ol style="list-style-type: none">1) Pages 4.4-1 and 4.4-2 - minor word changes relating to the addition of Table 4.4-5.2) Page 4.4-7 - Addition of Table 4.4-5, Instrument Operating Requirements For 480V A.C. Essential Bus Undervoltage Protection.3) Page 4.4-8 - Revisions to Notes (d) and (e) for clarification.4) Page 4.4-9 - Addition of "new" Note (u).5) Page 4.4-10 - Additional statement concerning Table 4.4-5.
SR 5.4	<ol style="list-style-type: none">1) Added e) to SR 5.4.1 and corrected typographical errors in the SR and Basis.2) Table 5.4-3, Item 5 - Corrected typographical errors.3) Added Table 5.4-5 concerning checks, calibrations, and tests of 480V A.C. Essential Bus Undervoltage Protection.4) Renumbered the remaining pages of Section 5.4.

ATTACHMENT 2

PROPOSED CHANGES