



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

June 26, 1984

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

PRINCIPAL STAFF	
✓	✓
D/RA	DRS
RC	CRSS
PAO	ML
SGA	DL
EIC	DT
DRMA	FILE

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Use of Non-Class 1E Control Power
and Control Components in Diesel
Generator Building Ventilation
Systems [RDC 80(83)]

Dear Mr. Keppler:

Our letter to you dated May 15, 1983, stated that final field rewiring for diesel generator building ventilation start signals was expected to be completed by June 15, 1984.

Field rewiring to implement the design modification for initiating the start signal from a safety-related circuit that contains only safety-related components has been completed, however, site acceptance of this work is pending submittal and review of supporting documentation. Documentation review for the subject rewiring is expected to be completed by July 15, 1984.

Sincerely,
A. Kaplan for M. Edelman
M. R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. J. A. Grobe
USNRC, Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8407100141 840626
PDR ADOCK 05000440
S PDR

JUN 29 1984

FE27 1/0