

MS 016

JUN 26 1984

Docket No. 50-368

Mr. John M. Griffin, Senior Vice President  
Energy Supply  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

DISTRIBUTION:

- Docket File
- NRC PDR
- Local PDR
- ORB#3 Rdg
- DEisenhut
- OELD
- EJordan
- JNGrace
- RSLee
- PMKreutzer
- ACRS (10)

Dear Mr. Griffin:

We have completed our evaluation of your responses to NRC Generic Letter 81-14, "Seismic Qualification of Auxiliary Feedwater Systems," dated February 10, 1981. We conclude that the auxiliary feedwater system at ANO-2 has sufficient seismic capability to withstand earthquakes up to the postulated Safe Shutdown Earthquake and accomplish its safety function.

A copy of our Safety Evaluation with the attached Technical Evaluation Report from our contractor, Lawrence Livermore National Laboratory, is enclosed.

Sincerely,

Original signed by:

James R. Miller, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure:  
As stated

cc: See next page

B407100636 B40626  
PDR ADOCK 05000368  
P PDR

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL				
SURNAME	PKreutzer	RSLee:dd	JRMiller				
DATE	6/22/84	6/22/84	6/22/84				