

Docket File



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

October 5, 1995

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT 2, ADMINISTRATIVE
CORRECTION TO AMENDMENT NO. 69 (TAC NO. M91295)

Dear Mr. Sylvia:

The purpose of this letter is to correct an administrative error in
Amendment No. 69 for Unit 2, which was issued September 11, 1995. In order to
properly reflect previously issued Amendment No. 66, please replace
page 3/4 4-10 of Amendment No. 69 with the enclosed page.

Sincerely,

Gordon E. Edison, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosure: As stated

cc w/encl: See next page

9510110163 951005
PDR ADOCK 05000410
P PDR

NRG FILE CENTER COPY

DFD 1/1

B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, NY 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Resident Inspector
Nine Mile Point Nuclear Station
P.O. Box 126
Lycoming, NY 13093

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, NY 12210

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. Kim A. Dahlberg
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P.O. Box 63
Lycoming, NY 13093

Ms. Denise J. Wolniak
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Richard B. Abbott
Vice President - Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. John V. Vinquist, MATS Inc.
P.O. Box 63
Lycoming, NY 13093

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY/RELIEF VALVES

LIMITING CONDITIONS FOR OPERATION

3.4.2 The safety valve function of at least 16 of the following reactor coolant system safety/relief valves shall be OPERABLE with the specified code safety valve function lift settings*:

- 2 safety/relief valves @ 1165 psig $\pm 1\%$
- 4 safety/relief valves @ 1175 psig $\pm 1\%$
- 4 safety/relief valves @ 1185 psig $\pm 1\%$
- 4 safety/relief valves @ 1195 psig $\pm 1\%$
- 4 safety/relief valves @ 1205 psig $\pm 1\%$

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

- a. With the safety valve function of one or more of the above required 16 safety/relief valves inoperable, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
- b. With one or more safety/relief valves stuck open, provided that the average water temperature in the suppression pool is less than 110°F, close the stuck-open safety/relief valve(s); if unable to close the open valve(s) within 5 minutes or if the average water temperature in the suppression pool is 110°F or more, place the reactor mode switch in the Shutdown position.

* The lift setting pressure shall correspond to ambient conditions of the valves at nominal operating temperatures and pressures.