



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
101 MARIETTA STREET, N.W.  
ATLANTA, GEORGIA 30303

ENCLOSURE 1

EXAMINATION REPORT

Facility Licensee: Duke Power Company  
422 South Church Street  
Charlotte, NC 28242

Facility Name: Catawba Nuclear Station

Facility Docket No. 50-413

Oral examinations were administered at the Catawba Nuclear Station near Clover, South Carolina.

Chief Examiner:

Tony Vinnoia  
Tony Vinnoia

8/29/84  
Date Signed

Approve by:

Bruce A. Wilson  
Bruce A. Wilson, Section Chief

8/30/84  
Date Signed

Summary:

Examinations on July 25-26, 1984

Oral re-examinations were administered to four candidates, three of whom passed.

8410100374 840906  
PDR ADOCK 05000413  
Q PDR

REPORT DETAILS

1. Persons Examined

SRO Candidates:

Homer T. Baumgardner, II  
Stacy S. Cooper  
Tony D. Williams

RO Candidates:

Rex B. Parker

Other Facility Employees Contacted:

\*J. W. Hampton, Plant Manager  
\*C. W. Graves, Jr., Superintendent of Operations  
\*G. Smith, Superintendent of Maintenance  
\*L. Schmid, Operations Engineer

\*Attended Exit Meeting

2. Examiner:

\*\*Tony Vinnola

\*\*Chief Examiner

Exit Meeting

At the conclusion of the site visit the examiner met with representatives of the plant staff to discuss the results of the examinations. Those individuals who clearly passed the oral examination were identified.

There were generic weaknesses (greater than 75 percent of candidates giving incorrect answers to one examination topic) noted during the oral examination. The areas of below-normal performance were: steam generator level setpoint indication, the bases for dilute and alternate dilute modes of reactor makeup, centrifugal pump theory, reactor coolant pump seal arrangement, and rod control system circuit components.