

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

OCT 04 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1 and 2
Pre-Operational Tests, Construction and
Fire Protection Deferrals

- References:
- 1) V. S. Boyer to A. Schwencer letter dated June 21, 1984.
 - 2) J. S. Kemper to A. Schwencer letter dated July 17, 1984.
 - 3) R. J. Stipcevich (PECO) and Byron Siegel (NRC) Conference Call dated 9/24/84.

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

In reference letters no. 1 and 2 we requested certain pre-operational tests, construction and fire protection items be deferred until after fuel load in accordance with the technical justifications provided.

Since the time our request was made several of the items identified in our deferral request letters have been completed and consequently should be dropped from further consideration and not incorporated as license conditions in our low power license. The individual deferral items to be deleted were given to Mr. B. Siegel in the reference telephone call and are as follows:

- Pre-operational Tests - 1P16.1 - Residual Heat Removal Service Water System.
- 1P79.2B - Offgas Pretreatment and Radiation Monitoring.
- 1P79.2C - Main Steam Line Radiation Monitoring.
- Construction - Wrapping of Cables for Raceway Separation Criteria Compliance.

8410100468 841004
PDR ADDCK 05000352
A PDR


B002
10

Fire Protection

- Encapsulation of Raceway Required for Safe Shutdown.
- Heat Shield and Spill Protection - Load Centers at EL 313 Reactor Building.
- Repair to Existing Structural Steel Coating.
- Internal Seals for Conduits That Penetrate Fire Barriers.

All other deferral items in reference letters no. 1 and 2 remain unchanged. Should you require additional information or clarification, we would be pleased to discuss this in greater detail.

Sincerely,



RJS/gra/10018402

cc: See Attached Service List

cc: Judge Helen F. Hoyt
Judge Jerry Harbour
Judge Richard F. Cole
Judge Christine N. Kohl
Judge Gary J. Edles
Judge Reginald L. Gotchy
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Ms. Phyllis Zitzer
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugaman, Esq.
Martha W. Bush, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing Appeal Board
Atomic Safety & Licensing Board Panel
Docket & Service Section
Mr. James Wiggins
Mr. Timothy R. S. Campbell