

NOTICE OF NONCONFORMANCE

Westinghouse Electric Corporation
Pittsburgh, Pennsylvania

Docket No.: 52-003
99900404

Based on the results of a Nuclear Regulatory Commission (NRC) inspection of Westinghouse Electric Corporation's AP600 Automatic Depressurization System (ADS) Phase B test program at the Ente Nazionale Energia e Ambiente (ENEA) VAPORE Test Facility, conducted on July 24 through July 26, 1995, it was determined that activities supporting Westinghouse Electric Corporation's AP600 design certification program, were not conducted in accordance with NRC requirements as identified below:

- A. Section 9.0, "Quality Assurance Requirements" of WCAP-14112, "Automatic Depressurization System Test Specification (Phase B1)," Revision 2, and Section 7.0, "As-Built Records" of ENEA document AP600-GQ9402, "Quality Assurance Plan Description: AP600 Test Program Conducted at the VAPORE Plant in ENEA Cassacia (Phase B)," Revision 2, provide for and require the preparation and maintenance of VAPORE test facility as-built drawings which pertain to the ADS Phase B tests that characterize the features which influence thermal-hydraulic and structural parameters for code validation and calculation methodology verification efforts.

Contrary to the above, as-built drawings, as defined and stipulated in WCAP-14112 and AP600-GQ9402, had not been generated for AP600 ADS Phase B testing at VAPORE. (95-02-01).

Please provide a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Chief, Special Inspection Branch, Division of Inspection and Support Programs, Office of Nuclear Reactor Regulation, within 30 days of the date of the letter transmitting this Notice of Nonconformance. This reply should be clearly marked as a "Reply to a Notice of Nonconformance" and should include for each nonconformance: (1) a description of the steps that were or will be taken to correct these items; (2) a description of the steps that have or will be taken to prevent recurrence; and (3) the dates your corrective actions and preventative measures were or will be completed.

Dated at Rockville, Maryland
This _____ day of _____, 1995

Enclosure 1

9510120282 951006
PDR GA999 EMVWEST
99900404 PDR