PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-84-59

Date: 9/4/84

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

FACILITY: Washington Public Power Supply System (WPPSS)

Washington Nuclear Project No. 2

Docket No. 50-397

Benton County, Washington

Licensee Emergency Classification XX Notification of Unusual Event

Alert

Site Area Emergency General Emergency

Not Applicable

Notification of Unusual Event Due to Apparent Fire SUBJECT:

At 1330 on 9/1/84 the site fire brigade and local fire department were called because of an apparent fire in the wellhouse. It was subsequently determined that a fire did not occur, but smoke had resulted from a lube oil leak on the diesel-driven fire pump, which was operating at the time. The licensee subsequently declared and terminated a notification of unusual event. The plant was operating at 66% power and was not affected by the event.

This PN is issued for information only.

This information is current as of 8:00 a.m. (PDT) on September 4, 1984.

CONTACT: A. Toth

FTS 444-0608

D. Willett FTS 463-3744

## DISTRIBUTION

H St.	MNBB	Phillips	E/W	Willste	Air Rights	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans
Comm. Bernthal	MPA		AEOD			Only
Comm. Roberts	ELD					
Comm. Asselstine		Regions:				
SECY		INPO	NSAC			
ACRS		Licensee				
CA		(Reactor	Licensees	3)	REGION V	7: FCRM 211
PDR		Resident	Inspector		(Revised	1 3/14/83)

8410100657 840904 PDR 1&E PNO-V-84-059