

RECEIVED
NRC

Arizona Public Service Company

1984 SEP 27 AM 10:58

September 24, 1984 REGION V:10F

ANPP-30635-TDS/TRB

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Time Extension For Report - DER 84-50
A 50.55(e) Potentially Reportable Deficiency Relating To Main
Steam Isolation Valves Do Not Close Within Five Seconds As
Required.
File: 84-019-026; D.4.33.2

Reference: (A) Telephone conversation between D. Hollenbach and
T. Bradish on July 24, 1984
(B) ANPP-30316, dated August 23, 1984 (Interim Report)


Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available by
September 25, 1984.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by October 25, 1984, at
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVB/TRB/nj

cc: See Page Two

8410100667 840924
PDR ADOCK 05000528
S PDR

1/0 IE-27

Mr. T. W. Bishop
DER 84-50
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
R. P. Zimmerman
S. R. Frost
L. Clyde
M. Woods
T. J. Bloom

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339