

Arizona Public Service Company

September 20, 1984  
ANPP-30590-TDS/TRB

U. S. Nuclear Regulatory Commission  
Region V  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Director  
Division of Resident  
Reactor Projects and Engineering Programs

Subject: Time Extension For Report - DER 83-63  
A 50.55(e) Potentially Reportable Deficiency Relating To  
HPSI Isolation Valves By Borg-Warner Failed To Open Against  
HPSI 'A' and 'B' Pump Flows.  
File: 84-019-026; D.4.33.2

Reference: (A) Telephone conversation between P. Narbut and R. Tucker on  
September 20, 1983  
(B) ANPP-28072, dated October 24, 1984 (Interim Report)  
(C) ANPP-28954, dated February 28, 1984 (Time Extension)  
(D) ANPP-29131, dated March 22, 1984 (Final Report)  
(E) Telephone conversation between P. Narbut and T. Bradish on  
April 2, 1984  
(F) ANPP-29395, dated April 30, 1984 (Revised Interim Report)  
(G) ANPP-29971, dated July 16, 1984 (Time Extension)  
(H) ANPP-30420, dated September 4, 1984 (Time Extension)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in  
Reference (A), an Interim Report was transmitted by Reference (B), a  
Time Extension was requested by Reference (C), and a Final Report was  
transmitted by Reference (D).

The NRC was notified in Reference (E) that the corrective action  
specified in Reference (D) failed to correct the deficiency and the  
subject DER had been re-opened. A revised Interim Report was submitted  
in Reference (F) and Time Extensions were requested in Reference (G) and  
(H). At that time it was estimated that a Final Report would be  
available by September 21, 1984.


8410110050 840920  
PDR ADOCK 05000528  
S PDR

REGION V  
RECEIVED  
1/0 IE-27  
1984 SEP 26 PM 12 19

Mr. T. W. Bishop  
DER 83-63  
Page Two

A Final Report has been submitted to APS for review. It is expected this Final Report will be transmitted to the NRC by October 16, 1984.

Very truly yours,



E. E. Van Brunt, Jr.  
APS Vice President  
Nuclear Production  
ANPP Project Director

EEVB/TRB/nj

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
D. B. Karner  
W. E. Ide  
D. B. Fasnacht  
A. C. Rogers  
L. A. Souza  
D. E. Fowler  
T. D. Shriver  
C. N. Russo  
J. Vorees  
J. R. Bynum  
J. M. Allen  
J. A. Brand  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
H. D. Foster  
D. R. Hawkinson  
L. E. Vorderbrueggea  
R. P. Zimmerman  
S. R. Frost  
L. Clyde  
M. Woods  
T. J. Bloom

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, GA 30339