

OPERATING DATA REPORT

DOCKET NO. 50-302
 DATE 7/3/84
 COMPLETED BY D. Graham
 TELEPHONE (904) 795-3802

OPERATING STATUS

1. Unit Name: Crystal River Unit 3
2. Reporting Period: 6/1/84 - 6/30/84
3. Licensed Thermal Power (MWt): 2544
4. Nameplate Rating (Gross MWe): 890
5. Design Electrical Rating (Net MWe): 825
6. Maximum Dependable Capacity (Gross MWe): 860
7. Maximum Dependable Capacity (Net MWe): 821
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
N/A

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>4367</u>	<u>64007</u>
12. Number Of Hours Reactor Was Critical	<u>720</u>	<u>4061.1</u>	<u>41630.3</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1280.3</u>
14. Hours Generator On-Line	<u>720</u>	<u>4022.6</u>	<u>40641.6</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1745267</u>	<u>9650175</u>	<u>91614510</u>
17. Gross Electrical Energy Generated (MWH)	<u>595526</u>	<u>3337607</u>	<u>31264343</u>
18. Net Electrical Energy Generated (MWH)	<u>567690</u>	<u>3181773</u>	<u>29698856</u>
19. Unit Service Factor	<u>100%</u>	<u>92.1%</u>	<u>63.5%</u>
20. Unit Availability Factor	<u>100%</u>	<u>92.1%</u>	<u>63.5%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>96.0%</u>	<u>88.7%</u>	<u>58.6%</u>
22. Unit Capacity Factor (Using DER Net)	<u>95.6%</u>	<u>88.3%</u>	<u>56.2%</u>
23. Unit Forced Outage Rate	<u>0%</u>	<u>2.6%</u>	<u>21.9%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
None

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>_____</u>	<u>1/14/77</u>
INITIAL ELECTRICITY	<u>_____</u>	<u>1/30/77</u>
COMMERCIAL OPERATION	<u>_____</u>	<u>3/13/77</u>

JE24
1/1

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-302

UNIT FLCRP-3

DATE 7/3/84

COMPLETED BY D. Graham

TELEPHONE (904) 795-3802

MONTH June 1984

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>820</u>	17	<u>831</u>
2	<u>803</u>	18	<u>825</u>
3	<u>813</u>	19	<u>833</u>
4	<u>797</u>	20	<u>812</u>
5	<u>803</u>	21	<u>810</u>
6	<u>790</u>	22	<u>810</u>
7	<u>791</u>	23	<u>818</u>
8	<u>799</u>	24	<u>813</u>
9	<u>538</u>	25	<u>810</u>
10	<u>633</u>	26	<u>813</u>
11	<u>825</u>	27	<u>801</u>
12	<u>824</u>	28	<u>789</u>
13	<u>831</u>	29	<u>770</u>
14	<u>828</u>	30	<u>578</u>
15	<u>824</u>	31	<u> </u>
16	<u>822</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-302
 UNIT NAME ELCRP-3
 DATE 7/3/84
 COMPLETED BY S.A. Stewart
 TELEPHONE (904) 795-3802

REPORT MONTH 6/84

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
84-24	840608	S	0	B	5	N/A	HC	HTEXCH	Reduced power to clean waterboxes.
84-25	840629	S	0	B	5	N/A	HC	HTEXCH	Reduced power to clean waterboxes.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

MONTHLY OPERATIONAL SUMMARY STATEMENT

DOCKET NO. 50-302

UNIT FLCRP-3


DATE 7/3/84

COMPLETED BY S.A.Stewart

TELEPHONE (905) 795-3802

MONTH June 1984

SUMMARY STATEMENT: The plant remained on-line the entire month of June. Condenser Delta-T limitations restricted power for part of the month. The plant reduced power twice for condenser waterbox cleaning.



**Florida
Power**
CORPORATION

July 9, 1984
3F0784-05

Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Monthly Operating Report

Dear Sir:

Attached are twelve (12) copies of the Crystal River Unit 3 June 1984 Monthly Operating Report. This report is submitted in accordance with Technical Specification 6.9.1.6.

Sincerely,

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

DVH/feb

Attachments

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30323

TE29
11