



Carolina Power & Light Company

SERIAL: NLS-84-232

JUN 1 1984

04 JUN 5 12:31

Mr. James P. O'Reilly, Regional Administrator
United States Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NO. 1 - DOCKET NO. 50-400

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62

SUPPLEMENTAL RESPONSE TO IE BULLETIN NO. 83-06

Dear Mr. O'Reilly:

SUMMARY

By letters dated November 18, 1983 (Serial No. LAP-83-531), November 15, 1983 (Serial No. LAP-83-525), and November 18, 1983 (Serial No. LAP-83-533), Carolina Power & Light Company responded to IE Bulletin 83-06, "Nonconforming Materials Supplied by Tube-Line Corporation Facilities At Long Island City, New York; Houston, Texas; and Carol Stream, Illinois." Carolina Power & Light Company (CP&L) provides the following additional information concerning the status of actions taken in response to the bulletin.

DISCUSSION

The general concerns expressed in the bulletin were reviewed for applicability to CP&L, as requested. As part of our review, CP&L investigated the possible use of additional inspection and testing during receipt inspection to strengthen quality assurance capabilities in detection of fraudulently supplied material. In the responses referenced above, CP&L stated it would report the results of the above referenced investigation. A program is scheduled to be implemented during the third quarter of 1984 at each of CP&L's nuclear power plants which will reduce the probability of accepting fraudulent or nonconforming materials (safety-related pipe, pipe fittings, and pipe components) during receipt inspections. Improved receipt inspection capabilities will be provided by including additional visual inspection, criteria and training, alloy verification, and hardness testing.

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8407160194 840601
PDR ADOCK 05000261
Q PDR

IE 11/10


Mr. James P. O'Reilly

-2-

JUN 1 1984

If you need any additional information regarding this response, please contact Mr. Sherwood R. Zimmerman at (919) 836-6242.

Yours very truly,




A. B. Cutter - Vice President
Nuclear Engineering & Licensing

WRM/pgp (142WRM)

cc: Mr. B. C. Buckley (NRC)
Mr. Grotenhuis (NRC)
Mr. G. F. Maxwell (NRC-SHNPP)
Mr. D. O. Myers (NRC-BSEP)
Mr. Travis Payne (KUDZU)
Mr. Daniel F. Read (CHANGE/ELP)
Chapel Hill Public Library
Wake County Public Library

Mr. Wells Eddleman
Dr. Phyllis Lotchin
Mr. G. Requa (NRC)
Mr. John D. Runkle
Mr. S. Weise (NRC-HBR)
Dr. Richard D. Wilson
Mr. G. O. Bright (ASLB)
Dr. J. H. Carpenter (ASLB)
Mr. J. L. Kelley (ASLB)

A. B. Cutter, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, contractors, and agents of Carolina Power & Light Company.


Notary (Seal)

My commission expires: OCT 04 1986

