


Appendix 3B. Figures

Figure 3-1. Wind Pressure Distribution on Reactor Building



WIND PRESSURE DISTRIBUTION ON THE REACTOR BUILDING

Figure 3-2. Turbine Building Tornado Wind Distributions




Figure 3-2.
Turbine Building Tornado Wind Distributions
(13 APRIL 2001)

Figure 3-3. Fire Protection System Piping Penetration Detail




Figure 3-4. Turbines Missiles Projected Areas (Low Pressure Turbine Rotor Discs)




Figure 3-5. Loss of Reactor Coolant Accident Boundary Limits





Figure 3-6. Location of Postulated Breaks



Note:
 References 3 and 4 provide the basis for eliminating the previously postulated reactor coolant system pipe breaks with the exception of those breaks at branch connections.

Figure 3-7. Analytical Method for Resolving Pipe Break Consequences




Figure 3-8. Deleted per 2001 Update

Figure 3-9. Main Steam and Feedwater Routing Plan Outside Containment. See 3-10 for Elevation View.




Figure 3-10. Main Steam and Feedwater Routing Elevation Outside Containment [Historical information, not required to be revised.]




Figure 3-11. Main Steam Routing Plan Outside Containment




Figure 3-12. Main Steam Routing Elevation Outside Containment Nearest Reactor Building Wall

Figure 3-13. Main Steam Routing Elevation Outside Containment Farthest From Reactor Building Wall




Figure 3-14. Main Feedwater Routing Plan Outside Containment

Figure 3-15. Main Feedwater Routing Elevation A-A Outside Containment




Figure 3-16. Response Acceleration Spectra [Historical information, not required to be revised.]




Figure 3-17. Response Acceleration Spectra [Historical information, not required to be revised.]




Figure 3-18. Response Acceleration Spectra [Historical information, not required to be revised.]




Figure 3-19. Multi-Degree of Freedom System with Support Motion




Figure 3-20. Reactor Building Interior Structure - Mass Model [Historical Information, not required to be revised.]




Figure 3-21. Auxiliary Building Mass Model [Historical Information, not required to be revised.]




Figure 3-22. Reactor Building 1st and 2nd Horizontal Mode Shapes




Figure 3-23. Reactor Building 1st and 2nd Vertical Mode Shapes




Figure 3-24. Reactor Building - Shear Force (lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-25. Reactor Building - Meridional Force N_0 (lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-26. Reactor Building - Meridional Moment M_0 (lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-27. Reactor Building - Membrane Shear N (lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-28. Reactor Building-Hoop Force N_0 (lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-29. Reactor Building-Hoop Moment M_0 (in.lb/in) Due to SSE [Historical information, not required to be revised.]




Figure 3-30. Containment Interior Structure, First Four Horizontal Mode Shapes, North-South Direction




Figure 3-31. Containment Interior Structure, First Four Horizontal Mode Shapes, East-West Direction




Figure 3-32. Containment Interior Structure - First Two Vertical Mode Shapes [Historical information, not required to be revised.]




Figure 3-33. Containment Interior Structure Response Loads Due to SSE in the North-South Direction [Historical information, not required to be revised.]




Figure 3-34. Containment Interior Structure Response Loads Due to SSE in the East-West Direction [Historical information, not required to be revised.]




Figure 3-35. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 738.22




Figure 3-36. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 768.22




Figure 3-37. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 789.47

Figure 3-38. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 817.92




Figure 3-39. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 841.85




Figure 3-40. Reactor Building and Base Rock Finite Element Representation






Figure 3-41. Reactor Building First Horizontal Mode



NODE	MODE 1			
	FREQ.=4.997CPS		FREQ.=4.892CPS	
	FIXED BASE —	SOIL INTER.---	R	Z
1	R	Z	R	Z
2	0.1	-0.6	0.5	-1.6
3	8.3	-4.0	8.9	-4.9
4	17.6	-8.8	18.3	-9.5
5	26.6	-12.9	27.2	-13.5
6	36.3	-16.3	36.9	-16.7
7	46.6	-18.9	47.0	-19.3
8	56.8	-21.0	57.2	-21.3
9	66.8	-22.4	67.1	-22.7
10	77.1	-23.4	77.3	-23.6
11	89.0	-24.1	89.0	-24.3
12	92.8	-20.5	92.9	-20.6
13	96.3	-15.1	96.4	-15.1
14	99.0	-7.6	99.0	-7.6
14	100.0*	0.0	100.0*	0.0

*R DISPLACEMENT NORMALIZED TO 100.

Figure 3-42. Reactor Building Second Horizontal Mode



MODE 2				
NODE	FREQ=13.82 CPS		FREQ=13.31 CPS	
	FIXED BASE —		SOIL INTER. ---	
	R	Z	R	Z
1	+0.1	-0.4	-12.1	-0.7
2	-27.3	-3.4	-39.9	-4.3
3	-66.7	-10.6	-75.3	-11.8
4	-95.0	-20.1	-97.5	-21.4
5	-108.3	-37.3	-105.6	-32.4
6	-105.5	-43.2	-99.1	-43.8
7	-87.5	-54.7	-79.2	-54.6
8	-56.3	-64.7	-48.2	-64.0
9	0.5	-72.9	4.4	-71.5
10	88.2	-80.3	83.8	-78.1
11	65.5	-119.2	67.3	-108.1
12	69.9	-123.0	73.5	-107.2
13	92.1	-64.2	93.1	-55.2
14	100.0*	0.0	100.0*	0.0

*R DISPLACEMENT
NORMALIZED TO 100.

Figure 3-43. Reduced Model of Interior Building Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, East-West Direction, Elevation 738.22




Figure 3-44. Combined Interaction Model Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, East-West Direction, Elevation 738.22




Figure 3-45. Reduced Model of Interior Building Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, East-West Direction, Elevation 777.60




Figure 3-46. Combined Interaction Model Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, East-West Direction, Elevation 777.60




Figure 3-47. Reduced Model of Interior Building Response Acceleration Spectrum, Damping = 0.02, Reactor Building, North-South Direction, Elevation 768.30




Figure 3-48. Combined Interaction Model, Response Acceleration Spectrum, Damping = 0.02, Reactor Building, North-South Direction, Elevation 768.30




Figure 3-49. Response Acceleration Spectrum, Damping = 0.02, Reactor Interior, North-South Direction, Elevation 768.22




Figure 3-50. Dynamic Analysis Model of Typical Piping System




Figure 3-51. Dynamic Analysis Model of Typical Piping System




Figure 3-52. Typical Envelope Horizontal Response Spectra for Analysis Comparison




Figure 3-53. Typical Verticle Response Spectra for Analysis Comparison




Figure 3-54. Typical Reactor Building and Containment Vessel Details




Figure 3-55. Reactor Building, Base Slab, Reinforcing, Bottom Radial Bars, Bottom Layer El. 717' + 4 3/4"




Figure 3-56. Reactor Building, Base Slab, Reinforcing Bottom Radial Bars, Top Layer Elevation 717' + 7 1/2"




Figure 3-57. Reactor Building, Base Slab, Reinforcing Top Radial Bars, Bottom Layer Elevation 721' + 10 3/4"




Figure 3-58. Reactor Building, Base Slab El. 723' + 0", Reinforcing, El. 717' + 6", El. 717' + 9", 722' + 0" and El. 722' + 3"

NO.	DESCRIPTION	QTY	UNIT	REMARKS
1	REINFORCING BAR	1000	LB	
2	CONCRETE	1000	CU YD	
3	FORMWORK	1000	SQ YD	
4	WELDED WIRE MESH	1000	SQ YD	
5	STEEL BRACING	1000	LB	
6	ANCHOR BOLTS	1000	PCS	
7	CAST-IN PLACE CONCRETE	1000	CU YD	
8	REINFORCING CHAIRS	1000	PCS	
9	CONCRETE CURING	1000	CU YD	
10	FORMWORK BRACING	1000	LB	
11	REINFORCING TIES	1000	PCS	
12	CONCRETE VIBRATORS	1000	HR	
13	FORMWORK OILING	1000	CU YD	
14	REINFORCING CUTTING	1000	HR	
15	CONCRETE PUMPING	1000	CU YD	
16	FORMWORK STRIPPING	1000	HR	
17	REINFORCING BENDING	1000	HR	
18	CONCRETE FINISHING	1000	CU YD	
19	FORMWORK CLEANING	1000	HR	
20	REINFORCING DELIVERY	1000	HR	
21	CONCRETE CURING	1000	HR	
22	FORMWORK REPAIR	1000	HR	
23	REINFORCING STORAGE	1000	HR	
24	CONCRETE TESTING	1000	HR	
25	FORMWORK PROTECTIVE	1000	HR	
26	REINFORCING WELDING	1000	HR	
27	CONCRETE MIXING	1000	HR	
28	FORMWORK ERECTION	1000	HR	
29	REINFORCING INSTALLATION	1000	HR	
30	CONCRETE PLACING	1000	HR	
31	FORMWORK DEMOLITION	1000	HR	
32	REINFORCING CLEANING	1000	HR	
33	CONCRETE CURE CURING	1000	HR	
34	FORMWORK STORAGE	1000	HR	
35	REINFORCING DELIVERY	1000	HR	
36	CONCRETE CURING	1000	HR	
37	FORMWORK REPAIR	1000	HR	
38	REINFORCING STORAGE	1000	HR	
39	CONCRETE TESTING	1000	HR	
40	FORMWORK PROTECTIVE	1000	HR	
41	REINFORCING WELDING	1000	HR	
42	CONCRETE MIXING	1000	HR	
43	FORMWORK ERECTION	1000	HR	
44	REINFORCING INSTALLATION	1000	HR	
45	CONCRETE PLACING	1000	HR	
46	FORMWORK DEMOLITION	1000	HR	
47	REINFORCING CLEANING	1000	HR	
48	CONCRETE CURE CURING	1000	HR	
49	FORMWORK STORAGE	1000	HR	
50	REINFORCING DELIVERY	1000	HR	




Figure 3-59. Reactor Building, Base Slab, Reinforcing Top Radial Bars, Top Layer Elevation 722' + 1 1/2"




Figure 3-60. Reactor Building, Concrete Shell, Developed Elevation - Reinforcing El. 722 + 6 Thru El. 875 + 4 1/2




Figure 3-61. Reactor Building, Concrete Shell, Developed Elevation - Reinforcing El. 722 + 6 Thru El. 875 + 4 1/2




Figure 3-62. Reactor Building - Equipment Hatch Reinforcing




Figure 3-63. Reactor Building, Inner Plan of Dome, Reinforcing




Figure 3-64. Reactor Building, Outer Plan of Dome, Reinforcing




Figure 3-65. Analysis of Reactor Building Penetration Space Frame Mathematical Model




Figure 3-66. Containment Vessel and Equipment Anchorage Details





Figure 3-67. Personnel Lock and Equipment Hatch Details






Figure 3-68. Typical Penetration Details

Figure 3-69. Reactor Building Containment Vessel, Cylinder Plate Layout and Penetration Location




Figure 3-70. Containment Vessel Penetration Details




Figure 3-71. Reactor Building Containment Vessel, Base Liner Plate, Anchors and Embedded Items




Figure 3-72. Reactor Building Containment Vessel, Base Liner Plate, Test Channel Layout




Figure 3-73. Containment Vessel As Built Overall Dimensions and Plate Thicknesses






Figure 3-74. Buckling Factors of Safety Comparison Between the McGuire and Catawba Stations



McGUIRE CONTAINMENT MODEL

Point	Meridional Force K/In.	Shear Force K/In.	Buckling Factor of Safety
1	-5.80	5.28	3.27



CATAWBA CONTAINMENT MODEL

Point	Meridional Force K/In.	Shear Force K/In.	Buckling Factor of Safety
1	-7.0	5.15	2.44*
2	-11.165	5.242	4.51

* Critical buckling loads are based upon experimental data in lieu of theoretical solutions.

Figure 3-75. Break in Element No. 1 - Ice Condenser, Transient Pressure in Compartments 7, 8, and 9




Figure 3-76. Break in Element No. 1 - Ice Condensor, Pressure Transients in Compartments 10, 11, and 12




Figure 3-77. Break in Element No. 1 - Ice Condensor, Pressure Transients in Compartments 13, 14, and 15




Figure 3-78. Break in Element No. 1 - Ice Condensor, Pressure Transients in Compartments 16, 17, and 18




Figure 3-79. Break in Element No. 1 - Ice Condensor, Pressure Transients in Compartments 19, 20, and 21




Figure 3-80. Break in Element No. 1 - Ice Condensor, Pressure Transients in Compartments 22, 23, and 24




Figure 3-81. Break in Element No.1 - Ice Condensor, Pressure Transients in Compartments 25, 29, and 33




Figure 3-82. Fourier Series Representation of Dynamic Loads







Figure 3-83. Compartment Layout - Plan at Equipment Rooms Elevation




Figure 3-84. Compartment Layout - Containment Section View




Figure 3-85. Layout of Containment Shell

Figure 3-86. Civil-Environmental Division Partial Organizational Chart
[HISTORICAL INFORMATION NOT REQUIRED TO BE REVISED]




Figure 3-87. Reactor Building, First Horizontal Mode, $f = 4.96478$ cps (Kalnin's)




Figure 3-88. Reactor Building, First Horizontal Mode, $f = 4.97$ cps (Finite Elements)




Figure 3-89. Containment Vessel, First Horizontal Mode, $f = 9.284$ cps (Kalinin's)




Figure 3-90. Containment Vessel, First Horizontal Mode, $f = 9.3234$ cps (Finite Elements)




Figure 3-91. Containment Vessel, Second Horizontal Mode, $f = 25.69$ cps (Kalnin's)




Figure 3-92. Containment Vessel, Second Horizontal Mode, $f = 25.660$ cps (Finite Elements)




Figure 3-93. Containment Vessel, First Vertical Mode




Figure 3-94. Containment Vessel, First Vertical Mode




Figure 3-95. Portion of the Operating Deck





Figure 3-96. Operating Deck Strudl Finite Elements Representation



FULL OPERATING DECK
ELAS (FEM) REPRESENTATION



CATAWBA NUCLEAR STATION
PSAR Figure 3.8.3-10
Amendment 4 (New)

Figure 3-97. Comparison of Program Results Fixed Boundary Conditions







Figure 3-98. Comparison of Program Results Pinned Boundary Conditions



SECTION A-A



SECTION B-B

Figure 3-99. Pressure Seals and Gaskets




Figure 3-100. Pressure Seals and Gaskets

This figure is currently unavailable in an electronic format. It can be located in a hardcopy version of the UFSAR.

Figure 3-101. Pressure Seals and Gaskets




Figure 3-102. Diesel Generator Area, General Arrangement Floor Plan, El. 736 +6, Roof Plan, El. 764 + 7

Figure 3-103. Diesel Generator Area, General Arrangement Cross Section

Figure 3-104. Auxiliary Building, Fuel Building, General Arrangement Plan at El. 760+6

Figure 3-105. Auxiliary Building, Fuel Building, General Arrangement Plan at El. 778+10

Figure 3-106. Auxiliary Building, Fuel Building, General Arrangement, Longitudinal Section Thru Fuel Pool

Figure 3-107. Auxiliary Building, Fuel Building, General Arrangement, Transverse Section at Cask Area

Figure 3-108. Auxiliary Building, Floor El. 733 + 0, General Arrangement, Battery Room Plan

Figure 3-109. Auxiliary Building, El. 750 + 0, General Arrangement, Cable Room Plan

Figure 3-110. Auxiliary Building, El. 767 + 0, General Arrangement, Control Room Plan

Figure 3-112. Reinforcement Arrangement Between the Auxiliary Building Foundation and a Typical Vertical Wall

Figure 3-113. Vibration Checkout Functional Test Inspection Points




Figure 3-114. Vibration Checkout Functional Test Inspection Points

FEATURES TO BE EXAMINED

- | | | | |
|----|---|----|---|
| 1 | THERMOCOUPLE CONDUIT CLAMPS INSIDE THE THERMOCOUPLE COLUMN. | 19 | OUTLET NOZZLE INTERFACE SURFACE CONDITION. |
| 2 | CIRCUIT SWAGELOK FITTINGS, THEIR BANDINGS, AND THE TAB TYPE LOCKS. | 20 | NEUTRON SHIELD PANEL DOWEL PIN COVER PLATE WELDS |
| 3 | CLAMP ARRANGEMENTS AT THE MOUNTING BRACKET LOCATIONS. | 21 | NEUTRON SHIELD PANEL SCREW LOCKING DEVICES. |
| 4 | PLUG TO CONDUIT WELD AT THE FOUR SUPPORT COLUMNS ADJACENT TO THE THERMOCOUPLE COLUMNS. | 22 | INTERFACE SURFACES AT THE SPACER PADS ALONG THE TOP AND BOTTOM ENDS OF THE NEUTRON PANELS. |
| 5 | ACCESSIBLE ANGLE CONDUIT CLAMPS INSIDE THE UPPER SUPPORT COLUMNS. | 23 | BAFFLE ASSEMBLY SCREW LOCKING ARRANGEMENTS AT THE TWO TOP AND THE TWO BOTTOM FORMER ELEVATIONS. |
| 6 | ACCESSIBLE WELD JOINTS AT THE THERMOCOUPLE STOP FOR THE SELF INSTRUMENTED COLUMNS. | 24 | LOWER CORE PLATE TO CORE BARREL FLANGE SCREW LOCKING DEVICES ACCESSIBLE AT THE 0°, 90°, 180°, AND 270° AXES. |
| 7 | WELD JOINTS ON ACCESSIBLE SUPPORT COLUMN AND MIXING DEVICE GUSSETS (THERMOCOUPLE SUPPORT HARDWARE). | 25 | CORE SUPPORT COLUMNS AND THEIR SCREW LOCKING DEVICES. |
| 8 | RIGIDITY OF EXPOSED PORTION OF THERMOCOUPLE CONDUIT RUNS, AT ACCESSIBLE LOCATIONS. | 26 | CORE SUPPORT COLUMN ADJUSTING SLEEVES. |
| 9 | RIGIDNESS OF THE ACCESSIBLE PROTRUDING THERMOCOUPLE TIPS. | 27 | ACCESSIBLE (2) INSTRUMENTATION GUIDE COLUMN LOCKING COLLARS NEAREST THE MANWAY. |
| 10 | THERMOCOUPLE COLUMN AND GUIDE TUBE SCREW LOCKING DEVICES. | 28 | LOCKING DEVICES AND CONTACT OF THE CRUCIFORM SHAPED BOTTOM INSTRUMENTATION GUIDE COLUMNS WHERE ATTACHED TO THE CORE SUPPORT AND TIE PLATES. |
| 11 | ACCESSIBLE SUPPORT COLUMN, MIXING DEVICE, ORIFICE PLATE, AND CORE PLATE INSERT SCREW LOCKING DEVICES. | 29 | LOCKING DEVICES OF THE SECONDARY CORE SUPPORT BUTT COLUMNS AT THE CORE SUPPORT, TIE PLATE AND BASE PLATE. |
| 12 | UPPER CORE PLATE INSERTS. | 30 | RADIAL SUPPORT KEY WELDS. |
| 13 | DEEP BEAM WELDS AT THE SKIRT AND AT THE OUTER HOLLOW ROUNDS. | 31 | RADIAL SUPPORT KEY LOCKING ARRANGEMENTS AND BEARING SURFACES. |
| 14 | ACCESSIBLE GUIDE TUBE WELDS. | 32 | HEAD AND VESSEL ALIGNING PIN SCREW LOCKING DEVICES AND BEARING SURFACES. |
| 15 | UPPER BARREL TO FLANGE GIRTH WELD. | 33 | IRRADIATION SPECIMEN GUIDE SCREW LOCKING DEVICES AND DOWEL PINS |
| 16 | UPPER BARREL TO LOWER BARREL GIRTH WELD. | 34 | VESSEL NOZZLE INTERFACE SURFACE CONDITION. |
| 17 | LOWER BARREL TO CORE SUPPORT GIRTH WELD. | 35 | VESSEL CLEVIS LOCKING ARRANGEMENTS AND BEARING SURFACES. |
| 18 | UPPER CORE PLATE ALIGNING PIN WELDS AND BEARING SURFACES. | | |

Figure 3-115. Time-History Dynamic Solution for LOCA Loading





Figure 3-116. Theoretical Solution [Historical information, not required to be revised.]



Significant response parameters, calculated in accordance with Biggs' solution with intermediate steps to 5 significant figures:

$$y_m = 0.8041''$$

$$t_m = 0.0663 \text{ sec.}$$


$$T_n = 0.1107 \text{ sec.}$$

$$y_{\text{max}} - y_{\text{min}} = 0.3689 \text{ sec.}$$


Reference: John M. Biggs, Introduction to Structural Dynamics, McGraw-Hill, Figure 2.22, 1964

Figure 3-117. PWhip Verification Example Inelastic Pipe Element [Historical information, not required to be revised.]


Structure:



Resistance Function:



Applied Force:



PWHIP Model:






Figure 3-118. PWhip Verification Example Inelastic Yield (U-Bar) Element Plastic Behavior
 [Historical information, not required to be revised.]

Structure:




Model:



$$M = 0.0259 \text{ kip-sec}^2/\text{in.}$$

Figure 3-119. Theoretical Solution [Historical information, not required to be revised.]



Theoretical Solution:

Time of initial impact, $t_0 = 0.071982 \text{ sec.}$

Velocity at initial impact, $\dot{y}_0 = 27.785 \text{ in/sec.}$

Time to zero velocity (maximum deflection y_m), $t_m = 0.10037 \text{ sec.}$


Maximum displacement of mass m , $y_m = 1.55063 \text{ in.}$

Reference: William T. Thomson, Vibration Theory and Application,
Prentice-Hall, Example 4.6-1, 1965.

Figure 3-120. PWhip Verification Example Inelastic Yield (U-Bar) Element Initial Gap Effect
 [Historical information, not required to be revised.]

PWhip Model:

(Figure 3.9.2.3-d)



U-Bar stiffness, $k = 1973.92 \text{ lb/in}$
 Mass, $m = 0.5 \text{ lb-sec}^2/\text{in}$
 Gravitational acceleration, $g = 386 \text{ in/sec}^2$
 Initial gap, $h = 1.0''$

Figure 3-121. Test Chamber Temperature Profile for Accident Environment Simulation




Figure 3-122. Reactor Coolant Loop Model for Steam Generator Replacement




Figure 3-123. Reactor Coolant Loop Model for Steam Generator Replacement




Figure 3-124. Reactor Coolant Loop Model for Steam Generator Replacement




Figure 3-125. Reactor Coolant Loop Model for Steam Generator Replacement




Figure 3-126. Time-History Dynamic Solution for LOCA Loading




Figure 3-127. Loop Layout and Global Coordinates




Figure 3-128. RPV Shell Submodel




Figure 3-129. Core Barrel Submodel




Figure 3-130. Reactor Internals Submodel





Figure 3-131. Hydrodynamic Masses in Vessel/Barel Downcomer Annulus



Not Drawn to Scale



-  - Node number
-  - Hydrodynamic Mass Element

Figure 3-132. Containment Vessel Mathematical Model

