

B. The Technical Specifications contained in Appendix A, as revised through Amendment No. 74, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

C. Records

Boston Edison shall keep facility operating records in accordance with the requirements of the Technical Specifications.

D. DELETED

E. Recirculation Loop Inoperable

The reactor shall not be operated with one recirculation loop out of service for more than 24 hours. With the reactor operating, if one recirculation loop is out of service, the plant shall be placed in a hot shutdown condition within 24 hours unless the loop is sooner returned to service.

F. Fire Protection

The licensee may proceed with and is required to complete the modifications identified in Paragraphs 3.1.1 through 3.1.19 of the NRC's Fire Protection Safety Evaluation (SE), dated December 21, 1978 for the facility. These modifications will be completed in accordance with the schedule in Table 3.1.

In addition, the licensee shall submit the additional information identified in Table 3.2 of this SE in accordance with the schedule contained therein. In the event these dates for submittal cannot be met, the licensee shall submit a report, explaining the circumstances, together with a revised schedule.

The licensee is required to implement the administrative controls identified in Section 6 of the SE. The administrative controls shall be in effect by December 31, 1978.

G. Physical Protection

The licensee shall fully implement and maintain in effect all provision of the following Commission approved documents, including amendments and changes made pursuant to the authority of 10 CFR 50.54(p):

- (1) "Security Plan for the Pilgrim Nuclear Power Station," dated November 7, 1977 with Revision 2 dated May 25, 1978 and Revision 3 dated January 8, 1979.
- (2) "Pilgrim Nuclear Power Station Safeguards Contingency Plan," dated April 5, 1979 and revised by letters dated December 20, 1979 and April 22, 1980, submitted pursuant to 10CFR 73.40. The Contingency Plan shall be fully implemented, in accordance with 10CFR 73.40(b), within 30 days of the approval by the Commission.
- (3) "Pilgrim Nuclear Power Station Guard Training and Qualification Plan" Revision 3, dated October 1980 includes pages dated August 18, 1979, May 28, 1980, and October 1, 1980. This Plan shall be followed in accordance with 10CFR73.55(b) (4), 60 days after approval by the Commission. All security personnel, as required in the above plans, shall be qualified within two years of this approval. The licensee may make changes to this plan without prior Commission approval if the changes do not

8407170081 840712
PDR ADDCK 05000293
PDR
P