

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.  
VICE PRESIDENT  
NUCLEAR OPERATIONS

34 SEP 24 P 1:43  
September 30, 1984

Mr. James P. O'Reilly  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, GA 30323


SUBJECT: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
Special Report (SPR 84-013)

Dear Sir:

Attached is a Special Report for the Virgil C. Summer Nuclear Station. This Report is required by Technical Specification 6.9.2 as a result of entry into Action Statement (a) of Technical Specification 3.3.3.10, "Loose-Part Detection Instrumentation," on August 14, 1984.

Should there be any questions, please call us at your convenience.

Very truly yours,

  
O. W. Dixon, Jr.

RJB:OWD/lcd  
Attachment

cc: V. C. Summer  
T. C. Nichols, Jr./O. W. Dixon, Jr.  
E. H. Crews, Jr.  
E. C. Roberts  
W. A. Williams, Jr.  
D. A. Nauman  
Group Managers  
O. S. Bradham  
C. A. Price  
D. A. Lavigne  
J. F. Heilman  
C. L. Ligon (NSRC)

K. E. Nodland  
R. A. Stough  
G. Percival  
C. W. Hehl  
J. B. Knotts, Jr.  
I&E Washington  
Document Management Branch  
INPO Records Center  
ANI Library  
NPCF  
File

8410110564 840920  
PDR ADOCK 05000395  
S PDR

11 IE22

Mr. James P. O'Reilly  
SPR 84-013  
Page Two  
September 20, 1984

EVENT DESCRIPTION AND ACTION TAKEN

On August 14, 1984, with the Plant in Mode 1, the Digital Metal Impact Monitoring System was declared inoperable. The cause of this event has been attributed to failed printed electronic boards. A purchase order has been initiated, and the estimated date of receipt of the new boards is September 30, 1984. Repair to the unit will be completed prior to start-up after the First Refueling Outage.