

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
NEW YORK POWER AUTHORITY ) Docket No. 50-333  
James A. FitzPatrick Nuclear Power Plant )

APPLICATION FOR AMENDMENT TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the New York Power Authority, as holder of Facility Operating License No. DPR-59, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

The change proposed corrects an error in Table 3.2-7 ("Instrumentation That Initiates Recirculation Pump Trip") on Page 77 of Appendix A to the FitzPatrick Operating License. The trip level setting associated with the reactor high pressure instrument is changed from " $\geq$  1120 psig" to " $\leq$  1120 psig".

The purpose of this change is to correct an error on Table 3.2-7 that was apparently introduced in the initial issuance of the Technical Specifications (Appendix A).

The proposed changes to the Technical Specifications are presented in Attachment I to this Application. The Safety Evaluation is included in Attachment II.

NEW YORK POWER AUTHORITY

By J. P. Bayne  
J. P. Bayne  
First Executive Vice President  
Chief Operations Officer

State of New York  
County of Westchester

Subscribed and sworn to before  
me this 5<sup>th</sup> day of October 1984.

Ilene Mann  
Notary Public

B410120028 B41009  
PDR ADOCK 05000333  
P PDR

ILENE MANN  
Notary Public, State of New York  
No. 4701200  
Qualified in Westchester County  
Term Expires March 30, 1985