



50-395

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 12, 1995

Mr. Gary J. Taylor
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: DISCREPANCY WITH BRANCH TECHNICAL POSITION (BTP) EICSB 18 -
VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1 (TAC NO. M89539)

Dear Mr. Taylor:

In a May 19, 1994 letter, Mr. John L. Skolds requested NRC concurrence with your staff's conclusion that no action was necessary to meet your licensing basis with respect to BTP EICSB 18, "Application of the Single-Failure Criterion to Manually Controlled Electrically Operated Valves." In addition to your letter, we received a May 20, 1994 Region II request to evaluate this issue at your plant. Although we answered the Region II request, we did not formally respond to your letter. This letter corrects that oversight.

As reported in Inspection Report No. 50-395/94-10, your staff identified two charging/high-head safety injection (HHSI) pump cross-connect motor-operated valves, XVG-8133A and XVG-8133B, that are vulnerable to a single-failure contrary to the recommendation in BTP EICSB 18. The concern was that when pump "C" is aligned to train "B," a "hot short" in the control circuitry of either of the valves could cause a valve to mechanically change position while all HHSI flow is being delivered via the train "B" flow path, thus defeating the automatic function for both trains of HHSI. In the May 19, 1994 letter, your staff attempted to show that no corrective action was required because the probability of the postulated single failure was acceptably low.

The NRC staff has evaluated this issue and concluded the postulated scenario could disable the HHSI, thereby compromising plant emergency response to small break loss-of-coolant accident and cooldown transient events. The NRC's regulations (e.g., General Design Criterion 35, "Emergency core cooling," 10 CFR Part 50 Appendix K) require that emergency core cooling system designs allow the safety function to be accomplished assuming a single failure. In this case, the regulations do not allow for probability arguments to justify accepting a postulated single failure. Therefore, the BTP EICSB 18 position regarding single failure is based on a regulatory requirement and is not just a staff recommendation.

9510160160 951012
PDR ADOCK 05000395
P PDR

REGULATORY CENTER COPY

QF01
110

Mr. Gary J. Taylor
South Carolina Electric & Gas Company

VIRGIL C. SUMMER NUCLEAR STATION

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, South Carolina 29065

J. B. Knotts, Jr., Esquire
Winston & Strawn Law Firm
1400 L Street, N.W.
Washington, D.C. 20005-3502

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
Drawer 60
Winnsboro, South Carolina 29180

Mr. Virgil R. Autry
Director of Radioactive Waste Management
Bureau of Solid & Hazardous Waste Management
Department of Health & Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. R. M. Fowlkes, Manager
Nuclear Licensing & Operating Experience
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

Mr. Gary J. Taylor

- 2 -

Therefore, we cannot concur with the position stated in Mr. Skolds's letter. The valves should have their power locked out in accordance with the single failure criterion of BTP EICSB 18. Alternatively, the administrative controls you've implemented to ensure the supply breakers for both valves are locked open with valves in the open position if the HHSI pump "C" is aligned to the train "B" HHSI is also acceptable, provided a redundant valve position indication for these valves is provided in the control room to satisfy the recommendations of BTP EICSB 18.

Sincerely,

Original signed by

Stephen Dembek, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-395

cc: See next page

DISTRIBUTION

Docket File
PUBLIC
S. Varga
J. Zwolinski
OGC
ACRS (4)
E. Merschhoff

DOCUMENT NAME: G:\SUMMER\SUM89539.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDII-3/LA <i>C</i>	PDII-3/PH <i>C</i>	SRXB <i>C</i>	EELB <i>MC</i>	PDII-3/D <i>C</i>
NAME	BC <i>BC</i>	SDembek <i>SD</i>	RJones <i>RJ</i>	JCalvo <i>JC</i>	FHebdon <i>FH</i>
DATE	09/21/95	09/22/95	09/26/95	10/11/95	09/12/95

OFFICIAL RECORD COPY 177#2 10
X