

official record copy



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30303

APR 30 1984

Florida Power Corporation
ATTN: Mr. W. S. Wilgus
Vice President Nuclear Operations
P. O. Box 14042, M.A.C. H-2
St. Petersburg, FL 33733

Gentlemen:

SUBJECT: REPORT NO. 50-302/84-07

On February 27 - March 2, 1984, NRC inspected activities authorized by NRC Operating License No. DPR-72 for your Crystal River facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

The inspection findings indicate that certain activities violated NRC requirements. The violation, references to pertinent requirements, and elements to be included in your response are presented in the enclosed Notice of Violation.

During the inspection your review of Post-TMI commitments disclosed that the CR-3 post accident sampling system was inoperable due to improperly closed valves in the containment building. The corrective action you took immediately restored the system to operability but failed to address the more basic cause of the problem: an inadequate review of procedures affecting safe operation of the CR-3 facility. In your response to the enclosed Notice of Violation, include actions you have taken, or will take, to prevent recurrence of violations of this type.

In addition to the need for corrective action regarding this specific violation we are concerned about the implementation of your management control system that permitted the occurrence. Consequently, in your reply, you should describe in particular those actions taken or planned to improve the effectiveness of your management control system.

In accordance with 10 CFR 2.790(a), a copy of this letter, its enclosures, and your reply will be placed in NRC's Public Document Room upon completion of our evaluation of the reply. If you wish to withhold information contained therein, please notify this office by telephone and include a written application to withhold information in your response. Such application must be consistent with the requirements of 2.790(b)(1).

