

Entergy Operations, Inc. P.O. Box 756

Port Gibson, MS 39150 Tel 601 437 2800

C. R. Hutchinson

Vice President Operations Grand Gulf Nuclear Station

October 12, 1995

U.S. Nuclear Regulatory Commission Mail Station P1-137 Washington, D.C. 20555

Attention:

Document Control Desk

SUBJECT:

Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416 License No. NPF-29

Monthly Operating Report

GNRO-95/00115

Gentlemen:

In accordance with the requirement of Technical Specification 5.6.4, Entergy Operations is providing the Monthly Operating Report for Grand Gulf Nuclear Station Unit 1 for September 1995.

Also, please note that the Maximum Dependable Capacity (Gross MWe and Net MWe) has changed due to the HP turbine upgrade.

If you have any questions or require additional information, please contact this office.

Yours truly,

attachments.

Operating Status

Average Daily Power Level

3. Unit Shutdown and Power Reductions

cc: (See Next Page)

170037

9510170003 950930 PDR ADDCK 05000416 R PDR JE24.

October 12, 1995 GNRO-95/00115 Page 2 of 3

cc:

Mr. D. C. Hintz (w/a)
Mr. R. B. McGehee (w/a)
Mr. N. S. Reynolds (w/a)
Mr. J. E. Tedrow (w/a)
Mr. H. L. Thomas (w/o)

Mr. Leonard J. Callan (w/a)
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive Suite 400
Arlington, TX 76011

Mr. P. W. O'Connor, Project Manager Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop 13H3 Washington, D.C. 20555

DOCKET NO	50-416			
DATE	10/05/95			
COMPLETED BY	S. D. Lin			
TELEPHONE	(601) 437-6793			

OPERATING STATUS

1.	Unit Name: GGNS UNIT 1						
2.							
3.	Licensed Thermal Power (MWt): 3833 MW						
4.	Nameplate Rating (Gross MWe): 1372.5 M						
5.	Design Electrical Rating (Net MWe): 1250						
6.	Maximum Dependable Capacity (Gross MW						
7.	Maximum Dependable Capacity (Net MWe)						
8.	If changes occur in Capacity Ratings (Items						
	through 7) Since Last Report. Give Reason						
9.	Power Level To Which Restricted, If Any (N		N/A				
10.	Reasons For Restrictions, If Any:N	Α	and the same and the same				
		This \$4	Vala Data	Cumulativa			
		This Month	Yr to Date	Cumulative			
11.	Hours in Reporting Period	720	6,551	95,967			
	Number of Hours Reactor was Critical	678.2	4.830.9	77,982.0			
13.	Reactor Reserve Shutdown Hours	0	0	0			
14.	Hours Generator On-Line	668.5	4,623.0	74,969.5			
15.	Unit Reserve Shutdown Hours	0	Q	0			
16.	Gross Thermal Energy Generated (MWH)	2.416,757	16,957,931	265,801,426			
	Gross Electrical Energy Generated (MWH)	793,010	5,522,341	84,843,840			
18.	Net Electrical Energy Generated (MWH)	760,307	5,297,553	81,283,694			
19.	Unit Service Factor	92.8	70.6	80.0			
20.	Unit Availability Factor	92.8	70.6	80.0			
21.	Unit Capacity Factor (Using MDC Net)	90.0	70.3	77.8			
22.	Unit Capacity Factor (Using DER Net)	84.5	64.7	70.8			
23.	Unit Forced Outage Rate	7.2	10.5	6.7			
24.	Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):						
	If Shut Down At End of Report Period. Esti		Startup:				
26.	Units in Test Status (Prior to Commercial O	peration):					
			Forecast	Achieved			
	INITIAL C	RITICALITY		08/18/82			
	INITIAL E	10/20/84					
	COMMER	07/01/85					

DOCKET NO 50-416 DATE

10/05/95 COMPLETED BY S. D. Lin
TELEPHONE (601) 437-6793

MONTH September 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)		
1	1200	17	1105		
2	1206	18	0		
3	1214	19	0		
4	1217	20	291		
5	1211	21	810		
6	1214	22	851		
7	1214	23	859		
8	1209	24	1175		
9	1207	25	1147		
10	1223	26	1222		
11	1217	27	1220		
12	1213	28	1220		
13	1206	29	1217		
14	1203	30	1208		
15	1202	31	N/A		
16	1198				

UNIT SHUTDOWNS AND POWER REDUCTIONS

 DOCKET NO.
 50-416

 UNIT NAME
 GGNS Unit 1

 DATE
 10/05/95

 COMPLETED BY
 S. D. Lin

 TELEPHONE
 (601)437-6793

REPORT MONTH September 1995

No.	Date	Type (1)	Duration Hours	Reason (2)	Method Of Shutting Down Reactor (3)	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action To Prevent Recurrence (C&CA)
95-010	09/17/95	F	51.5	A	3	LER # 95-011	SJ	V	Reactor scram at low reactor water level caused by failure of the pump discharge check valve to close following a trip of Reactor Feed Pump Turbine "B" resulting from malfunction of pressure regulating valve PRV-4 in lube oil system. Both "B" and "A" discharge check valves were repaired to prevent a similar occurrence.

4

Report (LER) File (NUREG-0161)

1

F: Forced S: Scheduled Reason:

2

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training &

Licensing Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3

Method:

1-Manual

2-Manual Scram

3-Automatic Scram

4-Continued

5-Reduced load

6-Other

5

Exhibit 1 - Same Source

Exhibit G - Instructions for Preparation of Ex Data Entry Sheets for Licensee Event