

NARRATIVE SUMMARY OF MONTHLY OPERATING EXPERIENCE - AUGUST, 1984

August 1
through
August 22

The station was in operational mode 1 with reactor power a nominal 100%. The reactor coolant system was at normal operating temperature and pressure.

August 23

At 0606 hours, the fluid pressure in the main turbine's electro-hydraulic control system dropped to 1200 psig, down from a normal operating range of 1800 - 2100 psig. The second EHC pump started and returned system pressure to normal, but did not cycle as it should have. A reduction in reactor power was begun in anticipation of an EH system failure. Power was dropped to 40% and held.

Troubleshooting of the system revealed that a flow restricting orifice to the EH system clean up filters had blown out, thereby allowing an inordinate amount of flow to be recirculated to the EH reservoir. The filters were isolated and the system returned to normal operation. A reactor power increase was started at 0823 hours. 100% reactor power was reached at 2400 hours.

August 24
through
August 31

The station was in operational mode 1 with reactor power a nominal 100%. The reactor coolant system was at normal operating temperature and pressure.

8410150174 840831
PDR ADOCK 05000334
R PDR

IE24
11

OPERATING DATA REPORT

DOCKET NO. 50-334
 DATE 9-6-84
 COMPLETED BY J. L. Holtz
 TELEPHONE 412-643-1369

OPERATING STATUS

1. Unit Name: Beaver Valley Power Station, Unit #1
2. Reporting Period: August, 1984
3. Licensed Thermal Power (MWt): 2660
4. Nameplate Rating (Gross MWe): 923
5. Design Electrical Rating (Net MWe): 835
6. Maximum Dependable Capacity (Gross MWe): 860
7. Maximum Dependable Capacity (Net MWe): 810
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	5,855	73,079
12. Number Of Hours Reactor Was Critical	744	5,501.3	36,380.7
13. Reactor Reserve Shutdown Hours	0	0	4,482.8
14. Hours Generator On-Line	744	5,329.1	35,107.9
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,949,986	13,475,782	81,065,321
17. Gross Electrical Energy Generated (MWH)	610,000	4,329,500	25,758,400
18. Net Electrical Energy Generated (MWH)	573,020	4,062,635	23,951,523
19. Unit Service Factor	100.0	91.0	50.4
20. Unit Availability Factor	100.0	91.0	50.4
21. Unit Capacity Factor (Using MDC Net)	95.1	85.7	44.1
22. Unit Capacity Factor (Using DER Net)	92.2	83.1	42.8
23. Unit Forced Outage Rate	0	3.5	27.7

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Scheduled shutdown - October 13 for 4th Refueling

Scheduled duration is 73 days.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

MAJOR MAINTENANCE - AUGUST, 1984

1. Repaired leak on 1A motor driven auxiliary feedwater pump.
2. The orifice to the clean up filters of the turbine EHC system was replaced.
3. Continued leak repair on component cooling water heat exchanger, CC-E-1B.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-334
 UNIT BVPS Unit #1
 DATE 9-6-84
 COMPLETED BY J. L. Holtz
 TELEPHONE (412) 643-1369

MONTH August

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	784
2	742
3	783
4	784
5	784
6	743
7	784
8	783
9	742
10	743
11	784
12	783
13	742
14	783
15	785
16	742

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	781
18	783
19	784
20	784
21	784
22	783
23	702
24	783
25	784
26	784
27	783
28	742
29	784
30	742
31	784

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.



Duquesne Light

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

September 6, 1984

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Monthly Operating Report

United States Nuclear Regulatory Commission
Director, Office of Management Information & Program Control
Washington, D. C. 20555

Gentlemen:

In accordance with Appendix A, Technical Specifications, the Monthly Operating Report is submitted for the month of August, 1984.

Very truly yours,

J. J. Carey
Vice President
Nuclear Group

Enclosures

cc: NRC Regional Office, King of Prussia, PA

IE 24
11