

APPENDIX A

NOTICE OF VIOLATION

Pennsylvania Power & Light Company
Susquehanna Steam Electric Station

Docket No. 50-387
License No. NPF-14

As a result of the inspection conducted on July 30 - August 2, 1984, and in accordance with the NRC Enforcement Policy, 49 FR 8594 (March 8, 1984), the following violation was identified:

10 CFR 50.54(q) requires that nuclear power reactors have and follow plans that meet the standards in 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50. 10 CFR 50.47(b)(15) requires that radiological emergency response training is provided to those who may be called on to assist in an emergency. 10 CFR 50, Appendix E, Section IV.F requires specialized initial training and periodic retraining programs be provided to emergency personnel.

Section 8.1.1(3), of the Emergency Plan, states in part, Personnel assigned to the Pennsylvania Power & Light emergency organization with specific Emergency Plan duties and responsibilities shall receive specialized training. Table 8.1, Training of SES Emergency Response Personnel and training procedure NTP-OA-52.1, "Emergency Plan Training Matrix," specifies that individuals designated as members of the Emergency Support Staff shall complete all annual required program training.

Contrary to the above, two primary contact members of the current TSC/EOF On-Call List of five positions verified had not been provided the annual required training.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Pennsylvania Power & Light Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

9410150297 840913
PDR ADOCK 05000387
Q PDR

OFFICIAL RECORD COPY

DL50-387/84-27 - 0003.0.0
09/10/84