




KANSAS GAS AND ELECTRIC COMPANY

July 11, 1984

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

Mr. E. H. Johnson, Acting Chief
Reactor Projects Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 84-112
Re: Docket No. STN 50-482
Subj: Withdrawal of Potential 10CFR50.55(e) - Pinholes in
Charcoal Adsorber

Dear Mr. Johnson:

This letter withdraws the potential 10CFR50.55(e) concerning pinhole leaks and base metal cracks in the laundry and hot shower charcoal adsorber at Wolf Creek Generating Station. This matter was initially reported to you by Mr. H. K. Chernoff of Kansas Gas and Electric Company (KG&E) on June 18, 1984.

Further review of this concern has revealed that the deficiencies would not have affected adversely the safety of operations of Wolf Creek Generating Station and would not have created a safety hazard to the general public. Therefore, KG&E concludes that this matter is not reportable pursuant to 10CFR50.55(e)/10CFR21 and withdraws the potential report made on June 18, 1984.

Although this concern is not reportable, KG&E has reworked the charcoal adsorber and corrected the identified deficiencies. Please contact me or Mr. Otto Maynard of my staff if you have any questions concerning this subject.

Yours very truly,

GLK:dsn

xc: RCDeYoung
PO'Connor
HBundy

8407230334 840711
PDR ADOCK 05000482
S PDR

IK-27
1/0