

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Peach Bottom Unit 2

Docket/License: 50-277/DPR-44

As a result of the inspection conducted on April 21 - June 7, 1984, and in accordance with the revised NRC Enforcement Policy (10 CFR 2, Appendix C), published in the Federal Register on March 8, 1984 (49 FR 8583), the following violation was identified:

Technical Specification 6.8 and Regulatory Guide 1.33 (November 1972) require implementation of procedures for control of radioactivity. Procedure HPO/CO-100, Revision 13, April 25, 1983, Health Physics Guides Used in the Control of Exposure to Radioactive Material, requires posting, with "Contaminated Area" signs or a radiation tape barrier line, of areas having removable surface contamination above 1000 disintegrations per minute per 100 square centimeters (dpm/100 cm²).

Contrary to the above, on May 16, 1984, three fire barrier seals in the Reactor Building 165-foot elevation had removable surface contamination of 1700 to 23,000 dpm/100 cm² and were not posted with "Contaminated Area" signs or a radiation tape barrier line.

This is a Severity Level IV Violation (Supplement IV) applicable to DPR-44.

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations, and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8407230360 840702
PDR ADOCK 05000277
Q PDR