

APPENDIX A
NOTICE OF VIOLATION

Rochester Gas and Electric Corp.
R. E. Ginna Nuclear Power Plant

Docket No. 50-244
License No. DPR-18

As a result of the inspection conducted on May 7 - 11, 1984, and in accordance with the revised NRC Enforcement Policy (10 CFR 2, Appendix C), published in the Federal Register Notice (49 FR 8583) dated March 8, 1984 the following violation was identified:

Technical Specification 6.11 and 6.8.1, requires, in part, the licensee to develop written radiation monitoring procedures consistent with 10 CFR 20. 10 CFR 20.103(a)3 requires suitable measurements of concentrations of radioactive materials in air.

Contrary to the above, the licensee's procedures were inadequate in that procedures HP 4.3, HP 6.1 and HP 6.2 which require airborne monitoring did not specify the technique to be used to monitor area and breathing zone concentrations and to provide suitable measurements of such concentrations.

This is a Severity Level V violation (Supplement IV).

8407240044 840629
PDR ADOCK 05000244
PDR
Q