




GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

September 28, 1984
RBG-19044
File Nos. G9.5, G9.25.1.1

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Dear Mr. Collins:

River Bend Station Unit 1
Docket No. 50-458
Final Report/DR-145

Gulf States Utilities Company (GSU) has completed its evaluation of DR-145 concerning design modifications performed at a location not specified by Engineering and Design Coordination Report (E&DCR) No. C-3346. An engineering evaluation of the problem was performed in Calculation No. 553.8900 at the location where the work was originally specified by E&DCR No. C-3346. It was determined by using results of verification analysis that the embedded plate addressed in E&DCR No. C-3346 is acceptable without repair. GSU has therefore determined this condition is not reportable under 10CFR50.55(e). Nonconformance and Disposition Report No. 4500 was issued to remove the work performed at the incorrect location and to perform the work at the specified location.

Sincerely,

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

WJPD
JEP/PJD/lp

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

8410150474 840928
PDR ADOCK 05000458
S PDR

10 IE-27