

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 1	DOCKET NUMBER (2) C 5 0 0 0 3 7 3	PAGE (3) 1 OF 02
--	--------------------------------------	---------------------

TITLE (4)  
Unsecured High Radiation Area Door

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
06	17	84	84	034	000	07	13	84			05000

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)										
POWER LEVEL (10) 1 0 0	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)							
	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)							
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)							
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(vii)(A)								
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)								
	<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(ix)								

LICENSEE CONTACT FOR THIS LER (12)

NAME Lary R. Aldrich, extension 238	TELEPHONE NUMBER AREA CODE: 811535 171-167611
--	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS
A	ZIZ	Z191919	Z191919	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)  NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 0515 on June 17, 1984, a high radiation area door, which leads to the URC tank room on the 687' elevation of the Turbine Building, was found open with no positive access control. Individuals entered the room during the hours of 1525 on June 16, 1984 to 0455 on June 17, 1984. Upon leaving the room, the door was not closed and secured. Upon discovery of the lack of security control of the high radiation area, a Radiation Chemistry Technician closed and secured the door.

8407240376 840713  
PDR ADOCK 05000373  
S PDR

IE22  
/11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  LaSalle County Station Unit 1	DOCKET NUMBER (2)  0 5 0 0 0 3 7 3	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 3 4	- 0 1 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 388A) (17)

I. EVENT DESCRIPTION

At 0515 on June 17, 1984, a high radiation area door, which leads to the URC tank room on the 687' elevation of the Turbine Building, was found open with no positive access control. Contrary to Technical Specification 6.1.1., the room was found to be unsecured and unattended.

II. CAUSE

Individuals entered the room during the hours of 1525 on June 16, 1984 to 0455 on June 17, 1984. Upon leaving the room, the door was not closed and secured.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 mrem occurred.

IV. CORRECTIVE ACTION

Upon discovery of the lack of security control of the high radiation area, a Radiation Chemistry Technician (RCT) closed and secured the door. Emphasis is continuing to remind all workers of the requirements and responsibilities of all personnel when dealing with high radiation areas.

V. PREVIOUS OCCURRENCES

Previous unsecured high radiation door LER's were 373/84-25-00, 373/84-036-00, and 374/84-022-00.

IV. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



**Commonwealth Edison**  
LaSalle County Nuclear Station  
Rural Route #1, Box 220  
Marseilles, Illinois 61341  
Telephone 815/357-6761

July 13, 1984

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-034-00, Docket #050-373 is being submitted to your office in accordance with 10 CFR 50.73.

*C E Diederich*  
G. J. Diederich  
*for* Superintendent  
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director  
INPO-Records Center  
File/NRC

*IEZZ*  
*11*