

A RELAP5M3 Comparison of Model Boiler 2 MSLB from HZP Test

Document Number *PSA-B-95-18*
Revision *0*

Kevin B. Ramsden

ComEd
Nuclear Fuel Services Department
Downers Grove, Illinois

Prepared by: *Kevin B. Ramsden*

Date: *10/12/95*

Reviewed by: *[Signature]*

Date: *10/12/95*

Approved by: *Tim L. O'Brien PDR 10/15*

Date: *10/12/95*
(Date Issued)

Statement of Disclaimer

This document was prepared by the Nuclear Fuel Services Department for use internal to the Commonwealth Edison Company. It is being made available to others upon the express understanding that neither Commonwealth Edison Company nor any of its officers, directors, agents, or employees makes any warranty or representation or assumes any obligation, responsibility or liability with respect to the contents of this document or its accuracy or completeness.

Abstract

This calculation has been performed to validate the methods and models utilized with the RELAP5M3 computer code to calculate the time dependent differential pressure on the tube support plates (TSPs) during Main Steam Line Break (MSLB) events from Hot Zero Power (HZP) conditions. This event is the limiting event with respect to dynamic loading of the TSPs and accurate characterization of these loads is required as input to structural analyses of these structures being performed in support of the 3mv IPC submittals. This calculation utilizes a model similar to that employed in the Model D4 analysis to predict the response of the MB2 test facility to a full size MSLB from HZP. This comparison provides benchmarking support for the manner and methods employed in the generation of transient analysis of the Model D4 steam generators for Byron 1 and Braidwood 1.

Table of Contents

1. Introduction.....	1
2. Methodology/Model Description and Assumptions.....	2
2.1 Computer Code	2
2.2 Test Facility Description	2
2.3 Description of RELAP5M3 model	2
2.3.1 Initial Conditions	2
2.3.2 Tube Bundle Modeling	2
2.3.3 Break Flow Modeling	3
3. Calculations/Acceptance Criteria/Basedeck Changes	5
3.1 Base Case	5
3.2 Non-Equilibrium Case.....	5
3.3 Nozzle Size Sensitivity	5
4. Results	6
4.1 Base Case	6
4.2 Non-Equilibrium Case.....	6
4.3 Nozzle Area Sensitivity Study.....	7
5. Conclusions/Discussion	8
6. References.....	34
Appendix A - Data Set Index	35
Appendix B - Input Data Set Protection Form	36
Appendix C - MB2 Facility Description and Information	37
Appendix D RELAP5M3 MB2 Model Input Listing.....	38

List of Figures

Figure 1 RELAP5M3 Model Diagram of MB2 Facility.....	4
Figure 2 Base Case Dome Pressure Response.....	9
Figure 3 Base Case Break Flow Rate.....	10
Figure 4 Base Case TSP 1 DP.....	11
Figure 5 Base Case TSP 2 DP.....	12
Figure 6 Base Case TSP 3 DP.....	13
Figure 7 Base Case TSP 4 DP.....	14
Figure 8 Base Case TSP 5 DP.....	15
Figure 9 Base Case TSP 6 DP.....	16
Figure 10 Non-Equil. Case Dome Pressure Response.....	17
Figure 11 Non-Equil. Case Break Flow Rate.....	18
Figure 12 Non-Equil. Case TSP 1 DP.....	19
Figure 13 Non-Equil. Case TSP 2 DP.....	20
Figure 14 Non-Equil. Case TSP 3 DP.....	21
Figure 15 Non-Equil. Case TSP 4 DP.....	22
Figure 16 Non-Equil Case TSP 5 DP.....	23
Figure 17 Non-Equil. Case TSP 6 DP.....	24
Figure 18 Non-Equil. Case Temperature Response in 101-13.....	25
Figure 19 Dome Pressure Response 70% Case.....	26
Figure 20 Break Flow Rate 70% Case.....	27
Figure 21 TSP 1 DP 70% Case.....	28
Figure 22 TSP 2 DP 70% Case.....	29
Figure 23 TSP 3 DP 70% Case.....	30
Figure 24 TSP 4 DP 70% Case.....	31
Figure 25 TSP 5 DP 70% Case.....	32
Figure 26 TSP 6 DP 70% Case.....	33

1. Introduction

The MB2 test facility is a 0.8% power scaled, full height test facility that was built to test the design of the Model F steam generator. A series of tests were performed with this facility and were documented in references 1 and 2. This calculation utilizes data recovered from these tests to demonstrate the ability of RELAP5M3 to adequately and conservatively characterize the MSLB event from HZP conditions. Specifically, Test 2013, a MSLB from HZP and normal water level, was modeled to demonstrate that with appropriate input selection, RELAP5M3 will calculate representative pressure loads on the TSPs.

This calculation has two primary purposes. The first is to demonstrate that RELAP5M3 can model the TSP loads conservatively. The second is to demonstrate that key modeling options and model configurations used in the Model D4 analyses, when employed in the Model Boiler comparison, yield appropriate results. The primary modeling option of concern is the use of the equilibrium model in the tube regions. This is necessary to preclude pressure oscillations related to the non-equilibrium model interfacial heat transfer, that although small from a system perspective, cause erroneous loads to be predicted. The primary model configuration to be supported is the use of a detailed bundle nodalization, which represents a balance between optimal modeling practice and the desire to obtain differential pressure information as close to the tube support plates as achievable.

2. Model Description and Assumptions

2.1 Computer Code

The RELAP5M3 version 1.1 computer code as implemented on the ComEd HP-735 workstation network was utilized for this analysis. The installation of this code was verified specifically for this analysis by direct comparison of supplied sample problems output files. This computer code employs a state of the art two fluid model to calculate thermal hydraulic behavior of complex systems. A review of the code assessment problems indicates that this code has been tested and predicts well, the behavior of steam and water-filled vessels undergoing rapid depressurization.

2.2 Test Facility Description

A detailed summary of the test facility geometry is provided in Appendix C.

2.3 Description of RELAP5M3 model

The RELAP model nodalization diagram is provided in Figure 1. This model is a direct analogue of the Model D4 SG model developed for Byron 1 and Braidwood 1. The total volumes have been scaled to be representative of the test facility. A listing of the base model is provided in Appendix D.

2.3.1 Initial Conditions

The initial mass of the model compares favorably with that measured in the test, 1260 pounds in the RELAP model vs 1211 pounds as indicated by the test data reports. The initial water level has been initialized within two inches of the 441 inch level reported in the test. The test was initiated from 2% power, to be representative of HZP conditions with some decay heat removal. The RELAP5 model was initiated at a zero power condition, to yield the highest loads possible, as was modeled in the D4 analysis. The RELAP model initializes all volumes at 560 F, which results in an initial dome pressure of 1132 psia. The initial pressure in the test facility was 1090 psia.

2.3.2 Tube Bundle Modeling


Tube bundle interphase drag modeling is based on the use of the rodded bundle correlations (EPRI). The model represents the TSPs as having the same area as the bundle flow area, with the loss coefficient adjusted accordingly. This approach was utilized in the D4 model as well, and is the method recommended by the RELAP5 newsletter (April-July 1995). In the tube regions (Volume 101), a series of small nodes (.2ft) have been inserted on either side of the TSPs in order to predict the transient differential pressure load on the TSPs. Since MB2 is a full height test facility, this is

directly comparable to the Model D4 nodalization scheme. Crossflow frictional terms were calculated identically to the methods applied in the Model D4 calculation, and the data sheets are enclosed in Appendix D. In initial steady state testing, Westinghouse found it necessary to increase the effective crossflow resistance by a mean factor of 8.5 to obtain the appropriate pressure drop at the U-bend. This factor is also applied in this model.

2.3.3 Break Flow Modeling

The flow restricting orifice was modeled in junction 106 at the exit of the steam generator. The break is simulated in the line directly downstream of the orifice by the use of an MOV model. This valve was assumed to have an opening rate of 100 msec to be typical of the air operated valve actually employed in the test. To evaluate the potential effects of increased piping resistance in the test apparatus, a series of cases was performed using reduced nozzle area, comparable to C/D reductions in LOCA analysis.

Figure 1 RELAP5M3 Model Diagram of MB2 Facility



RELAP5M3 Model Diagram of MB2

3. Calculations

3.1 Base Case

The base case run utilized equilibrium modeling in the tube bundle and lower downcomer regions, comparable to the D4 model. This case used the full nozzle area, based on a throat diameter of 1.3 inches.

3.2 Non-Equilibrium Case

This case was identical to the base case, with the exception that the non-equilibrium models were enabled throughout the model.

3.3 Nozzle Size Sensitivity

Cases were run with 70% and 80% effective flow limiting nozzle area. These cases were identical in all other respects to the base case,

4. Results

4.1 Base Case

The model was allowed to run to a null transient for the first second to ensure an initially steady state. The break was initiated at 1 second, and the effects of the resulting transient were computed for a ten second period. Auxiliary feedwater at 97 degrees F was injected into volume 111 at a rate of .23 gpm increasing linearly to .35 gpm from 1 second to 11 seconds, as described in the test. The dome pressure behavior is shown in Figure 2. As can be seen, the overall pressure response is comparable to the test, but with a slightly higher rate of pressure decrease over the 10 second period. The break flow, shown in Figure 3, is higher than that indicated by steam flow measurements in the test steam line. This behavior is consistent with the pressure response observed, and prompted the sensitivity study on nozzle area. Test data was recovered from microfiche for the differential pressure data on the TSPs at a .1 second interval for the first 2 seconds of the event. The RELAP model predictions of transient TSP differential pressures are plotted against the test data for all six TSPs in Figures 4 through 9. Due to the location of the test instruments relative to the nodes available in the RELAP nodalization, some elevation head induced bias exists as demonstrated in the plots. The relative pressure changes are representative however, and provide a good indication of the ability of the code to reproduce the transient response. Of particular interest is the TSP 5 response, since the location of the test instrumentation includes not only the TSP, but a tube section as well. This geometry demonstrates the ability of the code to predict the TSP DP plus the tube bundle friction losses. The plots of the lower support plate behavior indicate that very little reverse flow occurred in the lower bundle region, and that the RELAP model consistently reproduces this effect. From the TSP DP plots, it can be seen that the equilibrium model produces pressure increases at the TSPs that are consistent in timing and conservative in magnitude.

4.2 Non-Equilibrium Case

The dome pressure and break flow rates for this case are shown in Figures 10 and 11. There is effectively no difference in these predictions from that of the base case. The TSP differential pressures are shown in Figures 12 through 17. These plots, particularly the upper three support plate responses (TSP 4-6) serve to illustrate the effects of the pressure oscillations. The initial response is not unreasonable, but highly oscillatory. At approximately .7 seconds into the event, the model predicts a large spike in pressure, when in fact the test data shows a declining pressure behavior. Figure 18 provides the saturation, liquid and vapor temperatures for volume 101-13, and illustrates the metastable nature of the nonequilibrium model that is believed to be the cause of this behavior. Forcing the model to maintain consistent fluid temperatures, as in the base case, eliminates this behavior, and produces results more closely related to the test data.

4.3 Nozzle Area Sensitivity Study

As noted above, the base case depressurization rate and steam flow based on the flow limiting nozzle dimensions appeared high relative to the test data. To ensure that the conservative overprediction of loads by the RELAP model was not solely a function of excessive blowdown rate, calculations were performed at 70% and 80% effective nozzle area. The 80% case yielded depressurization rates and steam flow rates still somewhat higher than the test data supported. The 70% case provided steam flow rates that were closer to those measured in the test, and a depressurization rate consistent, and slightly less than that observed, as shown in Figures 19 and 20. This provides a means of enveloping the pressure response. The TSP loads for this case are provided in Figures 21 through 26, and show that at the reduced depressurization rates and steam flows, that RELAP5 provides conservative prediction of the TSP loads.

5. Conclusions

As stated in the Introduction, this calculation had two purposes: to demonstrate that RELAP5M3 can be effectively used to develop conservative differential pressure loads on TSPs under MSLB conditions, and to demonstrate that the model options and nodalizations used in the D4 analysis yield appropriate responses when utilized to model applicable test data. The results obtained in this calculation demonstrate both of these points. RELAP5M3 does reproduce the test data results on the TSPs with reasonable conservatism. The model options used in the Model D4 analysis provide the best match to test data, both in timing and magnitude.

The results of the nonequilibrium case highlight the pressure oscillations caused by metastable behavior in the interfacial heat transfer models. It should be noted that this type of analysis is a special case that is severely impacted by what are in fact relatively small oscillations in the macroscopic pressure behavior. This problem has been brought to the attention of the code developers for resolution. The good agreement with long term vessel pressure and TSP load suggest that this problem would have minimal effect on most applications of the code. It appears that only in fast depressurization transients where differential versus integral behavior is the focus that this problem is of concern.

MB2 Test 2013 Comparison
Steam Dome Pressure Response




Figure 2 Base Case Dome Pressure Response




Figure 3 Base Case Break Flow Rate

MB2 Test 2013 Comparison
TSP 1 DP




Figure 4 Base Case TSP 1 DP




Figure 5 Base Case TSP 2 DP




Figure 6 Base Case TSP 3 DP

MB2 Test 2013 Comparison
TSP 4 DP




Figure 7 Base Case TSP 4 DP

MB2 Test 2013 Comparison
TSP 5 DP




Figure 8 Base Case TSP 5 DP

MB2 Test 2013 Comparison
TSP 6 DP




Figure 9 Base Case TSP 6 DP

MB2 Test 2013 Comparison NE Case
SG Dome Pressure Response




Figure 10 Non-Equil. Case Dome Pressure Response

MB2 Test 2013 Comparison NE Case




Figure 11 Non-Equil. Case Break Flow Rate

MB2 Test 2013 Comparison NE case
TSP 1 DP




Figure 12 Non-Equil. Case TSP 1 DP

MB2 Test 2013 Comparison NE Model
TSP 2 DP




Figure 13 Non-Equil. Case TSP 2 DP




Figure 14 Non-Equil. Case TSP 3 DP

MB2 Test 2013 Comparison NE Model
TSP 4 DP




Figure 15 Non-Equil. Case TSP 4 DP

MB2 Test 2013 Comparison NE Model
TSP 5 DP




Figure 16 Non-Equil Case TSP 5 DP

MB2 Test 2013 Comparison NE Model
TSP 6 DP




Figure 17 Non-Equil. Case TSP 6 DP

MB2 Test 2013 Comparison NE Case
Fluid Temperatures In Vol 101-13




Figure 18 Non-Equil. Case Temperature Response in 101-13

MB2 Test 2013 Comparison 70% Case
SG Dome Pressure Response




Figure 19 Dome Pressure Response 70% Case




Figure 20 Break Flow Rate 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 1 DP




Figure 21 TSP 1 DP 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 2 DP




Figure 22 TSP 2 DP 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 3 DP




Figure 23 TSP 3 DP 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 4 DP




Figure 24 TSP 4 DP 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 5 DP




Figure 25 TSP 5 DP 70% Case

MB2 Test 2013 Comparison 70% Case
TSP 6 DP




Figure 26 TSP 6 DP 70% Case

6. References

- 1) NUREG CR-4751
- 2) NUREG CR-4752

Appendix A - Data Set Index

Dataset	Description
Input	
mb2mod	base deck equilibrium case
mb2modne	base case nonequilibrium
output	
mb2mout1	base case
mb2mout2	NE case
mb2mout3	80% nozzle area
mb2mout4	70% nozzle area

Appendix B - Input Data Set Protection Form

Station: Byron/Brendwood Unit: 1-2 Cycle/Analysis: SG TSP

	Current File Location ¹	Copy To ²	Checksum # ³	
			sum - r	sum - p
1.	BB AfsKb/relaps/mb2mod	bb/TSPload/rel.mb2_9518	22064	3501909178 ✓
2.				

- Notes: 1) /nfs/sa is not required. Begin each file location with user id. File name should be descriptive and include a means of identifying associated computer code.
 2) Station, Unit, and Cycle/Analysis will define part of the destination location in /nfs.databank/SA therefore, these are not need in the "Copy To" column.
 3) The SA Admin will place a check mark next to the verified checksum numbers.

Author: [Signature] Reviewer: [Signature] SA Admin: [Signature] Date: 10/12/95

Appendix C - MB2 Facility Description and Information

Section 2

THE MB-2 TEST FACILITY

2-1. MB-2 BACKGROUND AND HISTORY

With the introduction of a new steam generator model, it is desirable to verify the various current features incorporated in the design. Although these features are generally verified in individual component tests, it may be appropriate to perform an integrated test which considers several design features to confirm that no unexpected synergistic effects exist. The Model Boiler No. 2 (MB-2) -- an approximately 0.8-percent power-scaled representation of the Model F steam generator unit -- is the third in a series of integrated steam generator test models constructed and tested in the last 10 years by Westinghouse at its Engineering Test Facility in Tampa, Florida. The previous two test models were built to investigate the thermal performance of a once-through steam generator, and a preheat design (steam generator Models D4 and E).

Based on the experience gained in the first two tests, it was concluded that the design objective of the MB-2 is to make it as prototypical as possible. Hence, to minimize uncertainties associated with scaling-down, use was made of steam generator tubes of the same material, dimensions, and tube pitch as specified for Model F. Prototypical primary and secondary temperatures, pressures, and mass velocities were also specified so that the performance of the model was directly applicable to the full-size unit, wherever possible. The 7-meter-(23 ft) high tube bundle, together with the primary moisture separator, provided a nearly prototypical driving head for the secondary circulation loop. Using prototypical fluid temperatures, hydraulic resistances in the tube bundle, tube support plates, primary swirl vane separator, and downcomer regions, it was possible to achieve a representative pressure-drop distribution and secondary flow in the circulation loop.

The MB-2 was extensively used for the measurement of Model F steady-state performance and for the qualification of a number of computer codes used in the design and analysis of full-size steam generators. The use of prototypical features, where possible, has reduced the uncertainty in interpreting test results and applying them to the performance of the full-size steam generator.

2-2. MODEL BOILER DESCRIPTION

The Model Boiler No. 2 (MB-2) is an approximately 0.8-percent power-scaled model of the Model F steam generator, a feeding-type unit. It is designed to be geometrically and thermal-hydraulically similar to the Model F in important areas, and is capable of generating a maximum of 10 MWt. At 100-percent power (6.67 MWt) it produces dry, saturated steam at 6.9 MPa (1000 psia), the same as Model F. A schematic rendering of the model, as configured for the LOF and SGTR tests, is shown in figures 2-1a and 2-1b, and the configuration used for the SLB tests is shown in figure 2-2. A typical Model F steam generator is shown in figure 2-3.

Within the model, dry saturated steam is generated by the transfer of heat from high-pressure water at 15.5 MPa (2250 psia) on the primary side to a steam and water mixture on the secondary side. The primary water enters the inlet side of the channel head, flows through the U-tubes, and leaves through the exit side of the channel head.

On the secondary side, feedwater or auxiliary feedwater enters the unit cell surrounding the primary separator, mixes with the recirculating water, flows down the downcomer pipes, and flows through the wrapper box cutout into the bundle just above the tubesheet. Directed by the flow distribution baffle, the flow sweeps across the tubesheet before turning upward through the bundle. As the fluid travels upward, a steam-water mixture is generated. Leaving the top of the tube bundle, the mixture flows through a cone into the riser. At the top end of the riser, the primary separator removes the water by centrifugal action and returns it to the downcomer circuit. The steam, with entrained moisture, then enters the secondary separator where the moisture is removed by a single-tier vane-type separator. The steam is again returned to the downcomer circuit via the disengagement tank (which is used to measure the flow rate of the moisture removed) in the LOF and SGTR tests (figure 2-1a), or via a straight pipe in the SLB tests (figure 2-2). The steam, exiting the vessel through the outlet nozzle, is saturated and essentially dry.

2-2-1. Tube Bundle

The MB-2 tube bundle is composed of 52 tubes arranged in a rectangular array, having 13 tube rows and 4 tube columns, as shown in figure 2-4. All tubes are fabricated from Inconel 600. They have the same outside diameter (1.75 cm or 11/16 in.), and wall thickness (1 mm or 0.040 in.) as the tubes in Model F and are configured in the same 2.49 cm (0.98 in.) square-pitch array. As a result, the primary and secondary unit cell flow areas for the model and the full-size steam generator are identical.




Figure 2-1a. Model Boiler No. 2 Configuration for LOF and SGTR Tests




Figure 2-1b MS-2 Cross Section Through Tube Bundle




Figure 2-2. Model Boiler No. 2 Configuration for SLB Tests

DIMENSIONS IN cm (in.)




Figure 2-3. Westinghouse Model F Steam Generator




Figure 2-4. MB-2 Cross Section

The straight length of the tube bundle is 6.69 meters (21.94 ft.), which is about 0.5 meter (20 in.) shorter than in Model F. The radii of the U-bends and the length of the tubes are defined in figure 2-5.

There are six tube supports in the MB-2 bundle, compared to seven supports in Model F, and also a flow distribution baffle (see figure 2-1a). The tube support plates utilized in MB-2 provide a full-size simulation of the tube/support plate juncture in a representative environment. The plates, exclusive of the grid at the third support location, have the same thickness and make use of the same quatrefoil broached hole configuration used in the full-size Model F. The support plates in MB-2 are partially composed of alternate broached and drilled hole designs. The axial spacing of the tube supports was selected to be identical to that which exists in Model F, 1.02 m (40.16 in.). The flow distribution baffle is located 0.5 m (20 in.) above the top of the tubesheet, as in Model F. It is partially configured with oversized drilled holes and an alternate "mini-broached" quatrefoil hole design. This baffle also includes a central cutout which simulates the effect of the central cutout in the Model F.


The heat transfer area of the MB-2 tube bundle is 39.75 m^2 (428 ft.²). Utilizing this area, a scaling philosophy was adopted which maintains the same bundle average heat flux as exists in Model F. The power scaling was subsequently used in sizing the flow areas for the downcomers and the primary and secondary separators to provide velocities and mass fluxes comparable to those of Model F. This scaling approach, as it applies to transient testing, is described in more detail in reference (5).

For this test program, the model was completely retubed and reinstrumented. The instrumentation layout and method of attachment is described in section 3.

2-2-2. MB-2 Upper Shell Region

Portions of the internals in the upper shell region were modified for the MB-2 Transient Test Program. Modifications were made to: the primary separator assembly, the deck plate drainage and venting, the downcomer, the secondary separator drain, and the feedwater inlet configuration. The steam shroud, located in the gravity-separation region between the primary and secondary separators, is the same as that used in the previous MB-2/Model F verification tests, along with the single-tier secondary separator.

ROW	"R" cm (in.)
1	3.10 (1.22)
2	5.59 (2.200)
3	8.08 (3.180)
4	10.57 (4.160)
5	13.06 (5.140)
6	15.54 (6.120)
7	18.03 (7.100)
8	20.52 (8.080)
9	23.01 (9.060)
10	25.50 (10.040)
11	27.99 (11.020)
12	30.48 (12.000)
13	32.97 (12.980)



- MEASURED FROM TOP OF TUBESHEET
- MAXIMUM DRAWING TOLERANCE
MINIMUM

Figure 2-5. MB-2 U-Tube Dimensions

Figure 2-6 is a scheme of the revised upper shell region. This region is presented in further detail in figure 2-7. A cross-sectional view at the deckplate is shown in figure 2-8. Detailed descriptions of the modified components are provided in the following sections.

2-2-2-1. Modular Primary Separator. The modular primary separator concept involves the use of a large number of small (17.8 cm or 7 in. diameter) primary swirl vane separator assemblies, rather than a much smaller number of large diameter -- 50.8 cm (20 in.), 129 cm (51 in.) or 142 cm (56 in.) -- separators. Modular separators have been installed and are operating in several Westinghouse nuclear plant steam generators. It should be noted that an array of modular separators is also used in the Combustion Engineering System 80 steam generators.

The decision to install the modular separator in the MB-2, rather than a scaled-down Model F separator, was based on a number of considerations. Some of these were:

- o Since there exists such a large variety of primary separator configurations presently in both Westinghouse and other units, no one separator could directly represent more than a small portion of the total steam generator population.
- o The modular separator has an advantage because it is prototypical. This alleviates any scaling uncertainties associated with the large-diameter field units and their scaled-down counterparts used in testing, at least for the Model F design.
- o The modular separator is more efficient at removing moisture, therefore providing higher-quality steam at the exit from the steam generator. Under transient conditions the separator can be expected to produce higher-quality flow. Since this higher-quality flow leads to increased cooldown of the steam generator secondary, the MB-2 SLB test results should provide data for a relatively severe SLB transient. Hence, the more efficient modular separator should provide data which can be applied directly to design calculations, as well as model verification.

The MB-2 modular separator employs four swirl vane blades oriented at 37° from the horizontal, the same as specified in some existing designs. The hub of the swirl vane is slightly elongated and is more streamlined than earlier units. The major design change, aside from the overall size reduction, is that the riser downstream of the hub is perforated with 0.8 cm (0.31 in.) diameter holes, evenly spaced around the circumference. These holes allow the liquid, which has been forced to the periphery of the riser pipe by the centrifugal motion imparted by the blades, to exit the riser and enter the annulus formed by the riser and the riser barrel. The remaining steam/liquid mixture continues to flow upward into the orifice, which also strips off some portion of the liquid. Figure 2-9 provides a view of the steam




Figure 2-6. Revised MB-2 Upper Shell Region (LOF and SGTR Tests)




Figure 2-7. MB-2 with Modified Upper Shell and Downcomer (LOF and SGTR Tests)




Figure 2-8. MB-2 Cross Section at Deck Plate (Elevation 477.01 in.)

87410-11




Figure 2-9. Flow Paths in MB-2 Upper Shell Region (LOF and SGTR Tests)

and liquid flow paths in the upper shell region. The riser barrel extends down approximately 48 cm (19 in.) below the deck plate. Both the riser and riser barrel cylinders are concentrically located about the center of the MB-2 shell (figure 2-8).

Outside of the riser barrel, the unit cell cylinder serves to define the local cross-sectional area which is associated with a single modular separator in a full-size steam generator. A unit cell partition is necessary because the cross-sectional area enclosed within the MB-2 shell is much too large for a single modular separator. The unit cell also encloses the appropriate areas for liquid drainage and steam venting through the deck plate. Liquid which collects on the deck plate is removed by drain pipes extending from the deck plate down to the intermediate deck plate. The vent area is represented by a pipe which extends 12.7 cm (5 in.) above the deck plate. The extension is provided to minimize the potential for reentrainment of any liquid which may be present on the deck plate. Additional vent area is also provided within the unit cell to represent a portion of the steam vent area present in the annular space between the deck plate and shell in the full-size steam generator. The edge of the deck plate is ringed with a 10 cm (4 in.) dam that limits the possibility of liquid reentrainment in the steam vented through the deck-plate-to-downcomer-drum gap. The sizing and layout of these various components are discussed in more detail in the following paragraph.

The riser and riser barrel cylinders used in the MB-2 are identical to those of the prototype modular separator, along with the swirl vane, hub, and orifice. The selection of the appropriate cross-sectional areas within the unit cell, downcomer drum, liquid drain and steam vents was based on matching the areas present in a typical modular separator configured in a Model F shell. Figure 2-10 provides a schematic representation of a Model F upper shell region configured with 130 modular separators. The separators are arranged in a 26 cm (10.25 in.) square-pitch array. The specific arrangement of separators is constrained by the available space enclosed by the feedwater distribution ring. Within the array there are 90 interstitial deck drains and 25 deck vents. In addition, there is a larger cylindrical drain in the center of the array. In the annular space between the edge of the deck plate and the shell there is approximately 4.5 m^2 (48 ft.^2) of area also available for steam venting. This annular area is more accessible to the modular separators located on the periphery of the array. Separators positioned in the interior of the array would not be influenced by this free space. Hence, a variety of separator situations exist from the outside to the inside of the array. It was decided to assign one-half of this peripheral area (on a per-separator basis) to the region which lies within the unit cell for use in defining an average or typical modular separator configuration for the MB-2. This portion is therefore




Figure 2-10. Modular Separators Configured in a Model F Shell

more local to the operation of the separator. The remaining one-half of the peripheral area will be contained within the downcomer drum, which, in effect, serves as a new shell for the single modular separator assembly. The calculations in table 2-1 summarize the derivation of the various areas in the Model F primary separator region and the corresponding areas specified for the MB-2.

The small differences between the desired areas and the actual MB-2 areas are primarily due to the use of commercially-available pipes for the various components.

2-2-2-2. Downcomer. As discussed previously, a cylindrical downcomer drum, 38.7 cm (15.25 in.) in diameter, has been used to limit the upper downcomer cross-sectional area to a value which corresponds to the area associated with a single modular separator configured in a Model F steam generator. The revised cross-sectional area enables the model to more closely represent the transient response of the downcomer liquid in the full-size unit. The previous large downcomer "dead space", between the wrapper box and the lower shell, has been eliminated from the downcomer circuit for the same reason. The lower downcomer volume therefore includes only the water contained within the two 7.8 cm (3.07 in.) ID pipes that feed into the hot and cold leg wrapper openings to the bundle. These pipes were scaled to represent the cross-sectional area in the Model F lower downcomer annulus.

A funnel was needed to link the upper cylindrical drum to the lower downcomer pipes (see figure 2-6). The design specified for the funnel is such that the enclosed water volume is minimized, again to better simulate the Model F downcomer response.

Table 2-2 provides a comparison of the downcomer cross-sectional areas and component volumes in the modified MB-2 and Model F. The differences between desired and actual values are a result of use of commercially-available material.

2-2-2-3. Secondary Separator Drain. The original MB-2 configuration included a drain pipe connected to the secondary separator drain box. This pipe was enclosed within a slightly-larger-diameter guide tube. The liquid flowing in the inner drain pipe discharged into a much larger reservoir called the disengagement tank. The pool of water enclosed in this tank permitted any steam bubbles, which may have been entrained in the secondary drain liquid, to vent to the free space above the deck plate. A 2.54 cm (1 in.) diameter J-tube was connected to the bottom outlet from the disengagement tank. The water flowing through this tube was measured using three differential pressure devices (pitot tube, elbow taps, and a venturi tube).

Table 2-1
COMPARISON OF MODEL F AND MB-2 AREAS

MODEL F

Total area within shell	= 14.39 m ² (154.9 ft ²)
Number of modular separators	= 130
Shell area for each separator	= 0.111 m ² (1.19 ft ²)
Total annular area between edge of deck plate and shell	= 4.47 m ² (48.1 ft ²)
Portion of total annular area to assign to each separator	= 0.34 m ² (0.37 ft ²)
Number of deck drains (3.5 in. Sch. 40 pipes, 9.89 in. ² inside)	= 90
Central drain area	= 0.045 m ² (0.49 ft ²)
Total deck drain area	= 0.62 m ² (6.7 ft ²)
Deck drain area for each separator	= 0.0047 m ² (0.051 ft ²)
Number of deck vents (3.5 in. Sch. 40 pipes, 9.89 in. ² inside)	= 25
Total deck vent area	= 0.16 m ² (1.71 ft ²)
Deck vent area for each separator	= 0.00123 m ² (0.0132 ft ²)

[desired Model F value]

MB-2

Downcomer drum: outer diameter	= 40 cm (15.75 in.)
inner diameter	= 38.7 cm (15.25 in.)
Unit cell: outer diameter	= 34.9 cm (13.75 in.)
inner diameter	= 33.6 cm (13.25 in.)
Area enclosed within downcomer drum (excluding unit cell piping metal)	= 1110 cm ² (172.1 in. ²) [1106 cm ² (171.5 in. ²)]
Area enclosed within unit cell	= 890 cm ² (137.9 in. ²) [935 cm ² (144.9 in. ²)]
Deck drain area (2 and 2 1/2 in. Sch. 40 pipes)	= 52.9 cm ² (8.2 in. ²) [47.4 cm ² (7.4 in. ²)]
Deck vent area (1 1/2 in. Sch. 40 pipe)	= 13.2 cm ² (2.04 in. ²) [12.26 cm ² (1.9 in. ²)]
Additional vent area included within unit cell to account for 1/2 peripheral vent area assigned to a typical modular separator	= 176.8 cm ² (27.4 in. ²) [171.6 cm ² (26.6 in. ²)]

Table 2-2
DOWNCOMER VOLUME/AREA COMPARISON

<u>Component</u>	<u>Modified MB-2 Configuration</u>	<u>Model F</u>
<u>Volumes m³ (ft³)</u>		
a. Upper downcomer	0.148 (5.24)	19.47 (687)
b. Secondary separator dis- engagement pipe, J tube, and extension	0.011 (0.38)	-
c. Downcomer funnel	0.025 (0.89)	-
d. Downcomer dead space	-	-
e. Downcomer pipes and ducts	<u>0.087 (3.09)</u>	<u>12.89 (455)</u>
f. Total	0.272 (9.60)	32.36 (1142)
<u>Volume Ratios</u>		
a. $\frac{\text{Upper downcomer}}{\text{Lower downcomer}}$	2.11	1.51
b. $\frac{\text{Lower downcomer}}{\text{Secondary bundle}}$	0.29	0.29
c. $\frac{\text{Total downcomer}}{\text{Secondary bundle}}$	0.89	0.73
<u>MB-2 Cross-Sectional Areas m² (ft²)</u>		
a. Upper downcomer (typical)	0.086 (0.93)	
b. Lower downcomer pipes	0.009 (0.10)	

Appendix A

TEST MODEL DRAWINGS, DIMENSIONS, FLOW AREAS,
VOLUMES, AND SUPPORT PLATE LOSS COEFFICIENTS

Table A-1

MB-2 TEST SECTION GEOMETRIC DATA

Wrapper box inner dimensions, length x width, in.	26.94 x 3.92
Wrapper wall thickness, in.	1.0
Tube outer diameter, in.	0.6875
Tube wall thickness, in.	0.040
Tube pitch, in.	0.98, square
Wrapper opening height, in.	4.60
Wrapper opening area, in. ²	18.032
Vertical height of straight portion of tubes from top of tubesheet, in.	263.27
Height of straight portion of wrapper box, in.	343.3
Inner diameter of riser, in.	7.0
Height of riser, in.	127.7
Downcomer inner diameter, in.	3.068
Height of downcomer pipe, in.	337.9
Height of lower downcomer annulus, in.	23.4
Height of downcomer duct, in.	7.5
Inner diameter of outer shell, in.	32.0
Flow distribution plate center cutout areas on each side of centerline, in.	2.69 x 3.92
Flow distribution baffle thickness, in.	0.75
Flow distribution baffle hole diameter, in.	0.760
Elevations of flow distribution baffle and support plates above top of tubesheet, in.:	
Flow distribution baffle	20.0
Support plate 1	40.16
Support plate 2	80.32
Support plate 3	120.48
Support plate 4	160.64
Support plate 5	200.80
Support plate 6	240.96
Flow distribution baffle center cutout, in. ²	13.85
Material area of flow distribution baffle, in. ²	46.11
Material area of plates 1, 2, 4 and 5, in. ²	39.68
Material area of plate 3, in. ²	30.48
Material area of plate 6, in. ²	40.08

Table A-2

MB-2 FLOW AREAS

Lower downcomer annulus (elev. 0 - 23.39 in.), in. ²	5.57
Downcomer ducts (elev. 23.39 - 30.89 in.), in. ²	64.72
Downcomer pipes (elev. 30.89 - 368.75 in.), in. ²	14.78
Downcomer funnel (elev. 368.75 - 374.75 in.), in. ²	237.31
Downcomer barrel (elev. 374.75 - 477.01 in.), in. ²	138.48
Dryer drain pipe (SLB tests)	3.56
Between tubesheet & TSP1; between TSPs; between TSP6 and 263.27 in., in. ²	67.00
Between top of U-bends and bottom of transition cone (elev. 276.25 - 343.30 in.), in. ²	105.60
Riser pipe (elev. 349.30 to 477.01 in., excluding the swirl vane), in. ²	38.48
Steam shroud (elev. 477.01 - 513.88 in.), in. ²	182.65
Net flow area of plates 1, 2, 4 and 5	27.31
Net flow area of plate 3	36.51
Net flow area of plate 6	26.91
Net flow area of flow distribution baffle	20.88

Table A-3

MB-2 SECONDARY SIDE VOLUMES

Lower downcomer annulus (elev. 0-23.39 in.), ft ³	0.172
Downcomer ducts (elev. 23.39-30.89 in.), ft ³	0.266
Downcomer pipes (elev. 30.89-368.75 in.), ft ³	2.891
Downcomer funnel (elev. 368.75-374.75 in.), ft ³	0.824
Downcomer barrel (elev. 374.75-477.01 in.), ft ³	8.195
Dryer drain pipe (SLB tests; Elev. 374.75-513.88 in.), ft ³	0.287
Tubesheet to TSP1 (elev. 0-40.16 in.), ft ³	1.506
TSP1 to TSP2 (elev. 40.16-80.32 in.), ft ³	1.514
TSP2 to TSP3 (elev. 80.32-120.48 in.), ft ³	1.535
TSP3 to TSP4 (elev. 120.48-160.64 in.), ft ³	1.535
TSP4 to TSP5 (elev. 160.64-200.80 in.), ft ³	1.514
TSP5 to TSP6 (elev. 200.80-240.96 in.), ft ³	1.514
TSP6 to top of U-bends (elev. 240.96-276.25 in.), ft ³	1.387
Top of U-bends to transition cone (elev. 276.25 - 343.30 in.), ft ³	4.098
Transition cone (elev. 343.30 - 349.30 in.), ft ³	0.436
Riser pipe (elev. 349.30 to 477.01 in.), ft ³	2.813
Steam shroud (elev. 477.01 - 513.88 in.), ft ³	3.922
Steam dome (elev. 514.25 - 551.25 in.), ft ³	13.370

Table A-4

FLOW AREA FRACTIONS AND LOSS COEFFICIENTS
FOR MB-2 SUPPORT PLATES

<u>Component</u>	<u>Flow Area Fraction (σ)</u> ⁽¹⁾	<u>Loss Coefficient(K)</u> ⁽²⁾
Flow distribution baffle	0.312	11.0
Support plates 1, 2, 4 and 5	0.408	5.0
Support plate 3	0.545	0.85
Support plate 6	0.402	5.4

(1) σ - component flow area/approach flow area

(2) Based on test data from an earlier MB-2 model using the same support plate design. $K = \Delta P_p / (V^2 / 2g_c)$, where the velocity (V) is based on the approach flow area.




Figure A-2. MB-2 Steam Nozzle Flow Restrictor

8741E-11




Figure 3-7. Secondary Side Pressure Taps Within Tube Bundle


Table 5-7
BOUNDARY CONDITIONS PRIOR TO SLB

SLB Size (%)	Test Run No.	SG Water Level (in.)	Primary System Pressure (psia)	Primary T _{hot} (°F)	Primary Fluid Flow (lbm/sec)	Secondary Pressure (psia)	Aux. Feedwater Temp. (°F)
100	T-2009	491	2070	560	91	1090	103
100	T-2013	441	2070	560	91	1080	97
100	T-2015	389	2070	560	91	1090	102
100	T-2017	389	2070	560	91	1100	99
100	T-2021	440	2070	561	91	1100	100
100	T-2023	442	2075	560	91	1100	104
50	T-2025	439	2080	562	91	1100	102
8	T-2029	437	1830	581	6.0	988	106
8	T-2031	499	1825	581	6.2	990	100
8	T-2032*	440	1825	581	6.0	1000	102
8	T-2035	440	1825	580	6.0	998	103
8	T-2036*	497	1825	580	6.0	998	103

*10-second burst tests

MB-2

SLB Run 2013



MB-2 SLB Run 2013

Time-sec	Ch. 227	Ch. 240	Ch. 244	Ch. 246	Ch. 247	Ch. 249	Ch. 255	Ch. 260
	0904	0405	0809	0102	0203	0607	506	308
	TSP#4	TSP#5	Grid#3	FDB	TSP#1	U-Bend	TSP #6	TSP #2
60.0	1.70	1.02	0.39	0.29	0.68	0.91	0.36	1.59
60.1	1.84	1.56	0.36	0.12	0.46	0.92	0.72	1.22
60.2	1.80	1.40	0.36	0.03	0.44	1.52	0.69	1.22
60.3	1.73	1.36	0.39	-0.03	0.51	1.22	0.58	1.48
60.4	1.65	1.06	0.39	0.00	0.58	1.05	0.50	1.56
60.5	1.65	1.06	0.39	0.00	0.58	1.05	0.50	1.56
60.6	1.39	0.97	0.34	0.09	0.58	0.93	0.43	1.40
60.7	1.42	0.86	0.34	0.04	0.57	0.91	0.43	1.34
60.8	1.40	0.96	0.33	0.14	0.56	0.90	0.42	1.32
60.9	1.41	0.95	0.32	0.15	0.56	0.92	0.42	1.29
61.0	1.40	0.93	0.32	0.15	0.55	0.89	0.42	1.25
61.1	1.40	0.93	0.32	0.15	0.55	0.89	0.42	1.25
61.2	1.31	0.86	0.29	0.16	0.52	0.84	0.39	1.17
61.3	1.28	0.88	0.30	0.16	0.50	0.84	0.39	1.15
61.4	1.27	0.86	0.29	0.15	0.50	0.83	0.38	1.13
61.5	1.24	0.83	0.27	0.15	0.47	0.82	0.38	1.09
61.6	1.24	0.83	0.27	0.15	0.47	0.82	0.38	1.09
61.7	1.09	0.71	0.25	0.16	0.43	0.69	0.30	1.01
61.8	1.08	0.69	0.25	0.16	0.43	0.67	0.28	1.01
61.9	1.09	0.70	0.28	0.16	0.44	0.68	0.28	1.01
62.0	1.10	0.69	0.25	0.16	0.43	0.67	0.28	1.00

SEP 25 095 04:14PM SGT&E

P. 4/4

Appendix D RELAP5M3 MB2 Model Input Listing

=mb2 test model mslb at hot standby test 2013
* hot standby nonequilibrium models used/inel guidance used on tsp models

*this deck is based on mb2 facility descriptions *

*
* this data is contained in *
* nfskr.relap5(mb2mod) *

100 new transnt

102 british british
105

*----- time step cards

	end	dtmin	dtmax	opt	min	maj	rstrt
201	1.	1.d-7	0.005	3	2	4000	2500
202	3.0	1.d-7	0.0005	3	2	4000	2500
203	1000.	1.d-7	0.005	3	10	4000	2500

*----- minor edit variables

	variable code	parameter	location
301	mflowj	106000000	*breakflow
302	p	105010000	*p81
303	cntrlvar	1	*dp tsp1
304	cntrlvar	2	*dp tsp2
305	cntrlvar	3	*dp tsp3
306	cntrlvar	4	*dp tsp4
307	cntrlvar	5	*dp tsp5
308	cntrlvar	6	*dp tsp6
309	cntrlvar	7	*dp bundle
*305	mflowj	112060000	*dc flow
*306	mflowj	300000000	*break flow
*307	velfj	101060000	*void frac
*308	velfj	101070000	*sg water mass

*----- trip input data

*variable trip cards

	variable	param	relation	variable	param	cons	latch
501	time	0	ge	null	0	11.	1
502	time	0	ge	null	0	1.001	1
503	time	0	ge	null	0	100.	1

*=====

* trip identifier I

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 2

* I
* 501 =>problem stop I

*-----
*
*trip stop advancement card

* trp no.

600 501

*----- hydrodynamic components

*-----
* primary side model I
* plenums and tubes modelled explicitly I
* hot leg and cold leg represented by tdvs I
*-----

*=====

	flowa	l	vol	azi	incl	dz	rough	hyd	pvbfe
0420000 inplen tmdpvol									
0420101	0.0	5.2183	147.64	0.0	0.0	0.0	0.0	0.0	00000
0420101	0.0	5.2183	5000.	0.0	0.0	0.0	0.0	0.0	00000

* ebt

0420200 3

	time	press	temp
0420201	0.0	2070.00	560.000
0420202	1.0e6	2070.00	560.000

*=====

	flowa	l	vol	azi	incl	dz	rough	hyd	pvbfe
0470000 outplen tmdpvol									
0470101	0.0	5.2183	147.64	0.0	0.0	0.0	0.0	0.0	00000
0470101	0.0	5.2183	5000.	0.0	0.0	0.0	0.0	0.0	00000

* ebt

0470200 3

	time	press	temp
0470201	0.0	2026.77	560.
0470202	1.0e6	2026.77	560.

*=====

1510000 tubes pipe

* nv
1510001 16
* flowa nv

```

1510101      .10467   16
*
*      length   nv
1510301     1.6667   1
1510302     1.68     2
1510303     3.34667  7
1510304     2.785    9

```

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 3

```

1510305     3.34667  14
1510306     1.68     15
1510307     1.6667   16

```

```

*
*      volume   nv
1510401     0.0     16

```

```

*
*      incline angle   nv
1510601     90.0       8
1510602    -90.0      16

```

```

*
*      elev cng       nv
*510701     1.6667    1
*510702     1.68      2
*510703     3.3467    7
*510704     3.5833    8
*510705     3.445     9
*510706    -3.445    10
*510707    -3.5833   14
*510708    -1.5      19
*510709    -1.0      20
*510710    -.5625    21

```

```

*
*      rough   hyd dia   nv
1510801     0.0   .050625  16

```

```

*
*      pvbfe   nv
1511001     00000  16

```

```

*
*      fvcahs nj
1511101     001000  15

```

```

*
*      flag   p       t       dummy dummy dummy nv
1511201     3   2070.0  560.0   0.0   0.   0.  16

```

```

*
*      flag=1 => (lbm/sec)
1511300     1

```

```

*
*      lflow       vflow   interfare flow       nj
1511301     91.00     0.0     0.0           15

```

```

*=====
1500000     junct   tmdpjun
*

```

```
*      from      to      area
1500101 042000000 151000000 .10467
```

```
*      flag
1500200 1
```

```
*      time      lflow      vflow      intflow
1500201 0.0          91.0        0.0         0.0
1500202 1.0e6        91.0        0.0         0.0
```

```
*=====
1590000 junct  sngljun
```

```
*      from      to      area      fjunf      fjunr      fvcahs
```

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 4

```
1590101 151010000 047000000 .10467      0.0      0.0      021000
```

```
*      flag      lflow      vflow      intflow
1590201 1          91.0        0.0         0.0
```

```
*=====
```

```
*-----
* secondary side model î
*-----
```

```
*=====
9020000 auxfeed  tmdpvol
```

```
*      flowa      flowl      vol      azi      incl      dz      rough      hyd      pvbfe
9020101 0.0          31.1533  147.64  0.0      0.0      0.0      0.0      0.0      00000
9020101 0.0          31.1533  5000.   0.0      0.0      0.0      0.0      0.0      00000
```

```
*      ebt
9020200 003
```

```
*      time      press      temp
9020201 0.0          1200.0     97.0
9020202 1.0e6        1200.0     97.0
```

```
*=====
3020000 fljun  tmdpjun
```

```
*      from      to      ajun
3020101 902000000 111000000 1.0
```

```
*      flag
3020200 1
```

```
*      time      lflow      vflow      int flow
3020201 0.0          0.         0.0        0.0
```

3020202	1.0	0.	0.0	0.0
3020203	1.01	0.25	0.0	0.0
3020204	11.01	0.34	0.0	0.0
3020205	11.01	0.0	0.0	0.0
3020206	1.0e6	0.	0.0	0.0

1000000 tubesht branch

*

* nj flag

1000001 2 1

*

*	flowa	flowl	vol	azi	incl	dz	rough	hyd	pvbfe
1000101	0.4653	1.6667	0.0	0.0	90.	1.6667	.00015	.09093	00101

*

*	flag	p	x
1000200	1	560.0	0.00

*

*	from	to	ajun	fjun	fjunr	fvcahs
1001101	112010000	100000000	0.03868	1.0	1.0	000000

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 5

1001101	112010000	100000000	0.03868	4.12	4.12	000000
---------	-----------	-----------	---------	------	------	--------

1002101	100010000	101000000	0.4653	11.0	11.0	010000
---------	-----------	-----------	--------	------	------	--------

*

*	lflow	vflow	int flow
---	-------	-------	----------

1001201	0.0	0.0	0.0
---------	-----	-----	-----

1002201	0.0	0.0	0.0
---------	-----	-----	-----

*ccfl/junction hyd diam info

*	hyddia	floodcorr	gasint	slope	nj
---	--------	-----------	--------	-------	----

1001110	.09093	0.	1.	1.	
---------	--------	----	----	----	--

*use hyd of 112 for junc 1 since reverse flow dominates

*1001110	.3442	0.	1.	1.	
----------	-------	----	----	----	--

1002110	.09093	0.	1.	1.	
---------	--------	----	----	----	--

*

1010000 boiler pipe

*

* nv

1010001 22

*

*	flowa	nv
---	-------	----

1010101	.4653	19
---------	-------	----

1010102	.7333	21
---------	-------	----

1010103	.2672	22
---------	-------	----

*

*	jarea	nj
---	-------	----

1010201	.4653	18
---------	-------	----

1010202	.7333	20
---------	-------	----

1010203	.2672	21
---------	-------	----

*

*	length	nv
---	--------	----

1010301	1.68	1
---------	------	---

1010302	3.3467	6
1010303	2.9408	7
1010304	5.5875	8
1010305	0.5	9
1010306	1.6205	10
1010307	1.48	1
1010308	0.2	3
1010309	9467	4
1010310	2	6
1010311	2.9467	7
1010312	0.2	9
1010313	2.9467	10
1010314	0.2	12
1010315	2.9467	13
1010316	0.2	15
1010317	2.9467	16
1010318	0.2	18
1010319	2.7408	19
1010320	5.5875	20
1010321	0.5	21
1010322	1.6205	22
*		
*	volume	nv
1010401	0.0	22
*		

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 6

*	incline angle	nv	
1010601	90.0	22	
*			
*	elev cng	nv	
*010701	3.0	2	
*010702	3.5833	3	
*			
*	rough hyd dia	nv	
1010801	.00015 0.09093	19	
1010802	.00015 0.0	22	
*			
*	fjunf	fjunr	nj
1010901	5.0	5.0	2
1010902	0.85	0.85	3
1010903	5.0	5.0	5
1010904	5.4	5.4	6
1010905	7.23	7.23	7
1010905	61.45	61.45	7
1010906	0.0	0.0	9
1010901	0.0	0.0	1
1010902	5.0	5.0	2
1010903	0.0	0.0	4
1010904	5.0	5.0	5
1010905	0.0	0.0	7
1010906	0.85	0.85	8

7 *add xflow resist here
7 *add xflow resist here with w mult

```

1010907      0.0      0.0      10
1010908      5.0      5.0      11
1010909      0.0      0.0      13
1010910      5.0      5.0      14
1010911      0.0      0.0      16
1010912      5.4      5.4      17
1010913      0.0      0.0      18
1010914      61.45     61.45     19 *add xflow resist here with w mult
1010915      0.0      0.0      21

```

```

*
*      pvbfe      nv
1011001      00101      19
1011002      00001      22

```

```

*      fvcahs nj
1011101      000000 21

```

```

*      flag      p      x      dummy      dummy      dummy      nv
1011201      1      560.00      .0      0.      0.      0.      1
1011202      1      560.00      .0      0.      0.      0.      2
1011203      1      560.00      .0      0.      0.      0.      22

```

```

*      flag=0 => (lbm/sec)
1011300      1

```

```

*      lflow      vflow      interface flow      nj
1011301      0.0      0.0      0.0      21

```

```

*ccfl/junction hyd diam info
*      hyddia      floodcorr      gasint      slope      nj
1011401      .09093      0.      1.      1.      18

```

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 7

```

1011402      0.0      0.      1.      1.      21

```

```

*=====
*=====

```

```

1020000      sep      separatr

```

```

*      nj      flag
1020001      3      1

```

```

*      flowa      flowl      vol      azi      incl      dz      rough      hyd      pvbfe
1020101      .2672      9.0220      0.0      0.0      90.      9.0220      .00015      0.000      00010

```

```

*      flag      p      uf      ug      vg
1020200      1      560.00      0.
1020200      1      560.00      0.025 * initialize to 441 in level

```

```

*      from      to      ajun      fjun      fjunr      fvcahs      vflim
* rearrange losses

```

```

1021101 102010000 103000000 .2672 0.86 0.86 000000
1022101 102000000 111010000 .1854 1.0 1.0 000000

```

```

1023101 101010000 102000000 .2672 1.0 1.0 000000
1023101 101010000 102000000 .2672 19.1 19.1 000000

```

```

*
*      lflow      vflow      int flow
1021201      0.0      0.0      0.0
1022201      0.0      0.0      0.0
1023201      0.0      0.0      0.0

```

```

*ccfl/junction hyd diam info

```

```

*      hyddia      floodcorr      gasint      slope      nj
*1021110      1.625      0.      1.      1.

```

```

*=====
1030000      unit      branch

```

```

*
*      nj      flag
1030001      2      1

```

```

*      flowa      flowl      vol      azi incl      dz      rough      hyd      pvbfe
1030101      1.2684      1.      0.0      0.0 90.      1.      .00015      0.0      00000

```

```

*      flag      p      uf      ug      vg
1030200      1      560.00      0.0
1030200      1      560.00      1.0      * initialize to 441 inch level

```

```

*      from      to      ajun      fjun      fjunr      fvcahs      vflim
1031101 103000000 110010000 .204 0.0 0.0 010000
1032101 103010000 104000000 1.2684 0. 0. 010000

```

```

*      lflow      vflow      int flow
1031201      0.0      0.0      0.0
1032201      0.0      0.0      0.0

```

```

*ccfl/junction hyd diam info

```

```

*      hyddia      floodcorr      gasint      slope      nj
*1031110      3.05      0.      1.      1.
*1032110      4.07      0.      1.      1.

```

```

*=====
1040000      unit      snglvol

```

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 8

```

*      flowa      flowl      vol      azi incl      dz      rough      hyd      pvbfe
1040101      1.2684      1.0      0.0      0.0 90.      1.0      0.00015      0.00      00000

```

```

*      flag      p      x
1040200      001      560.      1.0

```

```

*=====
2500000      dryerdrn      snglvol

```

```

*      flowa      flowl      vol      azi incl      dz      rough      hyd      pvbfe
2500101      .02472      10.522      0.0      0.0 -90.      -10.522      0.00015      0.0      00000

```

```

*      flag      p      x
2500200      001      560.      .5

```

2500200 001 560. .045 *initialize at 441 in

1240000 dryer branch

*
* nj flag

1240001 3 1

*
* flowa flowl vol azi incl dz rough hyd pvbfe
1240101 1.2684 1.0725 0.0 0.0 90. 1.0725 .00015 0.000 00000

*
* flag p uf ug vg
1240200 1 560.00 1.0

*
* from to ajun fjun fjunr fvcahs vflim
1241101 104010000 124000000 1.2864 .0 .0 030000
1242101 124010000 105000000 1.2864 0. 0. 030000
1243101 250000000 124000000 .02472 0.5 0.5 010000

*
* lflow vflow int flow
1241201 0.0 0.0 0.0
1242201 0.0 0.0 0.0
1243201 0.0 0.0 0.0

*ccfl/junction hyd diam info

*
* hyddia floodcorr gasint slope nj
*1241110 .0417 0. 1. 1.
*1242110 11.02 0. 1. 1.
*1243110 1.604 0. 1. 1.

1050000 dome pipe

*
* nv
1050001 2

*
* flowa nv
1050101 4.2933 2

*
* jarea nj
1050201 4.2933 1

*
* length nv
1050301 0. 2

*

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 9

*
* volume nv
1050401 6.685 2

*
* incline angle nv
1050601 90.0 2

*
*


```

*      rough  hyd dia  nv
1050801 .00015  0.0    2
*
*      fjunf      fjunr      nj
1050901  .0        .00    1
*
*      pvbfe  nv
1051001  00000  2
*test effect of vertical stratification in dome
*1051001  01000  2
*
*      fvcahs nj
1051101  000000 1
*
*      flag  p      x      dummy  dummy  dummy  nv
1051201  1  560.00  1.0    0.    0.    0.    2
*
*      flag=0 => (lbm/sec)
1051300  1
*
*      lflow      vflow  interface flow      nj
1051301  0.0        0.0    0.0        1
*
*ccfl/junction hyd diam info
*      hyddia  floodcorr  gasint  slope  nj
*1051401  12.83    0.    1.    1.    1
*=====
*=====
*****
1060000  nozzle sngljun
*
*      from      to      area  fjunf  fjunr  fvcahs
1060101 105010000 107000000 0.0092175 0.0    0.0    000100
*1060101 105010000 107000000 0.007374 0.0    0.0    000100 *80% area case at noz
*1060101 105010000 107000000 0.00645225 0.0    0.0    000100 *70% area case at n
*
*      flag  lflow      vflow      int flow
1060201  1      0.0        0.0        0.0
*****
1070000  nozzle snglvol
*
*      flowa  flowl      vol  azi  incl  dz      rough  hyd  pvbfe
1070101  0.014  1.5        0.0  0.0  90.  1.5    .00015  0.0  00000
*
*      flag  p      x
1070200  002  1106.  1.0
1070200  001  560.  1.0
*=====
3000000  break  valve

```

*

* from to ajun
3000101 107010000 900000000 0.014 0.0 0.0 00100

*
* time lflow vflow intflow
3000201 1 0.0 0.0 0.0

3000300 mtrvly
3000301 502 503 10.0 0.0
*3000301 502 503 2.0 0.0

*=====

9000000 break tmdpvly

* flowa flowl vol azi incl dz rough hyd fe
9000101 0.0 31.1533 147.64 0.0 0.0 0.0 0.0 0.0 00
9000101 5.0 0.0 9999. 0.0 0.0 0.0 0.0 0.0 00

* ebt
9000200 002

* time press x
9000201 0.0 14.7 1.0
9000202 1.0e6 14.7 1.0

*=====

1110000 funnel branch

* nj flag
1110001 3 1

* flowa flowl vol azi incl dz rough hyd pvbfe
1110101 1.648 .50 0.0 0.0 -90. -0.50 0.00015 0.0 00000

* flag p x
1110200 1 560.0 0.0

* from to ajun fjun fjunr fvcchs
1111101 111010000 112000000 .10264 0.5 1.0 000000
1112101 111000000 110000000 .96167 0.0 0.0 000000
1113101 250010000 111000000 .02472 1.0 0.5 000000

* lflow vflow int flow
1111201 0.0 0.0 0.0
1112201 0.0 0.0 0.0
1113201 0.0 0.0 0.0

*ccfl/junction hyd diam info

* hyddia floodcorr gasint slope nj
*1111110 .3442 0. 1. 1.
*1112110 11.89 0. 1. 1.
*1113110 1.604 0. 1. 1.

*=====

1100000 udc snglvly

* flowa flowl vol azi incl dz rough hyd pvbfe
1100101 .96167 8.522 0.0 0.0 90. 8.522 0.0 0.0 00000

```

*
*      flag      p      x
1100200  001      560.      0.033
*=====
1120000  ldc1-3 pipe
*
*      nv
1120001  12
*
*      flowa      nv
1120101  0.10264  10
1120102  0.44944  11
1120103  0.0368   12
*
*      length      nv
1120301  2.81548  10
1120302  .625     11
1120303  1.9492   12
*
*      volume      nv
1120401  0.0      12
*
*      incline angle      nv
1120601  -90.0    12
*
*      elev cng      nv
1120701  -2.81548  10
1120702  -.625     11
1120703  -1.9492   12
*
*      rough hyd dia      nv
1120801  0.0      0.      12
*
*      pvbfe      nv
1121001  00001    12
*
*      fvcahs nj
1121101  000000  11
*
*      flag      p      x      dummy      dummy      dummy      nv
1121201  1      560.00  0.0      0.      0.      0.      12
*
*      flag=0 => (lbm/sec)
1121300  1
*
*      lflow      vflow      interface flow      nj
1121301  0.0      0.0      0.0      11
*
*ccfl/junction hyd diam info
*      hyddia      floodcorr      gasint      slope      nj
*1121401  0.0      0.      1.      1.      14
*****
*****
*----- heat structure input
*

```

*general data

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 12

* nh np geo ss left coord.
11511000 16 11 2 1 0.0253125

*mesh flags

* location flg format flag
11511100 0 2

*mesh data

* mesh interval int #
11511101 .00033333 10

*composition data

* comp. # int #
11511201 1 10

*heat distribution data

* source int #
11511301 0.0 10

*initial temperature data

* temp. int #
11511401 560.0 11

*left bc cards

*	bvl	inc	type	surf	cyl ht	struct #
11511501	151010000	0000	1	0	13.784	1
11511502	151020000	0000	1	0	13.8943	2
11511503	151030000	10000	1	0	27.6783	7
11511504	151080000	10000	1	0	23.0325	9
11511505	151100000	10000	1	0	27.6783	14
11511506	151150000	0000	1	0	13.8943	15
11511507	151160000	0000	1	0	13.784	16

*right bc cards

*	bvr	inc	type	surf	cyl ht	struct #
11511601	100010000	0	1	0	15.5992	1
11511602	101010000	0000	1	0	15.724	2
11511603	101040000	30000	1	0	31.3232	7
11511604	101070000	0000	1	0	26.06558	9
11511605	101160000	-30000	1	0	31.3232	14
11511609	101010000	0000	1	0	15.724	15
11511610	100010000	0000	1	0	15.5992	16

*source data

* source mult ldh rdh struct #
11511701 0 0.0 0.0 0.0 16

*left boundary cards

* hdiam hlf hlr gridf gridr grdlssf grdlssr lbf struct #

```

11511801  0.    10.0    10.0    1.5  1.5    0.0    0.0  1.  16
*=====
*right boundary cards
*          hdiam  hlf      hlr    gridf  gridr  grdlssf grdlssr lbf struct =
11511901  0.    10.0    10.0    1.5  1.5    0.0    0.0  1.  16
*****
*----- heat structure thermal property data

```

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 13

```

*
*composition type and data format
*          material type  flag  flag
20100100      tbl/fctn      1    1    * inconel
*=====

```

```

*-----
* thermal conductivity data (btu/sec-ft/deg f) and volumetric heat
* capacity data (btu/ft**3-deg f) versus temperature for above
* composition
*-----

```

```

*=====
*inconel 600 thermal conductivity data
*          temperature      thermal conductivity
20100101      70.0          2.3843e-03
20100102      200.0         2.5232e-03
20100103      400.0         2.8009e-03
20100104      600.0         3.0787e-03
20100105      800.0         3.3565e-03
20100106     1000.0         3.6574e-03
20100107     1200.0         3.9815e-03
20100108     1400.0         4.3056e-03
20100109     1600.0         4.6296e-03
*=====

```

```

*inconel 600 volumetric heat capacity data
*          temperature      heat capacity
20100151      70.0          55.6831
20100152      200.0         55.5227
20100153      400.0         55.2607
20100154      600.0         54.9895
20100155      800.0         54.7069
20100156     1000.0         54.3982
20100157     1200.0         54.0907
20100158     1400.0         53.7516
20100159     1600.0         53.4205
20100160     1800.0         53.0796
*=====

```

```

*----- control system for measuring sg level

```

*
*
*-----
* note: the following control system is to work in british
* units (lbm, lbf, ft, s, p=lbf/sqin). in relap5
* the quantities stored in arrays are in si units.
* therefore, conversions from si to british units
* must be made.
*-----

IIIIIIII

*----- control variable card type
20500000 999

Oct 12 14:02 1995 rrunner:/nfs/sa/nfskr/relap5/mb2mod Page 14

*----- control component cards

* compute pressure difference

	name	type	scale(psi/pa)	init	flag
20500100	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500101	0.0 -1.0,	p,	101030000	1.0, p,	101010000
*					
20500200	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500201	0.0 -1.0,	p,	101060000	1.0, p,	101040000
*					
20500300	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500301	0.0 -1.0,	p,	101090000	1.0, p,	101080000
*					
20500400	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500401	0.0 -1.0,	p,	101120000	1.0, p,	101090000
*					
20500500	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500501	0.0 -1.0,	p,	101170000	1.0, p,	101140000
*					
20500600	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500601	0.0 -1.0,	p,	101180000	1.0, p,	101170000
*					
20500700	deltpp	sum	1.45003e-04	0.0	1
*	a0 a1	var var	vol vol	a2 var	vol
20500701	0.0 -1.0,	p,	101200000	1.0, p,	101010000
*					

```
*
*****
*****
*****
*****
*
*
* end of input deck - problem end
*
*
*****
```