

Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

October 13, 1995
LIC-95-0196

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

References: 1. Docket No. 50-285
2. Letter from OPPD (T. L. Patterson) to NRC (Document Control Desk) dated September 15, 1995 (LIC-95-0172)

SUBJECT: September 1995 Monthly Operating Report (MOR)

Enclosed please find the September 1995 MOR for Fort Calhoun Station (FCS) Unit No. 1 as required by FCS Technical Specification 5.9.1.

Also enclosed are the corrected "Operating Data Report" and "Unit Shutdowns and Power Reductions" forms for the August 1995 report period. Reference 2 was submitted with the number of forced outage hours as 39.1 rather than 52.4 hours. During preparation of the August MOR, the number of forced outage hours was inadvertently calculated using reactor critical hours rather than generator on-line hours.

If you should have any questions, please contact me.

Sincerely,



T. L. Patterson
Division Manager
Nuclear Operations

Enclosures

c: Winston & Strawn
L. J. Callan, NRC Regional Administrator, Region IV
R. L. Wharton, NRC Project Manager
W. C. Walker, NRC Senior Resident Inspector
R. T. Pearce, Combustion Engineering
R. J. Simon, Westinghouse
INPO Records Center

9510190217 951013
PDR ADOCK 05000285
R PDR

JE24