

BCD/Sci

IE-01

October 5, 1995

Mr. R. E. Querio  
Site Vice President  
LaSalle County Station  
Commonwealth Edison Company  
2601 North 21st Road  
Marseilles, IL 61341

SUBJECT: NRC INTEGRATED INSPECTION REPORT NOS. 50-373/95007(DRP)  
AND 50-374/95007(DRP)

Dear Mr. Querio:

This refers to inspection conducted on July 22 through August 31, 1995, at the LaSalle facility. The purpose of the inspection was to determine whether activities authorized by the license were conducted safely and in accordance with NRC requirements. At the conclusion of the inspection, findings were discussed with those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

No violations of NRC requirements were identified during the course of this inspection. However, we are concerned that you had not taken action to correct the design vulnerability of the reactor building ventilation system. As a result, your operators were again challenged to respond to a difficult reactor scram. We are concerned that there may be other design vulnerabilities which are not being promptly addressed.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practices," a copy of this letter and its enclosure will be placed in the NRC Public Document Room (PDR). We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original Signed by W. L. Axelson for

Brent Clayton, Chief  
Reactor Projects Branch 5

Docket Nos: 50-373; 50-374  
License Nos: NPF-11; NPF-18

Enclosure: Inspection Reports  
No. 50-373/95007(DRP);

100035

IEO/11

9510190264 951005  
PDR ADOCK 05000373  
G PDR

cc w/encl: J. C. Brons, Vice President,  
 Nuclear Support  
 J. S. Perry, Vice President, BWR Operations  
 D. J. Ray, Station Manager  
 J. Burns, Regulatory Assurance  
 Supervisor  
 D. Farrar, Nuclear Regulatory  
 Services Manager  
 Richard Hubbard  
 Nathan Schloss, Economist  
 Office of the Attorney General  
 State Liaison Officer  
 Chairman, Illinois Commerce  
 Commission

Distribution:

Docket File w/encl  
 PUBLIC IE-01 w/encl  
 OC/LFDCB w/encl  
 SRI LaSalle, Dresden,  
 Quad Cities w/encl  
 Project Manager, NRR w/encl

DRP w/encl  
 RIII PRR w/encl  
 W. L. Axelson, RIII w/encl  
 IPAS (E-Mail) w/encl

DOCUMENT NAME: R:\INSPRPTS\POWERS\LASS\LAS95007.DRP

To receive a copy of this document, indicate in the box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII	E	RIII	RIII	E	RIII	E
NAME	Hills/co <i>DB</i>		Creed <i>WLF</i>	Gardner <i>W</i>		Clayton <i>DB</i>	
DATE	10/3/95		10/3/95	10/3/95		10/5/95	

OFFICIAL RECORD COPY

*for*