



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-4-104
(412) 787-5141
(412) 923-1960
Telecopy (412) 787-2629
July 16, 1984

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. Harold R. Denton
Director of Nuclear Reactor Regulation
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
Alternate Pipe Break Design Criteria and Safety Balance for
Elimination of Large Primary Loop Pipe Ruptures

- REFERENCES:
1. NRC Generic Letter 84-04 dated 2/1/84
 2. DLC Letter 2NRC-4-017 dated 2/24/84
 3. NRC Letter to DLC dated 4/10/84
 4. DLC Letter 2NRC-4-071 dated 5/31/84

Gentlemen:

In support of our request for exemption to General Design Criterion 4 (Reference 2), this letter transmits five (5) copies of both proprietary (WCAP-10565) and non-proprietary (WCAP-10564) versions of the "Technical Bases for Eliminating Large Primary Loop Rupture as the Structural Design Basis for Beaver Valley Unit 2."


As Item 1 contains information proprietary to Westinghouse Electric Corporation, it is supported by an affidavit signed by Westinghouse, the owner of the information. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission and addresses with specificity the considerations listed in paragraph (b)(4) of Section 2.790 of the Commission's regulations.

Accordingly, it is respectfully requested that the information which is proprietary to Westinghouse be withheld from public disclosure in accordance with 10CFR Section 2.790 of the Commission's regulations. Correspondence with respect to the proprietary aspects of the Application for Withholding or the supporting Westinghouse affidavit should reference CAW-84-53, and should be addressed to R. A. Wiesemann, Manager, Regulatory & Legislative Affairs, Westinghouse Electric Corporation, P.O. Box 355, Pittsburgh, Pennsylvania 15230.

Should you have any questions concerning this matter, please contact this office.

DUQUESNE LIGHT COMPANY

8407240471 840716
PDR ADOCK 05000412
A PDR

By 
E. W. Woolever
Vice President

CHG: PDR }
LPDR }
NSIC }
NTS }
BUL }
NON PROP ONLY

5 NON PROP
5 PROP

8001
1/5

United States Nuclear Regulatory Commission
Mr. Harold R. Denton
Page 2

GHO/nml
Enclosures

cc: Mr. G. W. Knighton, Chief (w/o enc)
Ms. M. Ley, Project Manager (w/o enc)
Mr. A. E. Licitra, Project Manager (w/o enc)
Mr. G. Walton, NRC Resident Inspector (w/o enc)