

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD PERRY, OHIO 44081 (216) 259-3737 Mail Address: PO. BOX 97 PERRY, OHIO 44081 Donald C. Shelton SENIOR VICE PRESIDENT NUCLEAR

October 16, 1995 PY-CEI/NRR-1989L

United States Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Perry Nuclear Power Plant Docket No. 50-440 Monthly Operating Report

Gentlemen:

Attached is the September 1995 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If you have any questions or require additional information, please contact Mr. James D. Kloosterman, Manager - Regulatory Affairs at (216) 280-5833.

Very truly yours,

GMN:sc

Attachment

cc: NRC Project Manager

NRC Resident Inspector Office

NRC Region III

100085

Operating Companies Cleveland Electric Illuminating Toledo Edison

9510190380 950930 PDR ADDCK 05000440 R PDR [F24

CLEVELAND ELECTRIC ILLUMINATING COMPANY PERRY NUCLEAR POWER PLANT

September 1, 1995 - September 30, 1995

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER: 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Da:	ily I	Unit	Power	Lev	el	•	*	٠	٠	٠	٠	٠		٠	٠	٠	٠	٠	٠	٠	٠	٠	٠	1
Operating I	Data	Repo	ert .				٠		·			٠	٠			٠			٠		1		·	2
Unit Shutdo	owns	and	Power	Red	uci	tic	ons	3				į												(7)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-440
UNIT Perry One
DATE 10/13/95
CONTACT G.M.Neuman
TELEPHONE (216)280-5815

MONTH September 1995

AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DATLY POWER LEVE
(MWe-Net)		(MWe-Net)
0	17	1156
0	18	1165
0	19	1161
23	20	1157
195	21	1157
633	22	1161
1094	23	1126
1157	24	1169
1160	25	1166
1105	26	1166
656	27	1164
0	28	1165
0	29	1159
7	30	1158
391	31	N/A
932		

OPERATING DATA REPORT

Perry One 10/13/95

UNIT: DATE:

Docket: 50-440	1005		
Reporting Period: September			
Utility Contact: G.M.Neuman		and the same of th	
Licensed Thermal Power (MWt):	3579		
Nameplate Rating (Gross MWe):	1250	Table 1	
Design Electrical Rating (net		1006	
Maximum Dependable Capacity (G		1225	
Maximum Dependable Capacity (N		1166	0) 01
If Changes Occur in Capacity R Last Report, Give Reasons: None	acings (Item	Numbers 4 through	o) since
Power Level to Which Restricted			
Reasons for Restrictions, if a	ny: Operating	License	
	This Month	Yr-to-Date	Cumulative
Hours In Reporting Period	720.0	6,551.0	68,963.0
Hours Reactor was Critical	630.7	6,295.6	48,226.0
Reactor reserve Shutdown Hours	0.0	0.0	0.0
Hours Generator On-Line	562.5	6,141.8	46,429.8
Unit Reserve Shutdown Hours	0.0	0.0	0.0
Gross thermal Energy (MWH)	1,780,548	21,249,169	158,245,074
Gross Electrical Energy (MWH)	595,766	7,213,183	54,262,929
Net Electrical Energy (MWH)	563,058	6,878,755	51,563,582
Unit Service Factor	78.1%	93.8%	67.3%
Unit Availability Factor	78.1%	93.8%	67.3%
Unit Capacity Factor (using			
MDC Net)	67.1%	90.1%	64.7%
Unit Capacity Factor (Using			All the ter Added that shall be disting the party of the
DER Net)	65.7%	88.2%	62.87%
Unit Forced Outage Rate	21.9%	6.2%	10.8%
Forced Outage Hours	157.5	409.2	5,604.2
Shutdowns Scheduled Over Next 6	Months (Type	e, Date, and Dura	tion of Each):
January 12 1006 Pafiral Outage	#5. 57 day	duration	
January 13, 1996, Refuel Outage			THE RESERVE OF THE PERSON NAMED IN COLUMN TWO IS NOT THE PERSON NAMED IN COLUMN TWO IS NAME

UNIT SHUTDOWNS AND POWER REDUCTIONS REPORT MONTH SEPTEMBER 1995

DOCKET NO. 50-440
UNIT NAME Perry One
DATE 10/13/95
CONTACT G.M.Neuman
TELEPHONE (216)280-5815

NO.	DATE	TYPE 1	DURATION HOURS	REASON 2	METHOD 3	LER #	SYSTEM 4	COMP.	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
95-08	8/31	F	40.8	A	4	05	ВО	INVT	Cont. FO, Power supply failure caused an inadvertent RCIC initiation.
95-09	9/2	F	43.6	G	3	07	N/A	N/A	Feedwater Control Error
95–10	9/11	F	49.9	A	3	08	ВО	INVT	Power supply failure caused an inadvertent RCIC initiation.
95–11	9/14	F	23.2	A	9	N/A	N/A	N/A	Main Turbine Trip, low oil bearing header pressure.

SUMMARY: Perry Unit One started the month preparing for start-up. On 9/2 an operator error involving feedwater control resulted in an automatic scram. The unit was back on line at 1311 on 9/4 and 100% power was achieved on 9/7 at 1150. On 9/11 a power supply failure caused an inadvertent RCIC initiation, resulting in an automatic scram. The plant started back up on 9/13 at 1545. The unit was on-line for approximately three hours when a main turbine trip occurred. The unit was back on-line on 9/14, achieved 100% at 2115 on 9/16, and remained on line through month end

1. TYPE:

- F: Forced
- S: Scheduled

2. REASON:

- A-Equipment Failure (explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Examination
- F-Administrative
- G-Operational Error (explain)
- H-Other (explain)

3. METHOD

- 1-Manual
- 2-Manual Scram
- 3-Automatic Scram
- 4-Continued
- 5-Reduced Load
- 9-Other

- 4. EXHIBIT G- Instructions
 - for preparation of data entry sheets for Licensee Event Report (LER) file
 - (NUREG 1022)
- 5. EXHIBIT 1-Same Source