



A Centenor Energy Company

EDISON PLAZA
300 MADISON AVENUE
TOLEDO, OHIO 43652-0001

October 10, 1995

Ohio Environmental Protection Agency
Division of Surface Water
CM&E - Permit Compliance Unit
1800 Watermark Drive
P.O. Box 1049
Columbus, Ohio 43215

Ladies and Gentlemen:

Subject: Submittal of the September 1995 Wastewater Report

Attached is the September 1995 Wastewater Report for the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1, Permit Number 2IB00011*ED.

If you have any questions, please contact Mr. William T. O'Connor, Manager - Regulatory Affairs, at (419) 249-2366.

Very truly yours,

A handwritten signature in cursive script that reads 'John K. Wood'.

John K. Wood
Plant Manager
Davis-Besse Nuclear Power Station

TKW/lkg

Attachments

cc: Z. A. Clayton, Ohio Environmental Protection Agency
U. S. Nuclear Regulatory Commission Document Control Desk

100093

9510200134 950930
PDR ADDCK 05000346
R P R

JE23/1

TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. WSTOP 2101
TOLEDO 43652 OTTAWA

2IB00011001

SEP 1995

1 1

10/05/95

OH0003786

001 DISCHARGE TO LAKE ERIE

FORM

TOLEDO EDISON

T. WASCH

	1 999 WATER TEMP. F	3 1 PH S.U.	1 999 CONDUIT FLOW MGD	3 1 CHLOR FREE A MG/L
	00011	00400	50050	50064
01	80.6	8.7	27.9	AA
02	78.8	8.7	27.9	AA
03	80.6	8.7	27.8	AA
04	78.8	8.7	27.8	AA
05	77.4	8.7	27.8	AA
06	77.6	8.6	27.7	AA
07	76.3	8.7	33.7	AA
08	73.8	8.7	27.8	AA
09	71.9	8.6	27.7	AA
10	71.0	8.6	27.7	AA
11	70.1	8.6	27.7	AA
12	73.4	8.6	27.7	AA
13	71.6	8.8	28.4	AA
14	74.0	8.7	29.0	AA
15	71.7	8.7	29.0	AA
16	72.2	8.7	29.6	AA
17	71.6	8.7	28.7	AA
18	68.5	8.6	28.6	AA
19	68.8	8.7	28.6	AA
20	69.8	8.7	28.6	AA
21	69.1	8.7	28.6	AA
22	65.8	8.7	28.6	AA
23	62.3	8.6	28.7	AA
24	63.3	8.6	28.6	AA
25	64.3	8.7	28.6	AA
26	64.8	8.6	28.6	AA
27	66.0	8.7	36.1	AA
28	65.7	8.7	29.3	AA
29	68.0	8.6	28.4	AA
30	69.4	8.6	28.2	AA
31				
	2137.2	---	863.40	AA
	71.240	---	28.780	AA
	80.600	8.8000	36.100	AA
	62.300	8.6000	27.700	0.0000

AA: The free available chlorine detection limit is 0.05 mg/L using the direct amperometric method.

REPORTER

10/10/95

T. Wood

Plant Manager

2IB00011001



TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. NSTOP 2101
TOLEDO 43652 OTTAWA

2IB00011003

SEP 1995

1 1

10/05/95

OH0003786

003 OUTFALL NAVARRE MARSH

FORM

TOLEDO EDISON

T. WASCH

3	1
1	999
RESIDU	CONDUI
T. WPL	FLOW
MG/L	MGD

00530 50050

01	0.222
02	0.222
03	0.222
04	0.222
05	0.222
06	22.9 0.222
07	0.222
08	0.222
09	0.222
10	0.222
11	0.222
12	0.222
13	0.222
14	0.222
15	0.222
16	0.222
17	0.222
18	0.222
19	0.222
20	0.222
21	0.222
22	0.222
23	0.222
24	0.222
25	0.222
26	0.222
27	0.222
28	0.222
29	0.222
30	0.222
31	

22.9000	6.6600
22.9000	0.2220
22.9000	0.2220
22.9000	0.2220

REPORTER

10/10/95

Wood

Plant Manager

FORM

2IB00011003



TOLEDO EDISON COMPANY
DAVIS-BRESSE NUCLEAR-
POWER STATION - UNIT NO. 1
300 MADISON AV. NSTOP 2101
TOLEDO 43652 OTTAWA

2IB00011602

SEP 1995

1 1

10/05/95

OH0003786

602 LOW VOLUME WW SETTLING BASIN OVERFLOW

FORM

TOLEDO EDISON

T. WASCH

	1	3	3
	999	1	1
	CONDU	RESIDU	O&G
	FLOW	T. NPL	TOTAL
	MGD	MG/L	MG/L
	50050	00530	00550
01	0.286		
02	0.286		
03	0.286		
04	0.286		
05	0.286		
06	0.286	AA	
07	0.286		AA
08	0.286		
09	0.286		
10	0.286		
11	0.286		
12	0.286		
13	0.286		
14	0.286		
15	0.286		
16	0.286		
17	0.286		
18	0.286		
19	0.286		
20	0.286	AA	
21	0.286		AA
22	0.286		
23	0.286		
24	0.286		
25	0.286		
26	0.286		
27	0.286		
28	0.286		
29	0.286		
30	0.286		
31			
	8.5800	0.0000	0.0000
	0.2860	0.0000	0.0000
	0.2860	0.0000	0.0000
	0.2860	0.0000	0.0000

AA: The Oil and Grease detection limit is 1.0 mg/L using the partition-gravimetric method.
AA: The Total Non-filterable Residue detection limit is 1.0 mg/L using the gravimetric method.

REPORTER

10/10/95

Wood

Plant Manager

2IB00011602

