

Arizona Public Service Company

RECEIVED
NRC

1984 OCT -1 PM 12:48

September 27, 1984
ANPP-30681-TDS/TRB

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 84-63
A 50.55(e) Potentially Reportable Deficiency Relating To SIT
Vent Valve Did Not Close During Testing.
File: 84-019-026; D.4.33.2


Reference: Telephone Conversation between P. Narbut and T. Bradish on
August 31, 1984

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the referenced telephone conversation. At that time, it was estimated that a determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim Report is attached. It is now expected that this information will be finalized by October 24, 1984, at which time a complete report will be submitted.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVB/TRB/nj
Attachment

cc: See Page Two

8410160298 840927
PDR ADOCK 05000528
S PDR

IE-27, 11

Mr. T. W. Bishop
DER 84-63
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
R. P. Zimmerman
L. Clyde
M. Woods
T. J. Bloom

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 84-60
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1

I. Potential Problem

Valve SIB HV613 is a Target Rock solenoid valve. It is located on a SIT vent line. This valve is required for relieving SIT pressure during cooldown of the reactor. This is a failed close valve.

SIB-613 did not close when required during testing. The valve was opened when SIT pressure was 600 psig and would not close via the handswitch at 200 psig. The power was shut off to the valve and it still would not close. The cause of the failure has not been determined.

II. Approach To and Status Of Proposed Resolution

Two other DERs (84-58 and 84-67) have been written to document similar situations on Target Rock solenoid valves for other systems.

Bechtel Engineering is currently studying this problem to determine reportability and technical justification for corrective action.

III. Projected Completion of Corrective Action
and Submittal of the Final Report

The complete evaluation and final report are forecast to be completed by October 24, 1984.