

October 16, 1995

Mr. Nicholas J. Liparulo  
Nuclear Safety and Regulatory Activities  
Westinghouse Electric Corporation  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

SUBJECT: SAMPLE PROBLEM FOR COMPUTER CODE VALIDATION REGARDING THE  
CONTAINMENT VESSEL DESIGN FOR THE AP600

Dear Mr. Liparulo:

As agreed during the August 30 and 31, 1995, meeting regarding the containment vessel AP600 design, the Nuclear Regulatory Commission has prepared a sample problem for Westinghouse to validate the Chicago Bridge and Iron Company in-house computer code "E0781B" and resolve the staff's concern of Draft Safety Evaluation Report Open Item 3.8.2.4-8. The attached sample problem involves the axisymmetric model for internal pressure and wind analyses. If you have any questions, please contact Diane Jackson at (301) 415-8548 or Thomas Cheng at (301) 415-2770.

Sincerely,  
Original signed by  
Diane T. Jackson, Project Manager  
Standardization Project Directorate  
Division of Reactor Program Management  
Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosure: As stated

cc: See next page

DISTRIBUTION:

Docket File	DCrutchfield	WDean, EDO
PUBLIC	BGrimes	JMoore, 0-15 B18
PDST R/F	TQuay	ACRS (11)
RArchitzel	TKenyon	GBagchi 0-7 H15
DJackson	WHuffman	

DOCUMENT NAME: SAMPLEPR.BLM

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDST:DRPM	SC:PDST:DRPM			
NAME	DJackson:sp	RArchitzel			
DATE	10/14/95	10/11/95			

100155

LF03  
11

9510200291 951016  
PDR ADDCK 05200003  
A PDR

NRC FILE CENTER COPY

Mr. Nicholas J. Liparulo  
Westinghouse Electric Corporation

cc: Mr. B. A. McIntyre  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
P.O. Box 355  
Pittsburgh, PA 15230

Mr. John C. Butler  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Box 355  
Pittsburgh, PA 15230

Mr. M. D. Beaumont  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
One Montrose Metro  
11921 Rockville Pike  
Suite 350  
Rockville, MD 20852

Mr. Sterling Franks  
U.S. Department of Energy  
NE-42  
Washington, DC 20585

Mr. S. M. Modro  
EG&G Idaho Inc.  
Post Office Box 1625  
Idaho Falls, ID 83415

Mr. Frank A. Ross  
U.S. Department of Energy, NE-42  
Office of LWR Safety and Technology  
19901 Germantown Road  
Germantown, MD 20874

Docket No. 52-003  
AP600

Mr. Ronald Simard, Director  
Advanced Reactor Programs  
Nuclear Energy Institute  
1776 Eye Street, N.W.  
Suite 300  
Washington, DC 20006-3706

STS, Inc.  
Attn: Lynn Connor  
Suite 610  
3 Metro Center  
Bethesda, MD 20814

Mr. James E. Quinn, Projects Manager  
LMR and SBWR Programs  
GE Nuclear Energy  
175 Curtner Avenue, M/C 165  
San Jose, CA 95125

Mr. John E. Leatherman, Manager  
SBWR Design Certification  
GE Nuclear Energy, M/C 781  
San Jose, CA 95125


Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott  
600 Grant Street 42nd Floor  
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager  
PWR Design Certification  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94303

Mr. Charles Thompson, Nuclear Engineer  
AP600 Certification  
U.S. Department of Energy  
NE-451  
Washington, DC 20585

Axisymmetric Model for Internal Pressure and wind Analyses

Elevation  
256' 8 1/2"



218' 8 1/2"  
 ≈ 208' 5"  
 ≈ 202' 5"

170'

131' 9"

104' 1 1/2"

100'

Note: • All Radial distances are measured to the shell center.

• Segments # 23, 24 and 25 were used to account for the effect of the radial St. Veners.

- ○ = Segment #
- X = Beginning and Ending of a Segment


	$r_1^{(a)}$	$r_2^{(b)}$	$Z_1^{(a)}$	$Z_2^{(b)}$	# est Meas'ts	Remark
1	776.0387	780.8125	-49.5	0	6	
2	780.8125	//	0	125	8	
3	//	//	125	200.5	5	
4	//	//	200.5	347.75	10	
5	//	//	347.75	476.25	9	
6	//	//	476.25	621.25	10	
7	//	//	621.25	790.5	11	
8	//	//	790.5	985.0	12	
9	//	//	985.0	1179.5	12	
10	//	//	1179.5	1251.5	5	
11	//	//	1251.5	1375	8	
12	780.8125	736.2974	1375	1525	11	
13	736.2974	582.6925	1525	1675	11	
14	582.6925	259.8404	1675	1800	21	
15	259.8404	0	1800	1825.69	21	
16	780.8125	826	331	331	5	
17	825.6875	825.6875	327	336	5	
18	780.8125	750.0625	790.5	790.5	5	
19	750.0625	750.0625	783.5	797.5	5	
20	780.8125	736.8125	1251.5	1251.5	5	
21	780.8125	736.8125	1179.5	1179.5	5	
22	745.6125	1179.5	745.6125	1251	5	
23	745.6125	1179.5	780.8125	1251	5	(C)
24	780.8125	745.6125	1179.5	1251	5	(D)
25	780.8125	826.0	315.139	331.5	5	(E)

- (a) = Radial and Vertical Coordinates at the beginning of a segment
- (b) = Radial and Vertical Coordinates at the End of a segment
- (c) = Fake segment with  
 $E_{\theta} = 10 \text{ Psc}$  and  $E_{\phi} = 17706070 \text{ Psc}$
- (D) = Fake segment with  
 $E_{\theta} = 10 \text{ Psc}$  and  $E_{\phi} = 17706070 \text{ Psc}$
- (E) = Fake segment with  
 $E_{\theta} = 10 \text{ Psc}$  and  $E_{\phi} = 18376900 \text{ Psc}$

Other segments use:

Loading:  $\nu = 0.3$ ,  $E = 27,400,000 \text{ Psc}$

- 1- Case 1: Uniform Internal Pressure of 45 Psig was applied on segments 1 through 15.
- 2- Case 2: The Pressure distribution shown in the Figure on next page was applied on segments 6 through 15. 80 Fourier harmonics were used in the Analysis




### Output

\* Load Case 1: obtain <sup>surface</sup> stresses and displacement at all mesh points.

\* Load Case 2: obtain <sup>surface</sup> stresses and displacements at all mesh points along  $\theta = 0$  and  $\theta = 180$

## Axisymmetric Model For the Containment Head Buckling



Loading Type = Internal pressure

Young's Modulus = 29,500,000 psi

Yield stress = 60,000 psi

Elastic - Perfect plastic Stress-Strain relationship

The analysis was performed using five segments. The head was modeled as described in the axisymmetric model using four segments.

The problem was analyzed three times to study the effects of reducing the element size on the buckling load. The number of elements used in the analyses were 74, 148 and 296 respectively.