TELEX 440574 INTLAW UI

BISHOP, LIBERMAN & COOK

JUL 24 A10:34 NEW YORK NEW YORK 10004 (212) 248-6900 TELEX 222767

DOCKETING & SEF ERANCH

July 20, 1984

Peter B. Bloch, Esq. Chairman, Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dr. Kenneth A. McCollom Dean, Division of Engineering, Architecture and Technolo / Oklahoma State University Stillwater, Oklahoma 74074

Dr. Walter H. Jordan 881 West Outer Drive Oak Ridge, Tennessee 37830

Re: Texas Utilities Electric Company, et al. Comanche Peak Steam Electric Station, Units 1 and 2 (Docket Nos. 50-445 and 50-446) 0 L

Gentlemen:

In accordance with our obligation to apprise the Board of matters which may bear on issues before it, this will advise that Applicants have concluded that certain fire dampers at Comanche Peak are installed at variance with the Underwriters Laboratories ("UL") test configuration. This variance was detected by Applicants during normal testing of the dampers. In view of the variance, the reliability of operation of these dampers, as installed, is not supported by UL tests. Applicants presently envisage that rework or minor modifications are necessary for approximately 33 dampers. These facts have been reported by Applicants to NRC Region IV pursuant to 10 C.F.R. Part 50.55(e), and to the NRC Staff's Comanche Peak Technical Review Team (T.A. Ippolito, Project Director),.

Sincerely,

Nicholas S. Reynolds Counsel to Applicants

cc: Service List

8407250271 840720 PDR ADOCK 05000445