



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 27, 1984 84 JUL 9 A 9:16

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-021/1 - Update
Report - Fire Door 1A320 Blocked
Open to Support Planned
Maintenance Activities
AECM-84/0324

This is an update to a previous report submitted on May 15, 1984. The condition for which the report was submitted began on April 8, 1984, when fire door 1A320 to the Main Steam Tunnel Room was blocked open to support planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7. The maintenance outage is continuing and work is still being performed in the Main Steam Tunnel. Fire watches will be continued until the fire door is restored. This is submitted as a Special Report pursuant to Technical Specification 6.9.2. This is a final report.

Yours truly,

[Handwritten signature]

L. F. Dale
Director of Nuclear Licensing & Safety

EBS/SHH:rg

- cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555