

October 10, 1995

Florida Power Corporation  
Crystal River Energy Complex  
Mr. P. M. Beard, Jr. (SA2A)  
Sr. VP, Nuclear Operations  
ATTN: Mgr., Nuclear Licensing  
15760 West Power Line Street  
Crystal River, FL 34428-6708

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - CRYSTAL RIVER

Dear Mr. Beard:

On September 21, 1995, the NRC staff completed the semiannual Plant Performance Review (PPR) of Crystal River. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for Crystal River involved the participation of all Regional Technical Divisions and NRR in evaluating inspection results and safety performance information for the period from March 1995 to September 1995. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the Crystal River PPR review. It is provided to minimize the resource impact on your staff and to allow for scheduling conflicts and personnel availability issues to be resolved in advance of inspector arrival onsite. The enclosure details our inspection plan for the next 6 months. The rationale or basis for each inspection outside the core inspection program is provided so that you are aware of the reason for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature.

We will inform you of any changes to the inspection plan. If you have any questions, please contact K. Landis at (404) 331-5509.

Sincerely,

Orig signed by Ellis W. Merschoff

Ellis W. Merschoff, Director  
Division of Reactor Projects

Docket No.: 50-302  
License No.: DPR-72

Enclosure: Inspection Plan

cc w/encl: (See page 2)

9510230320 951010  
PDR ADOCK 05000302  
P PDR

OFFICIAL COPY

210100

1201

cc w/encl:

Gary L. Boldt, Vice President  
Nuclear Production (SA2C)  
Florida Power Corporation  
Crystal River Energy Complex  
15760 West Power Line Street  
Crystal River, FL 34428-6708

B. J. Hickle, Director  
Nuclear Plant Operations (NA2C)  
Florida Power Corporation  
Crystal River Energy Complex  
15760 West Power Line Street  
Crystal River, FL 34428-6708

L. C. Kelley, Director (SA2A)  
Nuclear Operations Site Support  
Florida Power Corporation  
Crystal River Energy Complex  
15760 West Power Line Street  
Crystal River, FL 34428-6708

Gerald A. Williams  
Corporate Counsel  
Florida Power Corporation  
MAC - A5A  
P. O. Box 14042  
St. Petersburg, FL 33733

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, FL 32304

Bill Passetti  
Office of Radiation Control  
Department of Health and  
Rehabilitative Services  
1317 Winewood Boulevard  
Tallahassee, FL 32399-0700

Joe Myers, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, FL 32399-2100

cc w/encl: Continued see page 3





cc w/encl: Continued  
 Chairman  
 Board of County Commissioners  
 Citrus County  
 110 N. Apopka Avenue  
 Inverness, FL 36250

Robert B. Borsum  
 B&W Nuclear Technologies  
 1700 Rockville Pike, Suite 525  
 Rockville, MD 20852-1631

Distribution w/encl:

L. Raghavan, NRR  
 G. Hallstrom, RII  
 PUBLIC

NRC Resident Inspector  
 U.S. Nuclear Regulatory Commission  
 6745 N. Tallahassee Road  
 Crystal River, FL 34428

SEND TO PUBLIC DOCUMENT ROOM?						
YES NO						
OFFICE	RII	RII	RII	RII		
SIGNATURE						
NAME	RSchin	KLandis	KBarr	JCasto		
DATE	10/10/95	10/10/95	10/10/95	10/11/95	10/ / 95	10/ / 95
COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\CR.PPR

**CRYSTAL RIVER  
INSPECTION PLAN**

IP - Inspection Procedure

TI - Temporary Instruction

Core Inspection - Minimum NRC Inspection Program (mandatory all plants)

INSPECTION PROCEDURE	TITLE/ PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - COMMENTS
IP 71001	Licensed Operator Requalification Program Evaluation	2	11/13-17/95	Core Inspection - Also to inspect corrective actions to improve EOPs
IP 84750	Radioactive Waste Systems, Water Chemistry Confirmatory Measurements and Radiological Environmental Monitoring	1	11/27-12/01/95	Core Inspection
IP 86750	Solid Radioactive Waste Management and Transportation of Radioactive Materials			
IP 92702 IP 40501	Corrective Actions for Violations and Deviations Self Assessment - Service Water System Operational Performance Assessment	3	12/04-08/95	Special Inspection on setpoint corrective actions and actions taken to improve the service water system.
IP 40500 IP 92720	Safety Assessment Corrective Action Program	3	01/08-12/96	Regional Initiative Inspect' to review the adequacy or status of the ongoing Safety Assessment and Corrective Action Program at Crystal River.

INSPECTION	TITLE/ PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - COMMENTS
IP 82701	Operational Status of the Emergency Preparedness Program	1	02/26-03/01/96	Core Inspection
IP 64704	Fire Protection Program	1	03/11-15/96	Core Inspection - also to inspect the RCP fire protection oil collection system
	Licensing Examination Preparation	3	03/11-15/96	Operator Exam Preparation
IP 73753	Inservice Inspection	2	03/18-22/96	Core Inspection and Regional Initiative to look at surface flaw in the presurrizer surge line nozzle
	Initial Licensing Examination	3	03/25-29/96	Operator Exam
IP 83750 IP 84750 IP 86750	Occupational Radiation Exposure Radioactive Waste Systems, Water Chemistry Confirmatory Measurements and Radiological Environmental Monitoring Solid Radioactive Waste Management and Transportation of Radioactive Materials	2	03/25-29/96	Core Inspection
IP 81700	Physical Security Program for Power Reactors	1	04/08-12/96	Core Inspection