

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power Corporation
Crystal River

Docket No. 50-302
License No. DPR-72

The following violation was identified during an inspection conducted on April 30 through May 4, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 4.0.5 and 10 CFR 50.55a(g) require that the licensee comply with the ASME Boiler and Pressure Vessel Code, Section XI, 1974 Edition with Addenda through Summer 1975, for testing pumps and valves. Subsection IWP-6210 and IWV-6210 of this Code require the licensee to maintain summary listings of pumps and valves to display the current status of the test program. For pumps, the Code states that when all quantities measured during a test are within the acceptable range of Table IWP-3100-2 only the date of each successful test shall be listed.

Contrary to the above, the licensee did not maintain the summary status listings required by the code.

This is a Severity Level V violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: MAY 31 1984

8407300239 840710
PDR ADDCK 05000302
Q PDR