

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	Docket No. 50-361
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 2 of the San Onofre Nuclear)	No. 147
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 147.


This amendment application consists of Proposed Change Number (PCN)-446, Supplement 1, to Facility Operating License No. NPF-10. PCN-446, Supplement 1, revises the Unit 2 Technical Specification (TS) Table 3.3.3, "Engineered Safety Feature Actuation System Instrumentation." This change will add a note to provide the required compensatory actions to permit extended Toxic Gas Isolation System (TGIS) Allowed Outage times during replacement of TGIS instrumentation under Design Change Package (DCP)-6933.

Subscribed on this 18th day of October, 1995

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: _____




R. W. Krieger
Vice President

State of California
County of ~~Orange~~ San Diego

On October 18, 1995 before me, Linda L. Rulon/Notary Public,
personally appeared R. W. Krieger, personally known to
me to be the person whose name is subscribed to the within instrument and
acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity upon
behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature Linda L. Rulon



UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	Docket No. 50-362
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 3 of the San Onofre Nuclear)	No. 131
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 131.


This amendment application consists of Proposed Change Number (PCN)-446, Supplement 1, to Facility Operating License No. NPF-15. PCN-446, Supplement 1, revises the Unit 3 Technical Specification (TS) Table 3.3.3, "Engineered Safety Feature Actuation System Instrumentation." This change will add a note to provide the required compensatory actions to permit extended Toxic Gas Isolation System (TGIS) Allowed Outage times during replacement of TGIS instrumentation under Design Change Package (DCP)-6933.

Subscribed on this 18th day of October, 1995.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By:



R. W. Krieger
Vice President

State of California
County of ~~Orange~~ San Diego

On October 18, 1995 before me, Linda L. Rulon/Notary Public,
personally appeared R. W. Krieger, personally known to
me to be the person whose name is subscribed to the within instrument and
acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity upon
behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature Linda L. Rulon



ENCLOSURE 1

DESCRIPTION AND SAFETY ANALYSIS
OF PROPOSED CHANGE NPF-10/15-446, SUPPLEMENT 1