Director, Office of Resource Management January Monthly Operating Report Page 3 February 13, 1984 Revised — July 11, 1984

1. Reporting Period: JANUARY 1984

Max. Depend. Capacity (MWe-Net):

2. Currently Authorized Power Level (MWt): 2775

OPERATING STATUS

## ATTACHMENT II OPERATING DATA REPORT

		DATE	V. C. SUMMER I 02/13/84 G. A. Loignon
Wt): Any\(\)	885 900 (Mwe-Net): N	porting Period	:744
N/A	THIS MONTH	YR TO DATE	CUMULATIVE
1	735.0 0 732.8	735.0	0

	Design Electrical Rating (MWe-Net): 900 Power Level to which restricted (If Any)(MWe-Net): N/A Reasons for Restrictions (If Any): N/A				
		THIS MONTH	YR TO DATE	CUMULATIVE	
6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16.	Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator on Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) Reactor Service Factor Reactor Availability Factor Unit Service Factor Unit Availability Factor Unit Capacity Factor (Using MDC) Unit Capacity Factor (Using Design MWe) Unit Forced Outage Rate	735.0 0 732.8 0 1,996,935 668,350 641,948 98.8 98.8 98.5 98.5 97.5 95.9 1.5	735.0 0 732.8 0 1,996,935 668,350 641,948 98.8 98.8 98.5 98.5 97.5 97.5 95.9 1.5	735.0 0 732.8 0 1,996,935 668,350 641,948 98.8 98.8 98.5 98.5 97.5 95.9 1.5	
-					

19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Spring Maintenance Outage, March 26, 1984, 15 Days.

20. If Shut Down at End of Report Period, Estimated Date of Startup: N/A

21. Units in Test Status (Prior to Commerical Operation):

Main or indicated that agreed	FORECAST	ACHIEVED
Initial Criticality	N/A	10-22-82
Initial Electricity	N/A	11-16-82
Commercial Operation	N/A	01-01-84

8407300351 840711 PDR ADOCK 05000395 R PDR