Director, Office of Resource Management March Monthly Operating Report Page 3
April 10, 1984
Pevisad — July 11, 1984

ATTACHMENT II OPERATING DATA REPORT

DOCKET NO.	50/395
UNIT	V. C. SUMMER I
DATE	04/10/84
COMPLETED BY	G. A. Loignon
TELEPHONE	(803) 345-5209

			TELEPHONE (C	03) 345-5209	
OPE	RATING STATUS				
2.	Reporting Period: MARCH 1984 Gross Currently Authorized Power Level (MWt): Max. Depend. Capacity (MWe-Net): Design Electrical Rating (MWe-Net): Power Level to which restricted (If Any)(Reasons for Restrictions (If Any): N/A	2775 885 900		744	
		THIS MONTH	YR TO DATE	CUMULATIVE	
6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17.	Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator on Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) Reactor Service Factor Reactor Availability Factor Unit Service Factor Unit Availability Factor Unit Capacity Factor (Using MDC) Unit Capacity Factor (Using Design MWe) Unit Forced Outage Rate	533.5 0 531.5 0 1,459,743 490,650 468,655 71.7 71.4 71.4 71.2 70.0 0.0	1,910.3 0 1,875.7 0 5,122,987 1,713,230 1,640,182 87.5 87.5 85.9 85.9 84.9 83.4 4.9	1,910.3 0 1,875.7 0 5,122,987 1,713,230 1,640,182 87.5 87.5 85.9 85.9 84.9 83.4 4.9	
19.	Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Scheduled refueling - September 1, 1984				
	If Shut Down at End of Report Period, Estimated Date of Startup: April 18, 1984 Units in Test Status (Prior to Commercial Operation): FORECAST ACHIEVED				
	Initial Criticali Initial Electrici Commercial Operat	ty	N/A 10-22 N/A 11-16 N/A 01-01	-82	