

October 17, 1995

Georgia Power Company
ATTN: Mr. C. K. McCoy
Vice President
Vogtle Electric Generating Plant
P. O. Box 1295
Birmingham, AL 35201


SUBJECT: INSPECTION REPORT NGS.: 50-424/95-18 AND 50-425/95-18

Gentlemen:

Thank you for your response of October 9, 1995, to our Notice of Violation issued on September 12, 1995, concerning activities conducted at your Vogtle facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

We appreciate your cooperation in this matter.

Sincerely,



Pierce H. Skinner
Reactor Projects Branch 2
Division of Reactor Projects

Docket Nos. 50-424, 50-425
License Nos. NPF-68, NPF-81

cc: Mr. J. D. Woodard
Senior Vice President
Georgia Power Company
Nuclear Operations
P. O. Box 1295
Birmingham, AL 35201

J. B. Beasley
General Manager, Plant Vogtle
Georgia Power Company
P. O. Box 1600
Waynesboro, GA 30830

cc: Continued page 2

9510240068 951017
PDR ADOCK 05000424
G PDR

210146

1/0
1201

cc: Continued
J. A. Bailey
Manager-Licensing
Georgia Power Company
P. O. Box 1295
Birmingham, AL 35201

Nancy G. Cowles, Counsel
Office of the Consumer's
Utility Council
84 Peachtree Street, NW, Suite 201
Atlanta, GA 30303-2318

Office of Planning and Budget
Room 615B
270 Washington Street, SW
Atlanta, GA 30334

Office of the County Commissioner
Burke County Commission
Waynesboro, GA 30830

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE, Suite 1252
Atlanta, GA 30334

Thomas Hill, Manager
Radioactive Materials Program
Department of Natural Resources
4244 International Parkway
Suite 114
Atlanta, GA 30354

Attorney General
Law Department
132 Judicial Building
Atlanta, GA 30334

Ernie Toupin
Manager of Nuclear Operations
Oglethorpe Power Corporation
2100 E. Exchange Place
Tucker, GA 30085-1349

Charles A. Patrizia, Esq.
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, D. C. 20004-9500

(Distribution - See page 3)

Distribution:

P. Skinner, RII
 R. Wright, RII
 G. Hallstrom, RII
 D. Hood, NRR
 PUBLIC

NRC Senior Resident Inspector
 U.S. Nuclear Regulatory Commission
 8805 River Road
 Waynesboro, GA 30830

SEND TO PUBLIC DOCUMENT ROOM?		YES		NO	
OFFICE	RII:DRP	RII:DRP			
SIGNATURE	<i>RW</i>	<i>PH</i>			
NAME	RWright:dka	PHSkinner			
DATE	10 / 17 / 95	10 / / 95	10 / / 95	10 / / 95	10 / / 95
COPY?	<input checked="" type="checkbox"/> YES NO	YES NO	YES NO	YES NO	YES NO

CHECKLIST

ROI 0917

EVALUATION OF LICENSEE CORRECTIVE ACTIONS FOR VIOLATIONS

Inspection Rpt No.: 95-18
Plant Name: Vogtle

Violation No.: 95-18-01
Response Received: October 10, 1995

ASSESSMENT BY RII MANAGERS OF LICENSEE'S CORRECTIVE ACTION:

Was the Root Cause for the Violation Addressed? If no, explain.

Yes

Were the Steps Taken Adequate to Correct the Problem and Prevent Future Violation? Yes

Results Achieved: The involved operator was counseled on the necessity of familiarity and compliance with applicable procedures and for using the STAR technique of self checking. The USS was counseled on the need to verify that all requirements to accomplish an activity are in compliance & the need to thoroughly brief personnel on the expectations & requirements of that activity. These individuals were counseled on September 7-8, 1995. This event will be presented in operator training and the procedure checklist will be reviewed for improvements by November 15, 1995.

Additional Corrective Steps That Will Be Taken: see above

Date of Full Compliance Indicated: November 20, 1995.

Robert W. Wright
Project Engineer
10/17/95
Date

Recommended Actions:

Response Letter

Telephone Call To Licensee

Letter Requesting Supplemental Information

Approved By: [Signature]
Branch Chief

10/17/95
Date

cc: Division Director
Original to Docket File