Houston Lighting & Power South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

October 16, 1995 ST-HL-AE-5180 File No.: G03.08 10CFR50

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555-0001

**The Light** 

compa

South Texas Project Electric Generating Station Units 1 and 2 Docket Nos. STN 50-498, STN 50-499 Response to NRC Generic Letter 95-07: "Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves"

Reference: NRC Generic Letter 95-07: "Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves dated August 17, 1995"

South Texas Project intends to implement the actions requested in the referenced letter. The attachment to this letter is the schedule for completion of the requested actions.

If there are any questions regarding this request, please contact Mr. S. E. Thomas at (512) 972-7162 or me at (512) 972-8787.

T. H. Clopinger Vice President, Niclear Engineering

KJT/lf

Attachment: Schedule for Completion of Actions Requested in NRC Generic Letter 95-07

9510240081 951016 PDR ADDCK 05000498 PDR GLB-95/5180

Project Manager on Behalf of the Participants in the South Texas Project

Houston Lighting & Power Company South Texas Project Electric Generating Station

C:

Leonard J. Callan Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011-8064

Thomas W. Alexion Project Manager U. S. Nuclear Regulatory Commission Washington, DC 20555-0001 13H15

David P. Loveless Sr. Resident Inspector c/o U. S. Nuclear Regulatory Comm. P. O. Box 910 Bay City, TX 77404-0910

J. R. Newman, Esquire Morgan, Lewis & Bockius 1800 M Street, N.W. Washington, DC 20036-5869

K. J. Fiedler/M. T. HardtCity Public ServiceP. O. Box 1771San Antonio, TX 78296

J. C. Lanier/M. B. Lee City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704

Central Power and Light Company ATTN: G. E. Vaughn/C. A. Johnson P. O. Box 289, Mail Code: N5012 Wadsworth, TX 77483 ST-HL-AE-5180 File No.: G03.08 Page 2

Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 61067 Houston, TX 77208

Institute of Nuclear Power Operations - Records Center 700 Galleria Parkway Atlanta, GA 30339-5957

Dr. Joseph M. Hendrie 50 Bellport Lane Bellport, NY 11713

Richard A. Ratliff Bureau of Radiation Control Texas Department of Health 1100 West 49th Street Austin, TX 78756-3189

U. S. Nuclear Regulatory Comm. Attn: Document Control Desk Washington, D. C. 20555-0001

J. R. Egan, Esquire Egan & Associates, P.C. 2300 N Street, N.W. Washington, D.C. 20037

J. W. Beck Little Harbor Consultants, Inc. 44 Nichols Road Cohassett, MA 02025-1166

#### UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

In the Matter of

Houston Lighting & Power Company, et al., Docket Nos. 50-498 50-499

South Texas Project Units 1 and 2

#### AFFIDAVIT

I, T. H. Cloninger, being duly sworn, hereby depose and say that I am Vice President, Nuclear Engineering, of Houston Lighting & Power Company; that I am duly authorized to sign and file with the Nuclear Regulatory Commission the attached response to NRC Generic Letter 95-07; that I am familiar with the content thereof; and that the matters set forth therein are true and correct to the best of my knowledge and belief.

H. Cloninger Vice President, Nuclear Engineering

STATE OF TEXAS

COUNTY OF MATAGORDA

Subscribed and sworn to before me, a Notary Public in and for the State of Texas, this 16 th day of October, 1995.



inda Kittenh

Notary Public in and for the State of Texas

ST-HL-AE-5180 Page 1 of 2 Attachment

## SCHEDULE FOR COMPLETION OF ACTIONS REQUESTED IN NRC GENERIC LETTER 95-07

## SOUTH TEXAS PROJECT UNITS 1 AND 2

# Reference: NRC Generic Letter 95-07: "Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves dated August 17, 1995"

NRC Generic Letter 95-07 requested licensees take specific actions to address pressure locking and thermal binding of safety-related, power-operated (including motor-, air-, and hydraulically operated) gate valves. South Texas Project plans to work closely with the Westinghouse Owner's Group in developing a program to address the requirements of NRC Generic Letter 95-07. It is expected that a common set of screening criteria will be developed for identifying valves potentially susceptible to pressure locking and thermal binding, taking into account both component and systems considerations. As the susceptible valves are identified, the need for additional analysis and/or valve modifications will be determined.

The following is an initial schedule developed to complete evaluations and assess any necessary corrective action.

South Texas Project plans to complete the following actions by November 15, 1995.

1. Perform screening evaluation of operational configurations of all safety-significant power-operated gate valves to identify those valves that are potentially susceptible to pressure locking or thermal binding.

2. Document a basis for operability of the potentially susceptible valves or, where the operability cannot be supported by the evaluation, take actions in accordance with Technical Specifications.

ST-HL-AE-5180 Page 2 of 2 Attachment

South Texas Project will comply with all actions and responses specified in the 180day required response of the referenced generic letter by February 13, 1996. These include completion and documentation of the following:

1. Evaluate the operational configurations of safety-significant power-operated gate valves to identify valves that are susceptible to pressure locking or thermal binding.

2. Perform furthe, analyses as appropriate, and take needed corrective actions (or justify longer schedules), to ensure that the susceptible valves identified are capable of performing their intended safety function(s) under all modes of plant operation, including test configurations.

3. Provide a written response to the NRC to include a summary description of the following:

(a) The evaluation of the operational configurations of safety-significant power-operated gate valves to identify valves that are susceptible to pressure locking or thermal binding and further analyses performed including the bases or criteria for determining that valves are or are not susceptible to pressure locking or thermal binding;

(b) The results of the susceptibility evaluation and the further analyses referred to in 3 (a) above, including a listing of the susceptible valves identified;

(c) The corrective actions, or other dispositioning, for the valves identified as susceptible to pressure locking or thermal binding, including: (i) equipment or procedural modifications completed and planned (including the completion schedule for such actions); and (ii) justification for any determination that particular safety-significant power-operated gate valves susceptible to pressure locking or thermal binding are acceptable as is.