


TEXAS UTILITIES GENERATING COMPANY

SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

BILLY R. CLEMENTS
VICE PRESIDENT, NUCLEAR OPERATIONS

July 20, 1984
TXX-4235



Mr. E.H. Johnson, Chief
Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Docket Nos.: 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
CURTAIN FIRE DAMPERS
QA FILE: CP-84-08, SDAR-132
FILE NO.: 10110

Dear Mr. Johnson,

On March 9, 1984 we verbally contacted your Mr. D. Hunnicutt of a deficiency with the installation of curtain fire dampers without proper provisions for thermal expansion. We have previously submitted interim reports logged TXX-4140 and TXX-4188 dated March 30, 1984 and June 4, 1984, respectively.

On July 18, 1984 at the CPSES site, we verbally advised your Messrs. Collins, Hunnicutt, Bangart, and Cummins and Mr. Wessman of NRR of our determination that this item is reportable under 10CFR50.55(e). Our evaluation is progressing. We will submit our formal report by August 13, 1984, the date previously established by our letter TXX-4188.

Very truly yours,

for
DR Chapman
Billy R. Clements

BRC/tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8407310001 840720
PDR ADOCK 05000445
S PDR

FE-27 *1/0*